

Date 1-31-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK W/O, REMOVED METERS
Jobs Completed	PUMPED OUT VAULTS/BOXES + READ METERS
Employees on Job F.P.-B.S. G.F.-T.C. 4 HR 4 HR	
Vehicles or Equip. Used 11-8-14	

Sewer Department

Address	CHECKED STATIONS TURNED ON BELLEVUE CYCLED OAKLAND
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 63RD + PITTSBURG + CALVIN BLVD.
Employees on Job K.M.-F.P.-B.S. 4 HR	CHANGED TOP FLOATBALL AT BRIDGEWAY
Vehicles or Equip. Used 14-15	

Ex. 7f (Water Infra.)

Meter Readers

Employees on Job T.C.-K.M. 4 HR	FINISHED AREA #2
Areas - Read	
Vehicles Used	
General Foreman <u>Frank J. Pace</u>	

Date 2-1-19

Daily Job Sheet

Sheet ____ of ____

Water Department

Comments

Address	OVERTIME CALL OUT
Jobs Completed	SHUT OFF METER AT PER CUST. REQUEST - BROKEN PIPE UNDER TRAILER
Employees on Job F.P.	
Vehicles or Equip. Used 11	

Ex. 6 (Personal Privacy)

Sewer Department

Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 1-30-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. LOCATRS	
Jobs Completed	CLEANED BREAK ROOM/SHOP CHANGED OIL IN 3" & 2" PUMPS	
Employees on Job F.P. - G.F. - T.C. / B.S. 4 HR / K.M. GHR		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address	CHANGED BELTS AT BRIDGE DALE - FLOATBALL IS ACTING UP - PUMP WAS NOT PUMPING UNTIL FLOATBALLS ARE PULLED UP & DOWN	
Job Completed	CHANGED BELTS AT OAKLAND	
Employees on Job B.S. - K.M. 2 HR		
Vehicles or Equip. Used 14		
Meter Readers		
Employees on Job F.P. 4 HR	FINISHED CYCLE 5 RADIO READS	
Areas - Read		
Vehicles Used 14		
General Foreman <u>Frank J. Rue</u>		

Date 1-29-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICK TRUCK W.O.	
Jobs Completed		
Employees on Job G.F. 6		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address	JETTED LINE TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy) 250 FOUND & CLEARED MANHOLE IN STREET TO JET FROM	
Job Completed	JETTED LINE FROM Ex. 6 (Personal Privacy) TOWARD HOSPITAL & UP MITCHELL IN FRONT OF Ex. 6 (Personal Privacy) OUR LINES ARE	
Employees on Job F.P. - B.S. - T.C. 4 PR	CLEAN & FLOWING - LATERAL IS HOLDING CHECKED FOR BACKUP AT Ex. 6 (Personal Privacy) COST. PROBLEM	
Vehicles or Equip. Used 14-15-9	PULLED BACK OFF PUMP & CLEANED OUT RAGS AT Ex. 6 (Personal Privacy) DRAINED UNIT #9	
<u>Meter Readers</u>		
Employees on Job T.C. - K.M. - G.F. 4 PR	FINISHED AREAS 29 - T.C. - K.M. - G.F. - 1 - K.M.	
Areas - Read	STARTED 2 - K.M.	
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		

Date 1-28-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job B.S.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) LAKE PILL BOX	
Job Completed	CYCLED BLOWERS AT OAKLAND & CROCKETTS	
Employees on Job K.M. F.P. - T.C. 4KR 2KR 1KR	JETTED LINE TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 14-15-9		
<u>Meter Readers</u>		
Employees on Job F.P. - T.C. 6KR 1KR	FINISHED AREAS 24-F.P. - 22-T.C. - 26-F.P. & T.C. CYCLE # RADIO READS F.P.	
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 1-26-19

Daily Job Sheet

Sheet ____ of ____

<u>Water Department</u>		Comments
Address	2 HR DOUBLETIME CALL OUT	
Jobs Completed	INSTALLED METER AT Ex. 6 (Personal Privacy)	
Employees on Job F.P. 1 HR		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address	DOUBLETIME	
Job Completed	JACKETED LINE ON CLARITA TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy)	
Employees on Job D.T. - F.P. 1 HR		
Vehicles or Equip. Used 14-9		
<u>Meter Readers</u>		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman _____		

Date 1-25-19

Daily Job Sheet

Sheet ____ of ____

<u>Water Department</u>		Comments
Address		OVERTIME 2 HR
Jobs Completed		
Employees on Job		
Vehicles or Equip. Used		
<u>Sewer Department</u>		
Address		
Job Completed		JETTED LINE ON CLARITA
Employees on Job D.T. - K.P.		
Vehicles or Equip. Used 9-14		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 1-25-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	REPAIRED 8" C.I. MAIN BREAK AT Ex. 6 (Personal Privacy) UPPER CAHOKIA - USED ONE 8" C.I. X 24" S.S. REPAIR CLAMP BACKFILLED	
Employees on Job F.P. - B.S. - K.M. 7 HR 6 HR 2 HR	WITH SPOIL - NEEDS ROCK ON EDGE OF Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 11-14-15 - BACKHOE		
<u>Sewer Department</u>		
Address	FOUND MANHOLES IN CLARITA FOR JET JOB	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 713 Ex. 7f (Water Infra.) LAKE PILL BOX	
Employees on Job F.P. - K.M. 1 HR 4 HR		
Vehicles or Equip. Used 14-15		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 1-24-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	SHUT OFF CORP, STOP AT MAIN AT Ex. 6 (Personal Privacy) WARE HIT BY PASSCOMM BORING	
Employees on Job F.P. - B.S. GHR		
Vehicles or Equip. Used 11-14 - BACKHOLE		
<u>Sewer Department</u>		
Address	JETTED LINE TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy)	
Job Completed		
Employees on Job D.T. & B.S. 2HRC		
Vehicles or Equip. Used 9 & 14		
Meter Readers		
Employees on Job K.M.	FINISHED 20 & 21	
Areas - Read		
Vehicles Used 8		
General Foreman _____		

Date 1-23-19

Daily Job Sheet

Sheet ___ of ___

Water Department

Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

OVERTIME 2 1/2 hrs

Job Completed

JETTED LINE WITH VILLAGE OF
CAHOKIA AT **Ex. 6 (Personal Privacy)**

Employees on Job

T.C.

Vehicles or Equip. Used

9

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 1-23-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O.

Jobs Completed

CRIMPED LINE TO Ex. 6 (Personal Privacy) HIT BY
PASSCOMM LLC BORING CREW

Employees on Job

F.P. - B.S. - T.C.
4HR 2HR

Vehicles or Equip. Used

11-14

Sewer Department

Address

PULLED BACK OFF PUMP & CLEANED
RAGS OUT AT Ex. 6 (Personal Privacy) REELS
B50 BELTS & PENETRATING FLUID FOR

Job Completed

BELT ADJUSTER - RUSTED

Employees on Job

K.M. - B.S.
1HR

Vehicles or Equip. Used

14

Meter Readers

Employees on Job

K.M. B.S. T.C.
3HR 3HR 6HR

FINISHED

23-T.C.

19-B.S.-T.C.-K.M.

Areas - Read

STARTED

24-T.C.

Vehicles Used

8-14

General Foreman

Franky - Ace

Date 1-22-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O.

LOCATES

Jobs Completed

REPAIRED MAIN BREAK AT
4 UPPER CAHOKIA RD. - USED ONE 8"
C.I. SS, REPAIR CLAMP - BACKFILLED WITH

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - B.S. - T.C. - K.M.
5HR 4HRONE LOAD CLEAN ROCK & 1/2 LOAD C-M-G
ROCK - 1/2 LOAD AT SHOP

Vehicles or Equip. Used

6-14-15-BACKHOLE

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP
AT 71ST. LAKE PILL BOX

Ex. 6 (Personal Privacy)

Job Completed

CYCLED BLOWERS AT OAKLAND &
CROCKETTS

Employees on Job

K.M.
4HR

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

T.C.
3HRSTARTED
20

Areas - Read

Vehicles Used

8

General Foreman

Frank J. Pace

Date 1-21-19

Daily Job Sheet

Sheet ___ of ___

Water Department

Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman Frank P. PaceH
O
L
I
D
A
YM
L
KD
A
Y

Date 1-19-19

Daily Job Sheet

Sheet of Water Department

Comments

Address

INSTALLED METER AT

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

INSTALLED 3" RADIO READ
METER

Jobs Completed

Employees on Job

F.P. - G.F.

3 HR DOUBLE TIME

Vehicles or Equip. Used

14

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 1-18-19

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK W.O.

Jobs Completed

REPAIRED MAIN BREAK AT
BREAK WAS NEXT TO TAP FOR
USED ONE 8" S.S. REPAIR CLAMP WITH 3/4" TAP,

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - G.F. - T.C. - K.M.

ONE 3/4" CORP. STOP, ONE 3/4" P.I.C. BARBX 3/4" COMP.
FITTING, 18" OF 3/4" COPPER TUBING - BACKFILLED
WITH TWO LOADS OF CLEAN ROCK + 1/2 LOAD C-M-G

Vehicles or Equip. Used

1/2 LOAD CM-G AT SHOP

G-11-14-15-BOTH BACKHOES

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 1-17-19

Daily Job Sheet

Sheet 1 of 1Water Department

Comments

Address

Service TRUCK

Jobs Completed

WORK orders

Employees on Job

GF

Vehicles or Equip. Used

11

Sewer Department

Address

Jetted Line AT

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Job Completed

REPLACED BELTS AT 63rd

Ex. 6 (Personal Privacy)

Employees on Job

BS
TCADDED OIL TO OAKLAND
UNABLE TO REMOVE DRAIN PLUG

Vehicles or Equip. Used

14
JETALSO OAKLAND NEEDS 2-
B-60 BELTS -

Ex. 6 (Personal Privacy)

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

B. Smith

Date _____

Daily Job Sheet

Sheet ____ of ____

Water Department

Comments

Address	Work Orders
Jobs Completed	
Employees on Job G.F.	
Vehicles or Equip. Used 11	

Sewer Department

Address	Bypass pumped 71 st → pillbox, cycled stations oakland @ crockett.
Job Completed	Changed oil ^a ; Ames, Beachland, Crocketts, Clinton, 63 rd Ex. 7f (Water Infra.) Bluff
Employees on Job B.S. - T.C. - K.M.	
Vehicles or Equip. Used 14, 8, 15	

Meter Readers

Employees on Job

Areas - Read

Vehicles Used


General Foreman



Date 1-15-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	Work orders	
Jobs Completed		
Employees on Job G.F. - B.S. - T.C.		
Vehicles or Equip. Used 8, 11, 14		
<u>Sewer Department</u>		
Address	Bypass pumped Calvin	
Job Completed	Pulled and cleaned pump @ checked stations. Cycled blowers crockett	
Employees on Job B.S. - K.M.		
Vehicles or Equip. Used Backhoe, 14, 15		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman		

Ex. 6 (Personal Privacy)

Ex. 7f (Water Infra.)

Date 1-14-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK W.O.
	CLEANED SNOW AT SHOP
Jobs Completed	
Employees on Job G.F. - T.C. - F.P. 4 HR 2 HR	
Vehicles or Equip. Used 8-11- BACKHOF	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) LAKE PILL BOX
Job Completed	CYCLED BLOWERS AT OAKLAND & CROCKETTS
Employees on Job F.P. - B.S. - T.C. - K.M. 6 HR 4 HR	JETTED LINE ON BATES TO RELIEVE BACKUP CALL AT Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 8-7-15- BACKHOF-9	PULLED PUMPS 1 & 2 AT Ex. 7f (Water Infra.) CLEANED OUT RACS/MOPS FROM PUMPS & RE-SET PUMPS - PUMPING NOW

Meter ReadersEmployees on JobAreas - ReadVehicles UsedGeneral Foreman Franky Pace

Date 1-11-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job G.F. GPR		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address		INSTALLED & WIRED PUMP & FLOATBALL AT BEHINS Ex. 6 (Personal Privacy)
Job Completed		INSTALLED & WIRED UP PUMP AT 75TH Ex. 7f (Water Infra.) CHECKED STATIONS ON SOUTH END
Employees on Job F.P. - B.S. - T.C. - K.M.		BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) LAKE PILL BOX 75TH Ex. 7f (Water Infra.) INSTALLING PUMP
Vehicles or Equip. Used 8-9-7-15-BACKHOE		CYCLED BLOWERS AT OAKLAND & Ex. 7f (Water Infra.) TURNED ON PERSHING
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 1-10-18

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK W.O. <hr/> LOCATES / MAIL
Jobs Completed	
Employees on Job G.F. - F.P. 2 HR	
Vehicles or Equip. Used 8-11	

Sewer Department

Address	EXPOSED VERTICAL LATERAL TO MAIN, SETTLED & USED CUTTER ON UNIT #9 BUT COULDN'T GET THROUGH BLOCK - BACKFILLED
Job Completed	ROAD WITH ROCK AT Ex. 6 (Personal Privacy)
Employees on Job B.S. - T.C. - <u>F.P. - K.M.</u> 4 HR	BY-PASS PUMPED WITH 3 rd GAS PUMP AT 75TH Ex. 7f (Water Infra.)
Vehicles or Equip. Used 7-9-8- BACKHOL-15	CYCLED BLOWERS FOR 4 HOURS AT OAKLAND, CROCKETTS & PERSHING

Meter Readers

Employees on Job <u>K.M. - F.P.</u> 4 HR	FINISHED 13414 - K.M. / CYCLE 4 RADIO F.P. READS
Areas - Read	
Vehicles Used 8-15	

General Foreman Franky Pace

Date 1-9-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		<u>Comments</u>	
Address		SERVICE TRUCK W.O. PUMPED OUT VAULTS & READ METERS	
Jobs Completed		LOCATED OUT IN FRONT OF BORING CREW ON 157 LOCATES	
Employees on Job B.S. - G.F.			
Vehicles or Equip. Used 7-11			
<u>Sewer Department</u>			
Address			
Job Completed			
Employees on Job			
Vehicles or Equip. Used			
Meter Readers			
Employees on Job F.P. - K.M.		FINISHED 17 & 18 - F.P. 12 - K.M.	
Areas - Read		STARTED 13 - K.M.	
Vehicles Used			
General Foreman		<u>Frank J. Pace</u>	

Date 1-8-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address	Service Truck - W.O
Jobs Completed	
Employees on Job G.F - B.S - KM	
Vehicles or Equip. Used 11-14-15	

Sewer Department

Address	Pumped down 71 st + pillbox on 71 st Pumped down 73 rd street Ex. 7f (Water Infra.) using 3" pump.
Job Completed	
Employees on Job KM	
Vehicles or Equip. Used	

Meter Readers


Employees on Job G.F - K.M - T.C	Started (15) Finished (15) 4 - GF 2 - KM	Started (12) (17) 8 - T.C
Areas - Read	Started & Finished 11	
Vehicles Used		

General Foreman Ryan McCall

Date 1-7-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address		
Jobs Completed		
Employees on Job		
Vehicles or Equip. Used		
<u>Sewer Department</u>		
Address K.M.B.S.		Installed motor @ sewer station on 73 rd street. Ex. 7f (Water Infra.)
Job Completed K.M.B.S.		W.D. Jetted line on bates
Employees on Job K.M., B.S., T.C.		
Vehicles or Equip. Used 14, 15		
<u>Meter Readers</u>		
Employees on Job T.C., G.F.		Finished 4 & 5 G.F. Finished 8 & 9 - T.C.
Areas - Read T.C. 7hr		
Vehicles Used 11/8		
General Foreman 		

Date 1-4-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	REPAIRED LEAK ON BELL ON DONNA - CUT OUT 28" OF 6" C.I. MAIN & REPLACED WITH TWO 6" SOLID SLEEVES & 27" OF 6"
Employees on Job G.F. - F.P. - B.S.	C-900 P.V.C. BLOCKED UNDER SLEEVES BACKFILLED WITH 3 BUCKETS OF SAND FROM SHOP & SPOIL - NEED TO REPAIR YARDS
Vehicles or Equip. Used 11-14-15-BACKHOLE	

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

T.C. - K.M.
4 MR

FINISHED

4 - K.M.

6 & 7 - T.C.

Areas - Read

STARTED

8 - T.C.

Vehicles Used

General Foreman

Frank J. Pace

Date 1-3-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK W.O.
Jobs Completed	FOUND LEAK ON DONNA - LEAK IS ON A BELL NEED TO CUT OUT BELL & REPLACE - NEED SOLID SLEEVES TO DO JOB (OR USE 501 EXTR.)
Employees on Job B.S. - K.M. G.F. 6 HR	
Vehicles or Equip. Used 14-15 - 11 - BACKHOL	

Sewer Department

Address	JETTED LINE ON BATES TO RELIEVE BACKUP AT HIGH RISE
Job Completed	PULLED PUMP FROM BEHIND LAURALEE & BROUGHT TO SHOP
Employees on Job F.P. - T.C. - B.S. - K.M. 2 HR 1 HR 2 HR	
Vehicles or Equip. Used 7-9-15-14	

Meter Readers

Employees on Job F.P. - T.C. 6 HR 7 HR	FINISHED CYCLES 243 RADIO READS / 3 T.C.
Areas - Read	STARTED 406 T.C.
Vehicles Used 8-7	

General Foreman Frank J. Pace

Date 1-2-19

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job G.F.	
Vehicles or Equip. Used 11	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT G3RD Ex. 6 (Personal Privacy)
Job Completed	PULLED MOTOR & TOOK TO SHOP AT 73RD - Ex. 6 (Personal Privacy) NEEDS NEW CONDUIT ON OUTSIDE OF CAN ALSO
Employees on Job F.P. - B.S. - K.M.	TRIED TO FIND LAMP HOLE AT Ex. 6 (Personal Privacy) NEED BACKHOLE TO EXPOSE MAIN
Vehicles or Equip. Used 14-15	CHECKED STATIONS - NEED TO PULL PUMP BEHIND Ex. 6 (Personal Privacy) NOT PUMPING

Meter Readers

Employees on Job T.C.	FINISHED 10
Areas - Read	STARTED 346
Vehicles Used 8	

General Foreman Frank J. Pace

Date 1-1-19

Daily Job Sheet

Sheet ___ of ___

Water Department

Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

New

YEARS

DAY

HOLIDAY

Water Department		Comments	
Address		SERVICE TRUCK W.O.	
		LOCATES	
Jobs Completed		DRAINED OUT CHURCH RD. TANK	
Employees on Job F.P. - G.F.		CHECKED SOUTH END SEWERS	
Vehicles or Equip. Used			
11-14			
Sewer Department			
Address			
Job Completed			
Employees on Job			
Vehicles or Equip. Used			
Meter Readers			
Employees on Job T.C. - K.M.		FINISHED 3-T.C. 7+10-K.M. RADIO READS F.P.	
Areas - Read		STARTED 8-K.M.	
Vehicles Used 8-15			
General Foreman <u>Frank J. Pace</u>			

Date 2-27-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		CLOSED 12" VALVE & OPENED HYDRANT VALVE & HYDRANT TO DRAIN TANK ON CHURCH RD.
Employees on Job		
F.P.-T.C. G.F. 3 HR		
Vehicles or Equip. Used		
11-14		

Sewer Department		
Address		JETTED LINE ON BATES TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy)
Job Completed		JETTED LATERAL AT Ex. 6 (Personal Privacy) LINE OPENED UP IN THE A.M. BUT WAS BLOCKED AGAIN IN THE P.M.
Employees on Job		BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) AKE PILL BOX CALVIN CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.) OAKLAND NEEDS NEW HOSE
Vehicles or Equip. Used		REMOVED WET ROCK & REPLACED WITH 1 LOAD PLUS C-MG ROCK AT Ex. 6 (Personal Privacy) GRADED ROAD & DRIVE - MOVED SPOT LIGHT AT SNOWS STATION
9-6-15-14-BACKHOE		

Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		

General Foreman Frank J. Pace

Date 2-26-19

Daily Job Sheet

Sheet ____ of ____

Water Department**Comments**

Address

SERVICE TRUCK W/O

Jobs Completed

Employees on Job

G.F.
4 HR

Vehicles or Equip. Used

11

Sewer Department

Address

EXPOSED VERTICAL LATERAL TO MAIN - JETTED
+ RAN CUTTER + OPENED DRAIN - COULD NOT
HOOK UP LATERAL DUE TO ODD PIPE SIZE

Job Completed

CONCRETE LATERAL IS O.D. 7.90
BACKFILLED WITH SPOIL ROCK + C-MG
FROM SHOP

Employees on Job

F.P. - T.C. - K.M.

Vehicles or Equip. Used

14-9- BACKHOLE

Meter Readers

Employees on Job

G.F.
4 HR

FINISHED

1-2-24-25-26-29-16 Radio Reads

Areas - Read

Vehicles Used

11

General Foreman

Frank J. Pace

Date 2-26-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address		$\frac{1}{2}$ HOUR OVERTIME FOR LUNCH
Jobs Completed		SETTLED & CUT 8" LATERAL TO MAIN,
Employees on Job F.P. - T.C. - K.M.		
Vehicles or Equip. Used		
9-14- BACKHOK		
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Franky Pace</u>		

Water Department		Comments
Address		SERVICE TRUCK W/O. RE-READS
Jobs Completed		
Employees on Job F.P. - G.S. 2 HR		
Vehicles or Equip. Used 11-14		
Sewer Department		
Address		
Job Completed		BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) LAKE PILL BOX
Employees on Job K.M. 4 HR		CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.)
Vehicles or Equip. Used 15		
Meter Readers		
Employees on Job K.M. - F.P. & G.F. 4 HR 6 HR		FINISHED 1 & 2 - K.M. 29 - F.P. & G.F.
Areas - Read		
Vehicles Used 8-14		
General Foreman <u>Frank J. Pace</u>		

Date 2-22-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK W.O. RAISED VALVE BOX FOR Ex. 6 (Personal Privacy)
Jobs Completed	SHUT OFF SERVICE FOR Ex. 6 (Personal Privacy) AT MAIN - SHUT OFF CORP STOP
Employees on Job F.P. - G.F. - T.C.	CHANGED 1" METER AT Ex. 6 (Personal Privacy) RAISED METER BOX WITH 3" CLAY RISER CUT AT SHOP AT Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 11-14-BACKHOE	GRADED ROAD WITH C-M-G ROCK AT WRIGHT Ex. 6 (Personal Privacy) RE VALVE WAS REPLACED GRADED ROAD WITH C-M-G ROCK AT Ex. 6 (Personal Privacy) HARVEST WHERE SADDLE WAS REPLACED

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) LAKE PILL BOX, 63RD & PITTSBURG & CALVIN
Job Completed	CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.)
Employees on Job K.M.	
Vehicles or Equip. Used 15	

Meter ReadersEmployees on JobAreas - ReadVehicles UsedGeneral Foreman Frank J. Pace

Date 2-21-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address		SERVICE TRUCK W.O. LOCATES
Jobs Completed		REPLACED BACKSIDE METER COUPLING AT Ex. 6 (Personal Privacy)
Employees on Job F.P.-T.C. G.P. 4HR		CUT OUT 2" METER WITH TORCH AT Ex. 6 (Personal Privacy)
Vehicles or Equip. Used		
14-11 - BACKHOE		

<u>Sewer Department</u>		
Address		BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) ARE PILL BOX CALVIN BLVD
Job Completed		CYCLED BLOWERS AT OAKLAND & Ex. 7f (Water Infra.)
Employees on Job F.P. - K.M. 4HR		LOCATED & EXPOSED MANHOLES ON END OF Ex. 7f (Water Infra.) - M.H. IN FRONT OF Ex. 6 (Personal Privacy) DOWN IN CHANNEL
Vehicles or Equip. Used		PRIMED PUMPS AT Ex. 6 (Personal Privacy) CHECKED Ex. 7f (Water Infra.) & SUPERIOR - ALL GOOD

Meter Readers		
Employees on Job T.C. 4HR		FINISHED AREA 22
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 2-20-19

Daily Job Sheet

Sheet of **Water Department****Comments**

Address

SERVICE TRUCK W.O.

CLEANED SNOW/ICE FROM FRONT WALK
& SPREAD ICE MELT

Jobs Completed

HAULED 1 BUCKET OF C-M-6 ROCK TO
Ex. 6 (Personal Privacy) WHERE SEWER WORK WAS
DONE & GRADED ROAD.

Employees on Job

F.P.-B.S. - G.F.

2 HR

Vehicles or Equip. Used

14-11- BACKHOLE

Sewer Department

Address

PULLED BOTH PUMPS & CLEANED OUT RAGS
AT Ex. 7f (Water Infra.) TRIED TO DRILL HOLES FOR
PIPE SYSTEM BRACKET BUT NEEDED CONCRETE BIT

Job Completed

PULLED PUMP #1 & REMOVED CHAIN THAT
WAS SUCKED UP INTO PUMP - PUMPING
& CYCLING NOW. AT Ex. 6 (Personal Privacy)

Employees on Job

F.P.-B.S. - K.M.

4 HR

Vehicles or Equip. Used

14-15- BACKHOLE

Meter Readers

Employees on Job

F.P.-B.S. - K.M. - T.C.

4 HR

FINISHED

19-B.S. & K.M. & T.C. - 26-T.C.

RADIO READS
F.P.

Areas - Read

STARTED

22-T.C.

Vehicles Used

8-14

General Foreman

Frank J. Pace

Date 2-19-18

Daily Job Sheet

Sheet of **Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

C.A. - B.S.
4 HR

Vehicles or Equip. Used

11-

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST Ex. 7f (Water Infra.) ARE PILL BOX

Job Completed

CYCLED BLOWERS AT OAKLAND

Ex. 7f (Water Infra.)

Employees on Job

K.M. B.S.
6 HR 4 HR

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

F.P. - K.M.
T.C. 6 HR 2 HR

FINISHED

20 - F.P. - 21 - F.P. & K.M.

Finished

23 & 24 - T.C.

Areas - Read


STARTED

26 - T.C.

Vehicles Used

7-8-15

General Foreman



Date 2-18-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address		SERVICE TRUCK W/O.
Jobs Completed		REPLACED 6" VALVE AT JEROME USED ONE 6" TAPPING GATE VALVE, ONE 6" 50' EXTREME, 50' OF 6" C-900 P.T.C. PIPE, ONE LOAD CLEAN ROCK & 1/2 LOAD C-M6 ROCK
Employees on Job F.P. - G.F. - T.C. - K.M.		SET VALVE BOX 2" VALVE IS 30' EAST OF 6" VALVE. (TOWARDS TRACK)
Vehicles or Equip. Used		
11-14-6" BACKHOE		

Ex. 6 (Personal Privacy)

Sewer Department	
Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	
Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	
General Foreman <u>Frank J. Pace</u>	

Date 2-15-19

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK W.O.
LOCATE

Jobs Completed

BROKE PAVEMENT AROUND VALVE TO
BE REPLACED AT JEROME Ex. 6 (Personal Privacy)
CHECKED VALVE BOXES TO BE SHUT OFF

Employees on Job

F.P. - G.H. B.S.
DNR

Vehicles or Equip. Used

11-14

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
TIST Ex. 7f (Water Infra.) AKE PILL BOX

Job Completed

CYCLAD BLOWERS AT OAKLAND Ex. 7f (Water Infra.)

Employees on Job

B.S.
G.H.

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 2-14-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

SERVICE TRUCK W.O.

LOCATES

Jobs CompletedCHECKED FOR LEAK AT
GROUND WATER - NOT A LEAK.

Ex. 6 (Personal Privacy)

Employees on JobG.F. + B.S. - F.P.
4HR 2HR**Vehicles or Equip. Used**

11-8-7

Sewer Department**Address**CYCLED **Ex. 7f (Water Infra.)** THROUGHOUT DAY
GOT DOWN TO 4.30 ON PANEL 2
I COULD SEE INCOMING LINE**Job Completed****Employees on Job****Vehicles or Equip. Used****Meter Readers****Employees on Job**F.P. - B.S.
6HR 4HR

FINISHED

17-B.S. - 18-F.P.

Areas - Read**Vehicles Used**

7-8

General Foreman

Franky Pace

Date 2-13-19

Daily Job Sheet

Sheet of **Water Department****Comments**

Address

SERVICE TRUCK W/O.

LOCATES

Jobs Completed

HAULED OFF SPOIL & ROCKED DRIVE
WHERE MAIN BREAK WAS REPAIRED AT

Ex. 6 (Personal Privacy)

Employees on Job

C.F. - B.S.

4 HR

GRADED PATCH IN ROAD WITH ROCK
WHERE MAIN BREAK WAS REPAIRED AT

Ex. 6 (Personal Privacy) MILDRED

Vehicles or Equip. Used

11 - BACKHOLE - 14

Sewer Department

Address

CHECKED STATIONS - NEED TO PULL
& CLEAN PUMPS AT

Ex. 7f (Water Infra.)

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST

Ex. 7f (Water Infra.) LAKE PILL BOX

Employees on Job

K.M. - B.S.

4 HR

CYCLED BLOWERS AT OAKLAND

Ex. 7f (Water Infra.)

Vehicles or Equip. Used

14-15

Meter Readers

Employees on Job

F.P. - T.C.

FINISHED

14-T.C. - 15-F.P.

Areas - Read

STARTED

17-T.C. 18-F.P.

Vehicles Used

7-8

General Foreman

Frank J. Pace

Date 2-12-19

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK W.O.
REPAIRED BACK OVERHEAD DOOR IN SHOP

Jobs Completed

REPLACED SADDLE FOR **Ex. 6 (Personal Privacy)**
USED ONE 6" A.C. SADDLE, ONE 3/4" x 3/4" COPP.
ONE 3/4" x 3/4" COPP. FITTING, 4' OF 3/4" COPPER

Employees on Job

F, P. - B, S. - G, F. - T, C. - K, M.
6 HR 2 HR

TUBING, BACK FILLED DITCH WITH SPOIL &
ROAD WITH ONE LOAD CLEAN ROCK & 1/4
LOAD C-M-G ROCK - DUMPED THE REST AT
SHOP

Vehicles or Equip. Used

6-14 - BACKHOC

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

T, C. - K, M.
2 HR 6 HR

FINISHED (STILL HAVE SOME F.O.W.)
AREA 13 TO DIP OUT

Areas - Read

Vehicles Used

8

General Foreman

Frank J. Pace

Date 2-11-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O.

RR-READS FOR BILLING

Jobs Completed

LOCATES

Employees on Job

F.P. - B.S. - G.F.

GMR

Vehicles or Equip. Used

7-11-14

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST Ex. 7f (Water Infra.) ALL PILL BOX

CALVIN BLVD. PITTSBURGH

Ex. 7f (Water Infra.)

Job Completed

CYCLED BLOWERS AT OAKLAND

Ex. 7f (Water Infra.)

Employees on Job

K.M.

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

T.C. - F.P.
GMR

FINISHED

RADIO READS - F.P. 11 & 12 T.C.

Areas - Read

STARTED

13-T.C.

Vehicles Used

General Foreman

Frank J. Pace

Date 2-9-19

Daily Job Sheet

Sheet of

<u>Water Department</u>	
Comments	
Address	3MR CALL OUT - DOUBLE TIME
Jobs Completed	SHUT OFF METER AT BROKEN PIPES IN HOUSE
Employees on Job	K.M.
Vehicles or Equip. Used	11

Ex. 6 (Personal Privacy)

<u>Sewer Department</u>	
Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	
<u>Meter Readers</u>	
Employees on Job	
Areas - Read	
Vehicles Used	
General Foreman <u>Frank J. Pace</u>	

Date 9-8-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O.

LOCATES

RE-READS

Jobs Completed

Employees on Job

F.P. - B.S. - G.F. - K.M.
4 HR 6 HR 3 HR

Vehicles or Equip. Used

8-11-14

Sewer Department

Address

DUG UP LATERAL AT **Ex. 6 (Personal Privacy)** TO
RELIEVE BACKUP

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST **Ex. 7f (Water Infra.)** LAKE PILL BOX

Employees on Job

F.P. - B.S. - K.M.
2 HR 5 HR

Vehicles or Equip. Used

14-15 - BACKHOE

Meter Readers

Employees on Job

F.P.
2 HRFINISHED
RADIO READS

F.P.

Areas - Read

Vehicles Used

14

General Foreman

Frank J. Pace

Date 2-7-19

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

G.F.

Vehicles or Equip. Used

11

Sewer Department

Address

SAUTOFF 53RD, 51ST,
STATIONS DUE TO EXCESSIVE RAIN &
SURCHARGE AT 54TH ST.

Ex. 6 (Personal Privacy)

Job Completed

BRIDGE DALE PUMPING FULL PIPE, BUT
SYSTEM BACKED UP DUE TO EXCESSIVE
RAIN

Employees on Job

F.P. - B.S.
1 HR

Vehicles or Equip. Used

14

Meter Readers

Employees on Job

F.P. - B.S. - T.C. - K.M.
7 HR

FINISHED

4 + 5 EXCEPT FOR F.O.W. - F.P. - K.M.

8 & 7

EXCEPT F.O.W.

Areas - Read

STARTED
RADIO READS
F.P. - K.M.

Vehicles Used

8-14

General Foreman

Frank J. Rose

Date 2-6-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O.

Jobs Completed

PULLED NEW LINE UNDER ROAD & REBUILT
SERVICE AT **Ex. 6 (Personal Privacy)** 1520 ONE
3/4" X 3/4" COMP. FITTING, ONE METER COUPLING,

Employees on Job

F.P. - B.S. - G.F.

ONE METER SHUT OFF, ONE 3/4" FLAREX COMP,
ONE 12" X 30" P.V.C. METER BOX, 55' OF 3/4"
COPPER TUBING, INSTALLED R.R. METER

Vehicles or Equip. Used

11-14-BACKHOLE

BACKFILLED WITH SPOIL - NEED TO
REPAIR YARDSSewer Department

Address

DIPPED OUT CANS AT BELLEVUE,
BLUFF, OAKLAND

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST **Ex. 7f (Water Infra.)** ALL PILL BOX

Employees on Job

K.M.

CYCLED BLOWERS AT OAKLAND

Ex. 7f (Water Infra.)

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

T.C.

FINISHED

10

Areas - Read

STARTED

6

Vehicles Used

8

General Foreman

Frank J. Pace

Date 2-5-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O.

Jobs Completed

PULLED NEW P.V.C. LINE UNDER ROAD,
REBUILT SERVICE + INSTALLED R.R. METER
AT **Ex. 6 (Personal Privacy)** A HOKIA RD.

Employees on Job

G.F. - F.P. - B.S.

USED 45' OF 3/4" P.V.C. TUBING, ONE 18" X
3/4" METAL SET, ONE 18" X 30" P.V.C. METAL
BOX, RING + LID FROM SHOP - BACKFILLED

Vehicles or Equip. Used

11-14-BACKHOP

WITH SPOIL - FILLED HOLE IN ROAD
CAUSED BY CRACK WITH C-M-L ROCK
FROM SHOP - 44' MAIN TO METERSewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

T.C.

FINISHED
5

Areas - Read

STARTED
10

Vehicles Used

8

General Foreman

Frank J. Pace

Date 2-4-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address		SOME SERVICE TRUCK W/O.
Jobs Completed		REPAIRED 4" C.I. MAIN BREAK AT BLUE WATER - USED ONE 4" C.I. S.S. REPAIR CLAMP BACKFILLED WITH CLEAN ROCK & C-MG
Employees on Job F.P. - K.M. 5 HR		ROCK FROM SHOP, - STILL NEED TO HAUL OFF 2 OR 3 BUCKETS OF MUD & DRESS UP DRIVEWAY.
Vehicles or Equip. Used		
14 - BACKHOE		

Ex. 6 (Personal Privacy)

<u>Sewer Department</u>		
Address		BY-PASS PUMPED WITH 31 GAS PUMP AT 71ST LAKE AIL BOX
Job Completed		CYCLED BLOWERS AT OAKLAND
Employees on Job K.M. 3 HR		
Vehicles or Equip. Used		
15		

Ex. 7f (Water Infra.)

Ex. 7f (Water Infra.)

Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 2-2-19

Daily Job Sheet

Sheet ___ of ___

Water Department

Comments

Address

DOUBLETIME CALL OUTS

Jobs Completed

SHUT OFF METER AT
WATER WAS RUNNING OUT OF HOUSE
BROKEN PIPES IN HOUSE

Ex. 6 (Personal Privacy)

Employees on Job

F.P.

SHUT OFF METER AT
WATER WAS RUNNING OUT OF HOUSE
BROKEN PIPES

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

11

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank Pace

Date 2-1-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	OVERTIME	
Jobs Completed		
Employees on Job		
Vehicles or Equip. Used		
<u>Sewer Department</u>		
Address	JETTED LINE ON BATES TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy)	
Job Completed	JETTED LINE ON TOLLET FOR VILLAGE OF CAHOKIA- ONE MAN & UNIT #9	
Employees on Job	F.P. - T.C. 1 hr 2 hr	
Vehicles or Equip. Used	14-9	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 2-1-19

Daily Job Sheet

Sheet ____ of ____

Water Department

Comments

Address

SERVICE TRUCK W.O.

Jobs Completed

SHUT OFF SERVICE FOR
AT MAIN - NEED TO REBUILD SERVICE &
INSTALL 4" C.F. CLAMP WITH TAP TO

Ex. 6 (Personal Privacy)

Employees on Job

REPLACE CORP. STOP LEAKING AT MAIN

F.P. - K.M. - G.F.
4 HR

Vehicles or Equip. Used

11-14 - BACKHOE

Sewer Department

Address

CHECKED SOME STATIONS - BELLEVUE
PUMPING BUT WELL IS STILL UP.
BRIDGE DALE CYCLING ON NEW FLOAT BALL

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST LAKE PILL BOX

Ex. 7f (Water Infra.)

Employees on Job

CYCLED BLOWERS AT OAKLAND

K.M. - F.P.
4 HR 4 HR

Ex. 7f (Water Infra.)

Vehicles or Equip. Used

14-15

Meter Readers

Employees on Job

T.C.

FINISHED
4 3

Areas - Read

STARTED
4

Vehicles Used

8

General Foreman

Franky Pace

Date 3-29-19

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK W.O.
Jobs Completed	FILLED CHURCH ROAD ELEVATED TANK
Employees on Job G.F. - B.S. 5 HR	GRADED ROADS WHERE REPAIRS WERE MADE ON JEROME LN, MIDKID, CHURCH RD. MORNINGSTAR & MOUSETTE LN.
Vehicles or Equip. Used 11-14 - BACKHOLE	

Sewer Department

Address	CHECKED STATIONS - PERSHING & CLINTON OFF DUE TO DISCHARGE LINE AT CLINTON BACKING OUT OF LINE
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT TIST Ex. 7f (Water Infra.) LAKE PILL BOX, CALVIN
Employees on Job K.M. - B.S. 3 HR	CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.)
Vehicles or Equip. Used 14-15	

Meter Readers

Employees on Job F.P. - T.C.	FINISHED 9 - F.P. 4 - T.C.
Areas - Read	STARTED 5 - T.C.
Vehicles Used 7-8	

General Foreman Frank J. Pace

Date 3-28-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK W.O. LOCATES	
Jobs Completed	REMOVED LEAKING TEST STATION AT Ex. 6 (Personal Privacy) (TANK) - REMOVED COPPER* TEST STATION PAST CURB COCK SHUT OFF	
Employees on Job G.F. - F.P. - B.S. 4 MC	DRAINED TANK AT Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 11-14-BACKHOE		
Sewer Department		
Address	AT CLINTON Q. Ex. 7f (Water Infra.)	
Job Completed	PULLED PUMP & CLEANED RAGS OUT - RAISED PUMP 1'-2' & RE SET FLOAT BALLS NEED TO SET DISCHARGE LINE & VAC WELL OUT	
Employees on Job F.P. - B.S.	CHECKED STATIONS ON NORTH SIDE	
Vehicles or Equip. Used 14-BACKHOE		
Meter Readers		
Employees on Job T.C. & K.M.	FINISHED 3-T.C. 708-K.M.	
Areas - Read	STARTED 4-T.C.	
Vehicles Used 8-15		
General Foreman <u>Frank J. Price</u>		

Water Department		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		REBUILT SERVICE AT Ex. 6 (Personal Privacy) USED ONE 3/4" X 3/4" COMP, ONE METER SHUT OFF ONE METER COUPLING, ONE 3/4" I.P. X 3/4" COMP.
Employees on Job F.P. - G.F. - BS - T.C. - K.M. 4HR		ONE 18" X 30" P.V.C. METER TILE, 10' OF 3/4" COPPER TUBING BACKFILLED WITH SPOIL - HOUSE LINE IS IRON PIPE 3/4"
Vehicles or Equip. Used		REPAIRED MAIN BREAK AT Ex. 6 (Personal Privacy) SPRINGS ON WALNUT - 1 LOAD CLEAR ROCK USED ONE 2" C.I. S.S. REPAIR CLAMP - 1/2 LOAD C-MIG
8-11-14-15 - BACKHOE		

Sewer Department	
Address	
Job Completed	
BY-PASS PUMPED WITH 3" GAS PUMP AT Ex. 7f (Water Infra.) TIST LAISE PILE BOX	
Employees on Job K.M. 4HR	
CYCLAD BLOWERS AT OAKLAND Ex. 7f (Water Infra.)	
Vehicles or Equip. Used 15	

Meter Readers
Employees on Job
Areas - Read
Vehicles Used

General Foreman Frank J. Pace

Date 3-26-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

SERVICE TRUCK W.O.

LOCATED

Jobs CompletedHOOKED UP NEW LINE AT
UPPER CAHOKIA - USED ONE METER COUPLING
ONE 3/4" X 3/4" COMP. FITTING, BACKFILLED WITH SPOIL
USED 20' OF 3/4" COPPER TUBING & INSTALLED

Ex. 6 (Personal Privacy)

Employees on JobG.F. - T.C. - F.P. - B.S. - K.M.
6 HR.

RADIO READ METER

Vehicles or Equip. Used

11-14-15 - BACKHOE - 8

SHUT OFF SERVICE TO

Ex. 6 (Personal Privacy)

AT MAIN

Sewer Department**Address**INSTALLED BELTS ON PUMP/MOTOR #1
AT SUPERIOR**Job Completed**INSTALLED TARPS ON BLOWER CANS AT
63RD

Ex. 6 (Personal Privacy)

Employees on JobB.S. - K.M.
2 HR**Vehicles or Equip. Used**

15

Meter Readers**Employees on Job****Areas - Read****Vehicles Used****General Foreman**

Franky. Pace

Date 3-25-19

Daily Job Sheet

Sheet of **Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

G.F.

Vehicles or Equip. Used

11

Sewer Department

Address

DRIED OUT ELECTRIC JUNCTION BOX AT
Ex. 7f (Water Infra.) REAR

Completed

TIGHTENED BELTS ON MOTORS AT
SUPERIOR 75TH Ex. 7f (Water Infra.) PUMPING 1/2 PIPE
NARD TO PULL VACUUM W/LL

Employees on Job

K.M. B.S. - T.C.
2 HRBY-PASS PUMPED WITH 3" GAS PUMP AT
71ST Ex. 7f (Water Infra.) LAKE PUL BOX,
63RD CALVIN BLVD.

Vehicles or Equip. Used

15 - 14

CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.)

Meter Readers

Employees on Job

F.P. - B.S. - T.C.
6 HR

FINISHED

CYCLE 2 RADIOS

29 - F.P. - B.S. - T.C. / 1 x 2 - T.C. / F.P.

Areas - Read

Vehicles Used

8-14-7

General Foreman

Frank J. Pace

Date 3-22-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**SERVICE TRUCK W.O.
LOCATES**Jobs Completed**REBUILT SERVICE & RAN NEW COPPER
LINE TO MAIN - USED 15' OF 3/4" COPPER
TUBING, ONE, 3/4" X 5/8" METER SET, ONE**Employees on Job**

F.P. - B.S. - T.C.

18" X 30" P.V.C. METER BOX, BACKFILLED
WITH SPOIL AT **Ex. 6 (Personal Privacy)****Vehicles or Equip. Used**

14-11 - BACKHOE

Sewer Department**Address**BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST **Ex. 7f (Water Infra.)** LAKE PILL BOX**Job Completed**CYCLED BLOWERS AT OAKLAND
TURNED ON PERSHING STATION **Ex. 7f (Water Infra.)****Employees on Job**K.M.
4 APR**Vehicles or Equip. Used**

15

Meter Readers**Employees on Job****Areas - Read****Vehicles Used****General Foreman**Frank J. Pace

Date 3-21-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK W.O. LOCATES	
Jobs Completed	CLEANED SHOP LOCATED VALVE AT	
Employees on Job	GRADED ROAD WITH ROCK AT	
F.P. - B.S. T.C.K.M. 4 HR 6 HR 8 HR		
Vehicles or Equip. Used		
11-14-8-BACKHOE		

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Sewer Department	
Address	PULLED BOTH PUMPS AT
Job Completed	PULLED PUMP AT 75TH
Employees on Job	CYCLED BLOWERS AT OAKLAND
F.P. - B.S. - K.M. 4 HR	
Vehicles or Equip. Used	
14-15-BACKHOE	

Ex. 7f (Water Infra.)

Ex. 7f (Water Infra.)

Ex. 7f (Water Infra.)

Ex. 7f (Water Infra.)

Meter Readers	
Employees on Job	FINISHED
T.C. 2 HR	
Areas - Read	
Vehicles Used	8
General Foreman	Frank J. Rose

Sheet ____ of ____

Water Department		Comments	
Address	W.O -		
Jobs Completed			
Employees on Job			
Vehicles or Equip. Used			
Sewer Department			
Address			
Job Completed			
Employees on Job			
Vehicles or Equip. Used			
Meter Readers			
Employees on Job	Finished	Finished	Finished
B.S., T.C, K.M	19-B.S, K.M	22-K.M	23, 24
Areas - Read	Started		
19, 22, 23, 24, 26	26		
Vehicles Used			
14, 8, 15			
General Foreman	K. McCall		

Date 3-19-19

Daily Job Sheet

Sheet of **Water Department****Comments**

Address

~~10.0~~ Work orders

Jobs Completed

Employees on Job

BS, KM, T.C.

Vehicles or Equip. Used

8, 15, 11

Sewer Department

Address

P.I. box on 71st cameroid,
73rd stations cycled.

Job Completed

Employees on Job

KM, BS

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

B.S., T.C.

Finished

20, 21 - T.C.

Finished

Radio Readings - B.S.


Areas - Read

20, 21, Radio Readings

Vehicles Used

14, 8

General Foreman



Date 3-18-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address		SERVICE TRUCK W.O.
		LOCATES
Jobs Completed		MISC. TRUCK 14 W.O.
		DATALOGGED & R.F. TESTED METER AT
Employees on Job		Ex. 6 (Personal Privacy)
F.P. - B.S. - T.C.		
Vehicles or Equip. Used		
8-11-14		

Sewer Department		
Address		BY-PASS PUMPER WITH 3" GAS PUMP AT
		7151 Ex. 7f (Water Infra.) LAKE ALC BOX,
		CALVIN BLVD.
Job Completed		CYCLED BLOWERS AT OAKLAND
		Ex. 7f (Water Infra.)
Employees on Job		25TH Ex. 7f (Water Infra.) ST. PUMPING - NEED TO
K.M.		PULL PUMP - TURNED OFF & PERSHING
		IS OFF TOO
Vehicles or Equip. Used		
15		

Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Franky & Pice</u>		

Date 3-15-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

SERVICE TRUCK W.O.

LOCATES

Jobs Completed

PULSE, TRUCK 14 W.O.

Employees on Job

F.P.-B.S.-T.C.

GER

Vehicles or Equip. Used

11-14

Sewer Department**Address**BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST Ex. 7f (Water Infra.) LAKE PILL BOX,

63RD

Ex. 7f (Water Infra.)

Job CompletedINSTALLED BRACKET ON PUMP #1 RAIL
SYSTEM AT Ex. 7f (Water Infra.)**Employees on Job**

F.P.-B.S.-K.M.

2 HR

CHECKED FOR BACKUP AT
COST. PROBLEM

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

7

CHECKED STATIONS ON SOUTH END

Meter Readers**Employees on Job****Areas - Read****Vehicles Used****General Foreman**

Date 3-14-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address		SERVICE TRUCK W.O. LOCATES
Jobs Completed		REMOVED LEAKING SADDLE/SERVICE LINE & INSTALLED 8" A.C. S.S. REPAIR CLAMP, BACKFILLED WITH CLEAN ROCK & C-M-G ROCK.
Employees on Job F.P. - B.S. - G.F. - T.C. - K.M. 6 HR		INSTALLED METER AT USED ONE 2" TO 1" REDUCER, 2" X 1" BUSHING & A 1" RADIO READ METER
Vehicles or Equip. Used		DISCONNECTED BIG DOORS AT SHOP TO CLOSE DUE TO ELECTRIC OUTAGE

Ex. 6 (Personal Privacy)

Sewer Department	
Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	
Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	
General Foreman <u>Franky Pace</u>	

Date 3-13-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O.

Jobs Completed

RAN NEW LINE UNDER ROAD AT
ALCOA - USED ONE $\frac{3}{4}$ " X $\frac{3}{4}$ " COMP. FITTING, ONE
 $\frac{3}{4}$ " COMP. NUT, 43' OF $\frac{3}{4}$ " P.I.C. TUBING

Employees on Job

(F.P. - B.S. - T.C.) - G.F.
6 HRBACKFILLED WITH LOAD CLEAN ROCK & TOPPED
OFF WITH C-M-G ROCK ON MAINSIDE &
BACKFILLED SPOIL ON HOUSE SIDE

Vehicles or Equip. Used

6-8-14-11 - BACKHOL

EXERCISED VALVE AT
NERO RISER FOR VALVE BOXSewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
TIST Ex. 7f (Water Infra.) LAKE PILL BOX,
CALVIN BLVD,

Job Completed

INSTALLED ANCHORS ON EI PUMP BRACKET
AT Ex. 7f (Water Infra.) LLED $\frac{3}{16}$ DRILL BIT TO
COMPLETE JOB

Employees on Job

K.M. - (F.P. - B.S. - T.C.)
2 HR

INSTALLED PULLEY AT BRIDGDALE

Vehicles or Equip. Used

14-15

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Franky Pace

Date 3-12-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job C.F. - T.C. 5 HR		
Vehicles or Equip. Used		
8-11		
Sewer Department		
Address		REMOVED OLD PUMP ASSEMBLY & INSTALLED NEW PUMP ASSEMBLY AT BRIDGE DALE
Job Completed		PULLED PUMP #2 & CLEANED OUT RAGS, TRIED TO INSTALL ANCHOR BOLTS FOR RAILS ON PUMP #1 BUT DRILL BIT WAS TOO SMALL FOR ANCHORS - AT
Employees on Job F.P. - B.S. - K.M. 4 HR		SAW CUT ROAD AT JEROME & AT
Vehicles or Equip. Used		
14-7- BACKHOE		
Meter Readers		
Employees on Job T.C. 3 HR		FINISHED 18
Areas - Read		
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		

Date 3-11-19

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

G.F.

Vehicles or Equip. Used

11

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST **Ex. 7f (Water Infra.)** LAKE PILL BOX

Job Completed

CYCLED BLOWERS AT OAKLAND

Ex. 7f (Water Infra.)

Employees on Job

B.S.
GAR

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

F.P.-T.C. B.S.
GAR

FINISHED
13 & 14 - F.P.

CYCLE 3 RADIOS
F.P.

Areas - Read

STARTED
18-T.C.

Vehicles Used

7-8

DIPPED OUT F.O.W. & READ METERS
B.S.

General Foreman

Frank J. Pace

Date 3-8-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O.

LOCATES

Jobs Completed

Employees on Job

C.F. - B.S.
G.H.R.

Vehicles or Equip. Used

11-14

Sewer Department

Address

PULLED PUMP & CLEANED OUT RAGS AT
75TH **Ex. 7f (Water Infra.)**

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST **Ex. 7f (Water Infra.)** LARK PILL BOX
CALVIN BLVD.

Employees on Job

K.M. - C.F. - B.S.
2 H.R.

CYCLED BLOWERS AT OAKLAND

Ex. 7f (Water Infra.)

Vehicles or Equip. Used

14-15- BACKHOF

Meter Readers

Employees on Job

C.F. F.P. T.C.
2 H.R. G.H.R.

FINISHED

15-T.C.

11 C.F. & F.P. 12 F.P.

Areas - Read

STARTED

17-T.C.

13-F.P.

Vehicles Used

7-8-11

General Foreman

Frantz Pace

Date 3-7-19

Daily Job Sheet

Sheet of **Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

REBUILT SERVICE + USED ONE METER SHUT OFF, METER COUPLING, TWO 3/4" COMP. FITTINGS ONE 18" X 30" P.V.C. METER BOX + INSTALLED RADIO READ METER -

Ex. 6 (Personal Privacy)

Employees on Job

C.F. - F.P. - B.S. - T.C.

INSTALLED ONE 4" C.I. S.S. REPAIR CLAMP WITH 3/4" TAP, ONE 3/4" CORP. STOP, ONE 3/4" COMP. FITTING, 12' OF 3/4" COPPER TUBING BACKFILLED WITH SPIC AT

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

8-11-14 BACKHOLE

RAISED BOX WITH 4" CLAY RISER CUT AT SHOP AT

Ex. 6 (Personal Privacy)

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT 63RD CLINTON - PUMP AT CLINTON COUGHT RAGS NEED TO PULL

Ex. 7f (Water Infra.)

Job Completed

CYCLED BLOWERS AT OAKLAND

Ex. 7f (Water Infra.)

Employees on Job

K.M.

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 3-6-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O.

OPENED & CLOSED VALVES AT CHURCH RD.
TANK

Jobs Completed

Employees on Job

F.P.-B.S.-T.C. G.F.
3 HR

Vehicles or Equip. Used

7-11-8-14

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST Ex. 7f (Water Infra.) LAKE PILE BOX
CLINTON

Job Completed

INSTALLED HOSE ON BLOWER AT OAKLAND
B.S. & K.M.
1 HR

Employees on Job

K.M.

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

F.P.-T.C.-B.S.
5 HR

FINISHED

5-F.P.-6-T.C.-9-B.S.

Areas - Read

Vehicles Used

7-8-14

General Foreman

Franky. Pice

Date 3-5-19

Daily Job Sheet

Sheet of

Water Department **Comments**


Address	<i>Work Orders</i>
Jobs Completed	
Employees on Job <i>G.F, T.C, BS</i>	
Vehicles or Equip. Used <i>14, 11</i>	

Sewer Department

Address	<i>Check stations, Cycled & Pumped Calvin Blvd.</i>
Job Completed	
Employees on Job <i>B.S, T.C, KM</i>	
Vehicles or Equip. Used <i>15, 14</i>	

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	


General Foreman *[Signature]*

Water Department		Comments
Address	W.O.	
Jobs Completed		
Employees on Job	B.S	
Vehicles or Equip. Used	11	
Sewer Department		
Address	Pumped & cycled 71 st & 73 rd , crocketts Ex. 7f (Water Infra.)	
Job Completed		
Employees on Job	L.M	
Vehicles or Equip. Used	15	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman 		

Date 3-2-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	located line at Ex. 6 (Personal Privacy)	
Jobs Completed		
Employees on Job	FP	
Vehicles or Equip. Used	14	
Sewer Department		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman		

Date 3-1-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job F.P. K.M.		
Vehicles or Equip. Used		
11		
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job F.P. / K.M. 7-5		FINISHED 4-F.P. 8-K.M.
Areas - Read		STARTED 5-F.P. - 9-K.M.
Vehicles Used 8-14		
General Foreman <u>Frank J. Pace</u>		

Date 4-30-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	POT HOLE & LOCATED MAIN FOR AT&T AT Ex. 6 (Personal Privacy) CHURCH RD.	
Employees on Job G.F. - F.P. - B.S. 4 HR	OPENED VALVE FOR CHURCH RD. TANK OPENED VALVES & FLUSHED TRANSMISSION LINE THROUGH Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 14-11 - BACKHOLE		
<u>Sewer Department</u>		
Address		
Job Completed	TRIED TO INSTALL PUMP AT M.H. IN FIELD Ex. 6 (Personal Privacy) P DID NOT RUN WHEN WE CHECKED IT IN FIELD OR IN SHOP. TOOK TO 12:00	
Employees on Job F.P. - B.S. 2 HR		
Vehicles or Equip. Used 14 - BACKHOLE		
<u>Meter Readers</u>		
Employees on Job K.M. - T.C. - F.P. 2 HR	FINISHED 4 - T.C. - 9 - K.M.	
Areas - Read	STARTED 5 - T.C. CYCLE 3 RADIO READS - F.P.	
Vehicles Used 8-14-15		
General Foreman <u>Frank J. Price</u>		

Date 4-29-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F. -	
Vehicles or Equip. Used 11	

Sewer Department

Address	CHECKED STATIONS - LAURA BREAKER WAS KICKED OUT - RESET BREAKER PUMPING NOW. Ex. 7f (Water Infra.)
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 715. Ex. 7f (Water Infra.) AKE PILL BOX, CALVIN, PITTSBURG Ex. 7f (Water Infra.) FROM RENOIS
Employees on Job K.M. - B.S.	LOCATES
Vehicles or Equip. Used 14-15 - BACKHOLE	CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.)

Meter Readers

Employees on Job F.P. - T.C.	FINISHED 748 - F.P. 3 - T.C.
Areas - Read	STARTED 4 - T.C.
Vehicles Used 7-8	

General Foreman Frank J. Pace

Date 4-26-19

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK W.O.

LOCATLS

Jobs Completed

METER SHOP WORK

Employees on Job

T.C. B.S.
6 HRS 4 HRS

Vehicles or Equip. Used

11 & 8

Sewer Department

Address

JACKETED LINE TO RELIEVE BACKUP AT
Ex. 6 (Personal Privacy) - CHECKED FOR BACKUP AT
- COST PROBLEM

Job Completed

PULLED PUMP IN FIELD Ex. 6 (Personal Privacy)
BROUGHT TO SHOP - BY-PASSED WITH 3" PUMP
JACKETED LINE AT CONVERSE Ex. 6 (Personal Privacy)

Employees on Job

F.P. - T.C. - B.S. - K.M.
2 HRS 4 HRSBY-PASS PUMPED WITH 3" GAS PUMP AT
715 Ex. 7f (Water Infra.) AKE PILL BOX

Vehicles or Equip. Used

CYCLED BLOWERS AT OAKLAND

Ex. 7f (Water Infra.)

9-14-15

Meter Readers

Employees on Job

F.P.
6 HRS

FINISHED CYCLE 2 RADIO READS

Areas - Read

Vehicles Used

14

General Foreman

Frank J. Pace

Date 4-25-19

Daily Job Sheet

Sheet of

<u>Water Department</u>	<u>Comments</u>
Address	SERVICE TRUCK W.O.
Jobs Completed	REPAIRED 2" SERVICE LINE LEAK AT Ex. 6 (Personal Privacy) USED 6' OF 2" P.V.C. TUBING, ONE 2" X 2" COMP. FITTING, ONE 2"
Employees on Job G.F. - <u>F.P. - B.S. - K.M.</u> 4 HR	CORPORATION NUT & WASHER GASKET, LINE IS 2" COPPER FROM SPLICED P.V.C. TO BOX.
Vehicles or Equip. Used 11-14-8	CHECKED STATIONS ON SIGNAL HILL

<u>Sewer Department</u>	
Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

<u>Meter Readers</u>	
Employees on Job <u>F.P. - B.S. - K.M.</u> 4 HR	FINISHED 1 & 2 - K.M. 29 - B.S. & F.P.
Areas - Read	
Vehicles Used 14-8	

General Foreman Frank J. Pace

Date 4-24-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job C.G.F.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address		BY-PASS PUMPED WITH 3" GAS PUMP AT 7151 Ex. 7f (Water Infra.) AKE PILL BOX, 63RD Ex. 7f (Water Infra.) ALVIN BLVD.
Job Completed		CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.)
Employees on Job K.M. - F.P. - B.S. 4 HR		CHECKED STATIONS ON SOUTH END - ALL GOOD - HAIR BUILD UP ON WIRES AT I.C. TRACKS IS GETTING BAD. & RENOIS OUT
Vehicles or Equip. Used 14-15		INSTALLED A 4'X4'X3/4" PIECE OF PLYWOOD ON WET WALL AT LAURALAA STATION
<u>Meter Readers</u>		
Employees on Job F.P. - B.S. 4 HR		STARTED 29
Areas - Read		
Vehicles Used 14		
General Foreman <u>Frank J. Price</u>		

Date 4-23-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

G.F. - B.S.
4 HR

Vehicles or Equip. Used

11-7

Sewer Department

Address

TURNED SEWER STATIONS BACK ON
AFTER HANKS MADE SEWER REPAIRS

Job Completed

Employees on Job

F.P.
2 HR

Vehicles or Equip. Used

14

Meter Readers

Employees on Job

K.M. - F.P. - B.S.
6 HR 4 HRFINISHED (F.O.W.)
22-K.M. (23-K.M.) 24-F.P. & B.S. - 26-F.P.

Areas - Read

CYCLE 5 RADIO READS B.S. & F.P.
START FINISH

Vehicles Used

General Foreman

Franky Rose

Date 4-23-19

Daily Job Sheet

Sheet ___ of ___

Water DepartmentComments

Address	CALL OUT - EARLY START 1 HR OVERTIME
Jobs Completed	SHUT OFF SEWER STATIONS FOR HANKS SEWER REPAIR JOB
Employees on Job F.P.	
Vehicles or Equip. Used 14	

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Franky. Pace

Date 4-22-19

Daily Job Sheet

Sheet of **Water Department****Comments**

Address

CALL OUT
2½ HR O.T.

Jobs Completed

LOCATED VALVES & SHUT THEM DOWN
REPLACED CAP ON HYDRANT AT OLD MO.
Ex. 6 (Personal Privacy) OPENED VALVES

Employees on Job

F.P. - Giff

Vehicles or Equip. Used

14

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 4-22-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W/O.
LOCATES

Jobs Completed

REPAIRED 6" C.I. MAIN BREAK AT
CAMP JACKSON - USED ONE 6" C.I. S.S.
REPAIR CLAMP - LEFT MAIN EXPOSED FOR HANKS

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - K.M. - G.F.
4HR 4HR

Vehicles or Equip. Used

14-15-11 - BACKHOE

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
7157 Ex. 7f (Water Infra.) AKE PILL BOX

Job Completed

CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.)
TURNED STATIONS OFF & ON FOR HANKS

Employees on Job

F.P. - K.M.
4HRFOUND LAMPHOLE & MANHOLES BEHIND 1, 5.F
Ex. 6 (Personal Privacy) NEEDED TO SET LINE TO
RELIEVE BACKUP. LAMPHOLE IS HOLDING.

Vehicles or Equip. Used

14-15

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Franky-Pace

Date 4-19-19

Daily Job Sheet

Sheet ____ of ____

<u>Water Department</u>		Comments
Address		
Jobs Completed		
Employees on Job		
Vehicles or Equip. Used		
<u>Sewer Department</u>		
Address		TWO SEPERATE CALL OUTS - ONE IN A.M. TO TURN OFF PUMP (K.M.) STATIONS FOR VILLAGE OF CAHOKIA
Job Completed		ONE IN P.M. TO TURN ON PUMP STATIONS FOR VILLAGE SEWER REPAIR (F.P.)
Employees on Job F.P. - K.M.		
Vehicles or Equip. Used 14		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 4-19-19

Daily Job Sheet

Sheet ___ of ___

Water DepartmentComments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Bell

Date 4-18-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	HOOKED UP BACKSIDE AT Ex. 6 (Personal Privacy) USED ONE $\frac{3}{4}$ " X $\frac{3}{4}$ " COMP. FITTING - HOUSE LINE IS $\frac{3}{4}$ " P.V.C. TUBING.	
Employees on Job G.F. <u>F.P. - B.S.</u> 4 HR		
Vehicles or Equip. Used 11 - 14 - BACKHOLE		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 7157 Ex. 7f (Water Infra.) LAKE PILL BOX	
Job Completed	CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.)	
Employees on Job K.M. 4 HR		
Vehicles or Equip. Used 15		
<u>Meter Readers</u>		
Employees on Job K.M. F.P. - B.S. 4 HR 4 HR 3 HR	FINISHED 19 - F.P. & B.S. 23 - K.M.	
Areas - Read		
Vehicles Used 8 - 14		
General Foreman <u>Frank J. Pace</u>		

Date 4-17-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O.

LOCATES

MOVED SAND IN BACK OF SHOP

Jobs Completed

GRADED DIRT, RAKED & SEADED YARD IN FRONT
OF **Ex. 6 (Personal Privacy)**

Employees on Job

F.P. - B.S. - G.F. - T.C.
6 HR 2 HRWENT TO REPLACE REGISTER AT ST. PAUL DR.
BUT WHEN I MOVED REGISTER IT STARTED TO
REGISTER - IT READ 17407 AT 12:45 P.M. & IT
READ 17421 AT 3:00 P.M. LEFT REGISTER ON

Vehicles or Equip. Used

11-8-14-BACKHOLE

Sewer Department

Address

INSTALLED PUMP IN FIELD
PUMPED DOWN WELL WITH 3" GAS PUMP FIRST**Ex. 6 (Personal Privacy)**

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST **Ex. 7f (Water Infra.)** AKE PILL BOX,
63RD **Ex. 7f (Water Infra.)** CALVIN BEVD.

Employees on Job

K.M. - F.P. - B.S.
2 HR

CYCLED BLOWERS AT OAKLAND

Ex. 7f (Water Infra.)

Vehicles or Equip. Used

14-15

CHECKED **Ex. 7f (Water Infra.)** BRIDGEBACK -
ALL GOOD

Meter Readers

Employees on Job

T.C.
6 HRFINISHED
20421

Areas - Read

Vehicles Used

8

General Foreman

Frank J. Pace

Date 4-16-18

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O.

LOCATES

Jobs Completed

Employees on Job

C.F. - F.P.
2MR

Vehicles or Equip. Used

~~14-15-9~~ 7-14Sewer Department

Address

PULLED PUMPS & CLEANED OUT RAGS AT

Ex. 7f (Water Infra.)

Job Completed

DUG TOP OFF WET WELL, PULLED & CLEANED
PUMPS, VACUMED OUT WET WELL, RE-SET
PUMP & FLOATBALLS AT 75TH

Ex. 7f (Water Infra.)

Employees on Job

F.P. - B.S. - T.C. - K.M.
GMRVACUMED OFF SOLIDS & REMOVED A PIECE
OF PLYWOOD FROM WET WELL AT

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

14-15-9 - BACKHOE

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Price

Date 4-15-19

Daily Job Sheet

Sheet _____ of _____

Water Department		Comments
Address	Repaired main break Ex. 6 (Personal Privacy) sed 4" ac clamp. W.O.	
Jobs Completed		
Employees on Job		
Vehicles or Equip. Used	KM, TC, BS, GF 15, 11, 14, Backhoe	
Sewer Department		
Address	Pulled rags out of bridgedale station. Pumped 71st & pillbox; also oakland Ex. 7f (Water Infra.)	
Job Completed		
Employees on Job	15, 14	
Vehicles or Equip. Used		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman _____		

Date 4-12-19

Daily Job Sheet

Sheet ___ of ___

Water DepartmentComments

Address

W.O.
Spliced 8" piece of copper on back side
3/4" copper-copper 3/4" backside; reconnect

Ex. 6 (Personal Privacy)

Jobs Completed

Employees on Job

B.S., T.C., G.F.

Vehicles or Equip. Used

11, 14, Backhoe

Sewer Department

Address

Cycled oakland Ex. 7f (Water Infra.) stations
Bypass pumped 71st & pillbox

Job Completed

Employees on Job

K.M.

Vehicles or Equip. Used

15


Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman



Date 4-11-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O.
LOCATES

Jobs Completed

Employees on Job

G.F. - F.P.
JUNE

Vehicles or Equip. Used

Sewer Department

Address

JETTED & CLEANED LINE ON 71ST ST.
GOT 80' FROM M.H. AS FAR AS
PILL BOX WET WELL
Ex. 6 (Personal Privacy)

Job Completed

PUMPED DOWN 75TH WET WELL &
CLEANED DISCHARGE LINE OUT TO M.H. BY
FENCE LINE
Ex. 7f (Water Infra.)

Employees on Job

B.S. - T.C. - K.M.

CYCLED BLOWERS AT OAKLAND
PERSHING
Ex. 7f (Water Infra.)

Vehicles or Equip. Used

9-8-15

Meter Readers

Employees on Job

F.P.

FINISHED
18CYCLE #
RADIO READS

Areas - Read

Vehicles Used

14

General Foreman

Frank J. Rice

Date 4-10-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. STARTED TO INSTALL TESTING STATION AT TANK ON CHURCH	
Jobs Completed	TESTED METERS IN SHOP FOR WARRANTY WITH Ex. 6 (Personal Privacy)	
Employees on Job F.P. - B.S. - C.R.F. G.H.R.	DATA LOGGED & R.F. TESTED METERS IN FIELD	
Vehicles or Equip. Used 11-7-14 - BACKHOLE		
Sewer Department		
Address	BY-PASS PUMPS WITH 3" GAS PUMPS AT 71ST Ex. 7f (Water Infra.) LAKE PILL BOX, CLINTON Ex. 6 (Personal Privacy)	
Job Completed	CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.) PERSHING	
Employees on Job K.M. - B.S. D.H.R.	PULLED PUMP IN FIELD Ex. 6 (Personal Privacy) TOOK TO SHOP	
Vehicles or Equip. Used 15 - BACKHOLE		
Meter Readers		
Employees on Job T.C.	FINISHED 14 & 17 & F.O.W.S	
Areas - Read	STARTED 18	
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		

Date 4-9-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	MOVED SERVICE FOR Ex. 6 (Personal Privacy) T - USED TWO 3/4" X 3/4" COMP. FITTINGS, ONE 12" X 30" P.V.C. METER BOX, 18' OF 3/4" COPPER TUBING - REUSED METER SHUT OFF & METER COUPLING BACKFILLED SOIL
Employees on Job F.P. - B.S. - G.P.	CHECKED HYDRANT THAT WAS HIT & KNOCKED OFF AT Ex. 6 (Personal Privacy) HYDRANT IS MISSING & BRANCH VALVE IS IN SWAMPY AREA NOW. HYDRANT IS NOT LEAKING
Vehicles or Equip. Used 14-11-BACKHOLE	

Sewer Department

Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers

Employees on Job K.M.	FINISHED 13
Areas - Read	STARTED 14
Vehicles Used 8	
General Foreman <u>Frank J. Pace</u>	

Date 4-8-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

C.F.

Vehicles or Equip. Used

11

Sewer Department

Address

LOCATES

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT
715. Ex. 7f (Water Infra.) LAKE, 75TH

Employees on Job

K.M. - B.S.

CHECKED STATIONS - RENOIS NEEDS PIPES
VIOLET WAS OUT - PUMPING NOW - WELL DOWN

Vehicles or Equip. Used

15 - 14

CYCLED BLOWERS AT OAKLAND
PERSHING

Meter Readers

Employees on Job

T.C. - F.P.

FINISHED
11-12-T.C. - 15-F.P.

Areas - Read

STARTED
13-T.C. 17-F.P.

Vehicles Used

8-7

General Foreman

Date 4-5-19

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK W.O.
Jobs Completed	REPLACED METER BOX, INSTALLED RADIO READ METER & GRADED DIRT AROUND BOX AT Ex. 6 (Personal Privacy) USED ONE 18" X 30" P.V.C. METER BOX, ONE 12" RESILIENT. NEED TO GO BACK & FINAL GRADE DIRT & SEED - TOO WET NOW.
Employees on Job F.P. - B.S. - T.C. - G.F. - GHR	REMOVED METER, SHUT OFF 2" SERVICE AT MAIN & INSTALLED USED METER BOX FROM SHOP TO LOCATE SERVICE IN FUTURE AT Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 8-11-14-BACKHOLE	

Sewer Department

Address	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT Ex. 7f (Water Infra.) 715 AKK PILL BOX
Employees on Job K.M.	CYCLAD BLOWERS AT OAKLAND Ex. 7f (Water Infra.)
Vehicles or Equip. Used 15	

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman



Date 4-4-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. LOCATES RE-READS + CHECK DEAD METERS	
Jobs Completed	MISC. WORK ORDERS FOR TRUCK 14- REPLACED SHUT OFF AT Ex. 6 (Personal Privacy) REMOVED JUMPER AND REMOVED BACKSIDE AT Ex. 6 (Personal Privacy)	
Employees on Job	F.P. - B.S. - G.F. - T.C. 4 HRC 4 HRC	
Vehicles or Equip. Used	7-11-14	
Sewer Department		
Address	PUMPED OUT CAN AT 82ND Ex. 7f (Water Infra.) CHECKED STATIONS	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 63RD Ex. 7f (Water Infra.) CLINTON, CALVIN BLVD.	
Employees on Job	CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.) DIPPED OUT BOX AT OAKLAND	
Vehicles or Equip. Used	14-15	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	<u>Frank J. Pace</u>	

Date 4-3-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W/O. LOCATES	
Jobs Completed	REMOVED 2" METER FROM Ex. 6 (Personal Privacy)	Ex. 6 (Personal Privacy)
Employees on Job G.F. - F.P. - T.C. - B.S. 4HR 2HR		
Vehicles or Equip. Used 11-14-8		
<u>Sewer Department</u>		
Address	HOOKED UP SEWER LATERAL AT CHURCH RD. - USED 10' OF 6" SCH. 35 P.V.C. PIPE, ONE SCH. 35 45° COUPLING, TWO 6" CONCRETE 6" P.V.C. FERNCO FITTINGS HAULED THREE Ex. 6 (Personal Privacy)	
Job Completed	BUCKETS OF C-M-6 ROCK TO GRADE ROAD	
Employees on Job K.M. - F.P. - B.S. - T.C. 4HR 6HR	BY-PASS PUMPED WITH 3" GAS PUMP AT 21ST Ex. 7f (Water Infra.) LAKE PILL BOX	
Vehicles or Equip. Used 6-14-15-BACKHOC	CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.)	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	Frank J. Lacey	

Date 4-2-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O.

LOCATES

DATA LOGGED & R.F. TESTED METERS

Jobs Completed

REPAIRED YARDS WHERE WORK WAS
COMPLETED AT

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy) - FALLING SPRINGS

Employees on Job

F.P. - G.F. - B.S. - T.C.

Vehicles or Equip. Used

6-7-11-14-BACKHOLE

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 4-1-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK W.O. DUG OUT BOXES TO REMOVE METERS AT Ex. 6 (Personal Privacy) UPPER CAHOKIA	
Jobs Completed	REBUILT BACKSIDE OF SERVICE AT ANDREWS - USED ONE 3/4" X 3/4" COMP. FITTING, ONE METER COUPLING, ONE 18" X 30" P.V.C. METER BOX & 3' OF 3/4" COPPER TUBING - BACKFILLER SPOIL Ex. 6 (Personal Privacy)	
Employees on Job	F.P. - G.F. - B.S. G.H.R. G.H.R.	
Vehicles or Equip. Used	11-14-BACKHOE	
<u>Sewer Department</u>		
Address	BY-PASS DUMPED WITH 3" GAS PUMP AT 71ST Ex. 6 (Personal Privacy) LAKE FILL BOX, 75TH Ex. 7f (Water Infra.)	
Job Completed	CYCLED BLOWERS AT OAKLAND, Ex. 7f (Water Infra.)	
Employees on Job	K.M.	
Vehicles or Equip. Used	15	
Meter Readers		
Employees on Job	FINISHED F.P.-G.F. T.C. 546-T.C. 10-G.F. RADIO READS-F.P. J.H.R.	
Areas - Read		
Vehicles Used	7-8-11	
General Foreman	Frank J. Pace	

Date 5-31-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

SERVICE TRUCK WORK ORDERS

Jobs CompletedPULLED NEW LINE UNDER ROAD AT
USED 35' OF 3/4" COPPER TUBING, ONE 1/4"
FLAREX COMP FITTING, ONE 3/4" X 3/4" COMP. FITTING,

Ex. 8 (Personal Privacy)

Employees on JobF.P. - B.S. - C.P.
5 HRBACK FILLED WITH SPOIL, COPPER FROM
MAIN TO METER - DON'T KNOW WHAT HOUSE LINE
IS.**Vehicles or Equip. Used**

11-14 - BACKHOLE

Sewer Department**Address**BY-PASS PUMPED WITH BOTH 3" GAS PUMPS AT
715' LAKE PILL BOX, CHURCH
RD. STATION.**Job Completed**CYCLED BLOWERS AT OAKLAND
CLEANED TRANSDUCER AT 530'
STATION IS TAKING IN A LOT OF STORM WATER

Ex. 7f (Water Infra.)

Ex. 7f (Water Infra.)

Employees on JobK.M. - F.P. - B.S.
4 HR 3 HRFROM FIELD BEHIND WELSON
CHURCH RD STATION DOWN ABOUT 10' FROM
HEADERS - THIS STATION IS TAKING IN A LOT
OF WATER FROM SOMEWHERE TOO

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

14-15 - BACKHOLE

ALL STATIONS ON AUTO EXCEPT CHURCH RD.

Meter Readers**Employees on Job**T.C. K.M.
4 HRFINISHED
3 T.C. 7 K.M.**Areas - Read**STARTED
4 T.C. 8 K.M.**Vehicles Used**

7-8

General Foreman

Frank J. Pace

Date 5-30-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

SERVICE TRUCK WORK ORDERS

Jobs Completed

LOCATES

Employees on JobF.P. - Gif.
Q.142**Vehicles or Equip. Used**

7-11

Sewer Department**Address**BY-PASS PUMPED WITH BOTH 3" GAS PUMPS
AT 715 **Ex. 6 (Personal Privacy)** EDNA, CALVIN,
CHURCH RD. STATION, CLINTON**Job Completed**PULLED #2 PUMP & CLEANED RAGS **Ex. 6 (Personal Privacy)**
REPLACED 4" CAM LOCK X 4" I.P. NIPPLE FOR
DISCHARGE BY-PASS & MADE UP HOSE AT CHURCH**Employees on Job**K.M. - B.S. - T.C. - F.P.
GARRD. STATION /
ALL STATIONS ON EXCEPT
& CHURCH RD.**Ex. 7f (Water Infra.)****Vehicles or Equip. Used**

7-14-15-BACKHOE

PULLED BACK & CLEANED OUT RAGS AT
BRIDGE DALE**Meter Readers****Employees on Job****Areas - Read****Vehicles Used****General Foreman**

Franky - Sale

Date 5-29-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

W.O.

Started pull in brideclale

Jobs Completed**Employees on Job**

BS, TC, GF

Vehicles or Equip. Used

14, 11, Backhoe

Sewer Department**Address**Checked stations
manually pumped 53rd**Job Completed****Employees on Job**

BS, TC


Vehicles or Equip. Used

14, 8

Meter Readers**Employees on Job**

KM, BS

Cycle 2 started - 10 left (wont pick up)

Areas - Read**Vehicles Used****General Foreman**

Date 5-28-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

SERVICE TRUCK WORK ORDERS

Jobs CompletedREPAIR SERVICE AT
USED ONE 3/4" FLARE X COMP. FITTING, 3 OF
3/4" COPPER TUBING, ONE 18" x 30" P.V.C. METER

Ex. 6 (Personal Privacy)

Employees on JobG.F. - T.C. - F.P.-B.S.
4HR 5HRBOX, ONE 18" METER SET - COPPER ON
BOTH HOUSE & MAIN SIDE, BACK FILL
SPOIL, INSTALLED RAD RAB METER**Vehicles or Equip. Used**

EXPOSED TAP FOR N PREP FOR

Ex. 6 (Personal Privacy)

8-11-14

JOB TOMORROW

Sewer Department**Address**BY-PASS PUMPED WITH 3" GAS PUMP
AT 71ST
PITTSBURG

Ex. 7f (Water Infra.)

Ex. 7f (Water Infra.)

Job Completed

CYCLED BLOWERS AT OAKLAND

Ex. 7f (Water Infra.)

Employees on JobK.A.
6HR**Vehicles or Equip. Used**

15

Meter Readers**Employees on Job**T.C. - F.P.-B.S.
4HR 3HR

FINISHED

172-T.C. 29-F.P.-B.S.

Areas - Read**Vehicles Used**

8-14

General Foreman

Franky Pace

Date 5-27-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address****Jobs Completed****Employees on Job****Vehicles or Equip. Used****Sewer Department****Address****Job Completed****Employees on Job****Vehicles or Equip. Used****Meter Readers****Employees on Job****Areas - Read****Vehicles Used****General Foreman**Frank P. Pace

HOLIDAY
MEMORIAL DAY

Date 5-24-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

W.O

Jobs Completed**Employees on Job**

G.F

Vehicles or Equip. Used

11

Sewer Department**Address**Pulled & replaced motor @ bridge Dale
Bypass pumped 71st & pillbox**Job Completed**Cycled crockett **Ex. 7f (Water Infra.)****Employees on Job**

B.M, B.S, T.C

Vehicles or Equip. Used

15, 14

Meter Readers**Employees on Job**


K.M, T.C, B.S

Areas - Read

Large Consumers

Vehicles Used

8

General Foreman

Date 5-23-19

Daily Job Sheet

Sheet of Water Department

Comments

Address

W.O.

Backfilled

Ex. 6 (Personal Privacy)

Jobs Completed

Employees on Job

Vehicles or Equip. Used

11

Sewer Department

Address

Checked stations, Replaced belt
station

Ex. 6 (Personal Privacy)

Job Completed

Employees on Job

KM, BS, TC

Vehicles or Equip. Used

15, 14

Meter Readers

Employees on Job

KM

Radio Reads cycle 5

Finished

Areas - Read

Vehicles Used

General Foreman

K. Gall

Date 5-22-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

N.O

Ex. 6 (Personal Privacy)

Rebuild service called line out of main
Repaired line and rebuild service Backfill tomorrow
④ 4" ac (2) (3) copper - copper 10' copper (5-23-2019)
② 3/4 corp (3) (1) front side (1) Backside

Jobs Completed**Employees on Job**

B.S., T.C., K.M., G.F.

Vehicles or Equip. Used

14, 15, BACKHOE

Sewer Department**Address**

Bypass pumped 712' & pillbox, cycled cricket

Ex. 7f (Water Infra.)

Job Completed**Employees on Job**

KM


Vehicles or Equip. Used

15

Meter Readers**Employees on Job****Areas - Read****Vehicles Used****General Foreman**

Date 5-21-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**W.O. / Locates**Jobs Completed****Employees on Job**G.F.B.S, TC**Vehicles or Equip. Used**11, 14**Sewer Department****Address**Pulled pump Ex. 6 (Personal Privacy) cleaned and
replaced
emptied and replenished oil in Oakland Ex. 7f (Water Infra.)**Job Completed**Pumped 63rd Ex. 7f (Water Infra.) jumped calvin buld.
Cycled 73rd oakland Ex. 7f (Water Infra.)**Employees on Job**K.M., T.C, B.S.**Vehicles or Equip. Used**14, 11, BACKHOE**Meter Readers****Employees on Job****Areas - Read****Vehicles Used****General Foreman**

Date 5-20-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**W.O.
LocatesRepaired & seeded yards
(All auto)**Jobs Completed****Employees on Job**

G.F., B.S., T.C.

Vehicles or Equip. Used

11, 14, Backhoe

Sewer Department**Address**

Ex. 6 (Personal Privacy)

short cycling (needs pulling)

Job CompletedBypass pumped 71st & pull box
Cycled 73rd stations


Ex. 7f (Water Infra.)

Employees on Job

KM

Vehicles or Equip. Used

15

Meter Readers**Employees on Job****Areas - Read****Vehicles Used****General Foreman**

Date 5-17-19

Daily Job Sheet

Sheet of **Water Department****Comments**

Address	SERVICE TRUCK W.O.
Jobs Completed	PULLED NEW CHLORINATING LINE AT Ex. 7f (Water Infra.) TANK
Employees on Job G.P. - F.P. - B.S. 2 HR	
Vehicles or Equip. Used	
11-14	

Sewer Department

Address	BY-PASS PUMPEA WITH 3" GAS PUMP AT TIST Ex. 7f (Water Infra.) LAKE PUL BOX CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.)
Job Completed	INSTALLED SAFETY FENCING AT WET WELL AT VIOLAT Ex. 6 (Personal Privacy)
Employees on Job F.P. - B.S. - K.M. 4HR 6HR 4HR	CHECKED ON BACKUPS - CUST. PROBLEMS
Vehicles or Equip. Used	
14-15 - BACKHOLE	

Meter Readers

Employees on Job	T.C. - F.P. 2HR FINISHED 21 & 22 - T.C. 26 - F.P.
Areas - Read	STARTED
Vehicles Used	7-8
General Foreman	Frank Pace

Date 5-16-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**SERVICE TRUCK W.O.
LOCATES**Jobs Completed****Employees on Job**F.P. G.F. - B.S.
2HR 3HR**Vehicles or Equip. Used**

11-14

Sewer Department**Address**INSTALLED BELT ON #1 PUMP AT
Ex. 7f (Water Infra.)**Job Completed**PUT IN POSTS AROUND WET WELL AT
LAURALEE **Ex. 7f (Water Infra.)****Employees on Job**F.P. - B.S.
4HR 2HR**Vehicles or Equip. Used**

14

Meter Readers**Employees on Job**K.M. - T.C. F.P. B.S.
6HR 3HR

FINISHED

19-B.S. & K.M. - 20-K.M. & F.P. - 23 & 24-T.C.

Areas - Read**Vehicles Used**

7-8-14

General ForemanFrank J. Pace

Date 5-15-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

SERVICE TRUCK W.O.

Jobs Completed**Employees on Job**

G.F.

Vehicles or Equip. Used

11

Sewer Department**Address**BY-PASS PUMPED WITH 3" GAS PUMP AT
715 **Ex. 7f (Water Infra.)** PILL BOX

308 72ND IS LOCATED

Job CompletedCYCLED BLOWERS AT OAKLAND
INSTALLED JUMP PUMP AT 513**Ex. 7f (Water Infra.)****Employees on Job**

F.P. - B.S. - T.C.

CHECKED STATIONS - PULLED BACK OFF OF
PUMP & CLEANED OUT RAGS AT BRIDGEDALE
Ex. 7f (Water Infra.) FEELS BELTS -
BELLEVILLE STILL UP**Vehicles or Equip. Used**

9-14-15

SETTED & VACUUMED LINE ON 71ST UNTIL BACK
MOTOR ON UNIT 9 QUIT RUNNING. TESTED IN
68" & HIT SAND/BLOCK.**Meter Readers****Employees on Job****Areas - Read****Vehicles Used****General Foreman**

Frank J. Pace

Date 5-14-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

SERVICE TRUCK W.O.

Jobs Completed**Employees on Job**

C. F.

Vehicles or Equip. Used**Sewer Department****Address**REPAIRED VACUUM HOSE ON UNIT #9 -
STILL NEED NEW HOSE - OLD ONE CRACKED &
WORN**Job Completed**

INSTALLED PUMP IN FIELD Ex. 6 (Personal Privacy)

PULLED PUMP #10 CLEANED RAGS OUT AT


Ex. 6 (Personal Privacy)

Employees on JobF.P. - B.S. - T.C. - K.M.
4HRINSTALLED NEW BELTS & PULLED BACK OFF
ON PUMP & CLEANED OUT RAGS AT 51ST +

Ex. 7f (Water Infra.)

Vehicles or Equip. Used

14-15-BACKHOLE

Meter Readers**Employees on Job****Areas - Read****Vehicles Used****General Foreman**

Date 5-13-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

SERVICE TRUCK W.O.

LOCATES

Jobs CompletedREPLACED CRUSHED METER BOX &
INSTALLED NEW RADIO READ METER AT
Ex. 6 (Personal Privacy) BACKFILLED WITH ONE
BUCKET SAND FROM SHOP & SPOIL**Employees on Job**G.F. - F.P.-T.C.
4 HR**Vehicles or Equip. Used**

11-14-BACKHOLE

Sewer Department**Address**BY-PASS PUMPED WITH BOTH 3" GAS PUMPS
AT 71ST Ex. 7f (Water Infra.) PILL BOX,
CALVIN, PITTSBURG, RENOIS**Job Completed**

CYCLED BLOWER AT OAKLAND

Ex. 7f (Water Infra.)

Employees on JobK.M. F.P.-T.C.
4 HR

SETTLED LINE TO RELIEVE BACKUP AT

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

9-14-15-BACKHOLE

PULLED BACK OFF PUMP & CLEANED OUT
RAGS AT BRIDGE ALE TO RELIEVE BACKUP
CALL FROM Ex. 6 (Personal Privacy)**Meter Readers****Employees on Job****Areas - Read****Vehicles Used****General Foreman**

Franky Pace

Date 5-10-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK W.O. LOCATES RE-READS
Jobs Completed	
Employees on Job G.F. - B.S. GHR 2 HR	
Vehicles or Equip. Used	
11-14	

Sewer Department

Address	BY-PASS PUMPED WITH BOTH 3' GAS PUMPS AT 715 Ex. 7f (Water Infra.) PILL BOX, FIELD FROM Ex. 6 (Personal Privacy)
Job Completed	CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.)
Employees on Job K.M. - B.S. GHR 4 HR	PULLED BACK OFF OF PUMP & CLEANED OUT RAGS AT BRIDGE DALE
Vehicles or Equip. Used 14-15-BACKHOC	CHECKED STATIONS

Meter Readers

Employees on Job B.S. - F.P. - K.M. 2 HR 2 HR	FINISHED AREAS 17 & 18 - F.P. RADIO READS - B.S.
Areas - Read	DIPPED OUT BOXES & READ METERS IN AREAS 15, 17 & 18 - F.P. & K.M.
Vehicles Used 7-15	

General Foreman Frank J. Pace

Date 5-9-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

G.F.

Vehicles or Equip. Used

11

Sewer Department

Address

BY-PASS PUMPED AT 71ST Ex. 7f (Water Infra.)
JACKET & VIDEOED LINE - CLEANED LINE
OUT FROM EDNA M.H. 70' TOWARDS LAKE

Job Completed

VACUMED OUT 1/2 TRUCK LOAD OF SAND &
DUMPED AT Ex. 6 (Personal Privacy)

Employees on Job

B.S. - T.C. - K.M.

Vehicles or Equip. Used

9-14-15

Meter Readers

Employees on Job

F.P.

FINISHED
15 EXCEPT FOR F.O.W.

Areas - Read

STARTED
17

Vehicles Used

7

General Foreman

Frank J. Pace

Date 5-8-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed		
Employees on Job	C.F.	
Vehicles or Equip. Used		
11		
Sewer Department		
Address	BY-PASS PUMPEA WITH 3" GAS PUMP AT 71ST & G3RD BLVD. Ex. 7f (Water Infra.)	
Job Completed	CYCLED BLOWERS AT OAKLAND & BLUFF CHECKED ON CREW WORKING ON SEWER LIFT CLEANED OUT ROOTS FROM LAT. Ex. 6 (Personal Privacy)	
Employees on Job	F.P. - B.S. - K.M. REMOVED TWO MOTORS & ONE BLOWER FROM BLUFF - OPENED UP CULVERT TO DRAIN FIELD AROUND BLUFF STATION & PUMPED OUT CAN	
Vehicles or Equip. Used	14-15 - BACKHOE	
Meter Readers		
Employees on Job	T.C. FINISHED 13414	
Areas - Read		
Vehicles Used	8	
General Foreman	Franky Paul	

Date 5-7-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK W/O. LOCATED
Jobs Completed	RE-LOCATED METER BOX OUTSIDE FENCING AT Ex. 6 (Personal Privacy) USED ONE $\frac{3}{4}$ " \times $\frac{3}{4}$ " COMP. FITTING, ONE MARK COUPLING, ONE METER SHUT
Employees on Job F.P. - B.S. - G.F. - K.M. 4 HR	OFF, ONE 18" \times 30" P.V.C. METER BOX, 12" OF $\frac{3}{4}$ " COPPER TUBING. BACKFILL WITH SPOIL - LINES IN & OUT OF BOX ARE COPPER
Vehicles or Equip. Used 11-14-15 - BACKHOLE	LOCATED & OPENED VALVES AT Ex. 6 (Personal Privacy) JUDITH - RAISED ONE VALVE BOX & REPLACED BROKEN VALVE BOX TOP - USED BOX TOP FROM SHOP

Sewer Department

Address	LOCATED M.H. ON LINDORF DR. - WORKED WITH CREW REPAIRING SEWER LINE AT Ex. 6 (Personal Privacy)
Job Completed	CHECKED BACKUP AT Ex. 6 (Personal Privacy) LINES DOWN & PUMP PUMPING - CUST. PROBLEM - NO ONE HOME
Employees on Job F.P. - B.S. 2 HR	
Vehicles or Equip. Used 14	

Meter Readers

Employees on Job T.C.	FINISHED 11/2/12
Areas - Read	
Vehicles Used 11	
General Foreman Frank J. Pace	

Date 5-6-19

Daily Job Sheet

Sheet of Water DepartmentComments


Address	rebuild service @ 36 Debres using $\frac{1}{4}$ copper to $\frac{1}{4}$ shut off, $\frac{1}{4}$ backside. w.o.
Jobs Completed	
Employees on Job	
G.F, B.S, T.C	
Vehicles or Equip. Used	
14, 11, Backhoe	

Sewer Department

Address	Bypass pumped at Renois Cycled oakland + crockett stations Bypass pumped 71st + pillbox
Job Completed	
Employees on Job	
B.S, T.C, KM	
Vehicles or Equip. Used	
15, 14, BACKHOE	

Meter Readers

Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman 

Date 5-3-19

Daily Job Sheet

Sheet ____ of ____

<u>Water Department</u>		Comments
Address		W.O.
Jobs Completed		
Employees on Job		
GF		
Vehicles or Equip. Used		
11		
<u>Sewer Department</u>		
Address		Check sewers, jetted line on Pearl, pumped down 71 st & pillbox, cycled oakland Ex. 7f (Water Infra.)
Job Completed		Tightened Tightened belts @ Ex. 7f (Water Infra.)
Employees on Job		
K.M, T.C, BS		
Vehicles or Equip. Used		
14, 15, Set truck		
<u>Meter Readers</u>		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	<u>K. J. McFall</u>	

Date 5-2-19

Daily Job Sheet

Sheet ___ of ___

<u>Water Department</u>		Comments
Address	W.O.	
Jobs Completed		
Employees on Job	G.F.	
Vehicles or Equip. Used	11	
<u>Sewer Department</u>		
Address	Check stations, pumped 71st & pillbox, replaced hose @ clinton, jetted 71st to pillbox 100ft from manhole, cycled crockett	
Job Completed		
Employees on Job	B.S., K.M., T.C.	
Vehicles or Equip. Used	14, 15, Jet truck	
<u>Meter Readers</u>		
Employees on Job	Started	Finished
B.S., T.C.	6 - B.S.	6 - T.C.
Areas - Read	6	
Vehicles Used	14, 8	
General Foreman	Kurt McCall	

Ex. 7f (Water Infra.)

Date 5-1-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O.
LOCATES

Jobs Completed

SHOT OFF BRANCH VALVE TO HYDRANT AT
157 Ex. 6 (Personal Privacy)

Employees on Job

G.F. F.P. B.S.
4HR 5HR

INSTALLED RE SETTER AT

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

11-14

Sewer Department

Address

Cycled crocket Ex. 7f (Water Infra.)
down pillbox, pumped

Job Completed

Employees on Job

K.M.

Vehicles or Equip. Used

15

Meter Readers

Employees on Job


T.C. - K.M. - F.P.
8 2hr 1HRFINISHED
CYCLE 3
RADIOS - F.P. 5-10 & 9 P.O.W.S - K.M.

Areas - Read

Started
6 - T.C.

Vehicles Used

General Foreman



Date _____

Daily Job Sheet

Sheet ____ of ____

Water Department		Comments
Address	W.O. / Locates	
Jobs Completed		
Employees on Job		
GP, TC, BS		
Vehicles or Equip. Used		
3, 4, 2		
Sewer Department		
Address	Cycled manholes, checked stations Ex. 7f (Water Infra.)	
Job Completed		
Employees on Job		
KM		
Vehicles or Equip. Used		
5		
Meter Readers		
Employees on Job	Started and finished	
KM, TC, BS	1 + 2 + 29	
Areas - Read		
1, 2, 29		
Vehicles Used		
4, 5		
General Foreman <i>K. McCall</i>		

Date 6-28-19

Daily Job Sheet

Sheet of Water DepartmentCommentsAddressSERVICE TRUCK WORK ORDERS
PUT TIRES ON BACKHOESJobs CompletedREPAIR SERVICE AT **Ex. 6 (Personal Privacy)**
USED ONE METER COUPLING, ONE METER
SHUT OFF, ONE 18" X 30" P.V.C. METEREmployees on JobG.F. - F.P.-B.S. - K.M.
5 HR 2 HRBOX, 4' OF 3/4" COPPER TUBING, ONE
3/4" P.V.C. BARB X COMP. FITTING. BACKFILLED
WITH SPOILVehicles or Equip. Used

11-14-15- BACKHOLE

Sewer DepartmentAddressBY-PASS PUMPED WITH 3" GAS PUMP AT
TIST **Ex. 7f (Water Infra.)** KE RILL BOX
CYCLED BLOWERS AT OAKLAND **Ex. 7f (Water Infra.)**Job CompletedCHECKED STATIONS - PULLA BACK OFF
PUMP & CLEANED OUT RAGS AT BRIDGEDALE
Ex. 7f (Water Infra.) MAY NEED PULLED - KICKED OUT &Employees on JobK.M. - E.P. - B.S.
6 HR 2 HRPUMPED FOR 2 HR TODAY TO GET WELL
DOWN - NEED TO PULL PUMP #1 AT
Ex. 6 (Personal Privacy) SWITCHED TO PUMP #2 AUTO &Vehicles or Equip. Used

PUMPING WELL DOWN NOW

14-15

Meter ReadersEmployees on Job

T.C.

FINISHED
4Areas - ReadSTARTED
5Vehicles Used

8

General Foreman

Frank J. Lee

Date 6-27-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

SERVICE TRUCK WORK ORDERS

Jobs CompletedINSTALLED 30" RESTRAINING NIPPLE &
HYDRANT EAST OF Ex. 6 (Personal Privacy) SAUGHT
INA. PKWY. - BACKFILLED WITH 12" CURB
OF CLEAN ROCK FROM SHOP & SPOIL -**Employees on Job**C.G. - F.P. - B.S. - K.M.
5 HR

NEED TO FLUSH HYDRANT

Vehicles or Equip. Used

11-14-15 - BACKHOE

Sewer Department**Address**PULLED PUMP & CLEANED OUT RAGS AT
CHURCH RD. - PUMPING NOW - DRAWING
15-16 AMPS WHEN PUMPING**Job Completed****Employees on Job**

F.P. - B.S. - K.M.

Vehicles or Equip. Used

14-15 - BACKHOE

Meter Readers**Employees on Job**

T.C.

FINISHED
3 EXCEPT F.O.W.'S**Areas - Read**

STARTED

4

Vehicles Used

8

General Foreman

Francis Pace

Date 6-26-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

SERVICE TRUCK W/O

Jobs Completed**Employees on Job**B.S. - C.F. - T.C.
C.H.R.

UNLOADED HYDRANT FOR SAUGET

Vehicles or Equip. Used

14-11-8

Sewer Department**Address**BY-PASS PUMPED WITH 3" GAS PUMPS
AT 71ST Ex. 7f (Water Infra.) DNA,
63RD Ex. 7f (Water Infra.) BLVD & CHURCH RD.**Job Completed**LOADED LADDER, BALLS, & AIR TANK FOR
REMOVAL OF PUMP ON CHURCH RD.**Employees on Job**K.M. - F.P. - T.C.
J.H.R. 2 H.R.ONE MAN + UNIT 9 AT 37TH FOR CENTREVILLE
NO ONE FROM CENTREVILLE SHOWED UP
AFTER 2 HOURS**Vehicles or Equip. Used**

7-15

CYCLED BLOWERS AT OAKLAND

Ex. 7f (Water Infra.)

Meter Readers**Employees on Job**

F.P.

FINISHED
RADIO READS**Areas - Read****Vehicles Used**

7

General Foreman

Frank J. Price

Date 6-25-19

Daily Job Sheet

Sheet of **Water Department****Comments**

Address	SERVICE TRUCK W.O.
Jobs Completed	REBUILT BACKSIDE AT USED ONE METER COUPLING, ONE 24" X 24" COMP. FITTING, ONE 18" X 30" P.V.C. METER BOX
Employees on Job F.P. - B.S. - T.C. G.M. 3DR	CLEARING BRUSH FROM AROUND HYDRANT AT T. ROMAN
Vehicles or Equip. Used 14 - BACKHOG	RAISED BOX WITH 6" CLAY RISER CUT AT SHOP & INSTALLED RADIO READ METER AT

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Sewer Department

Address	BY-PASS PUMPED AT CHURCH RD.
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers

Employees on Job K.M. F.P. - T.C. JDR 3DR 5DR	FINISHED 142 - T.C. 29 F.O.W.S - K.M. & T.C.
Areas - Read	STARTED RADIO READS - F.P.
Vehicles Used 8-7	

General Foreman

Frank J. Pace

Date 6-24-19

Daily Job Sheet

Sheet of **Water Department****Comments**

Address

W.A.

Jobs Completed

Employees on Job

BS

Vehicles or Equip. Used

11

Sewer Department

Address

Cycled crockett **Ex. 7f (Water Infra.)**
Bypass pumped: 71st, pillbox, church road, pittsburg

Job Completed

Employees on Job

KM

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

BS

started & finished
Large consumers


Areas - Read

Large consumers

Vehicles Used

8

General Foreman



Date 6-21-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

SERVICE TRUCK W.O.

LOCATES

Jobs CompletedINSTALLED FENCING AROUND HOLE
WHERE HYDRANT WAS REMOVED EAST
OF **Ex. 6 (Personal Privacy)** PARKWAY**Employees on Job**

F.P. - B.S.

HAULED BOXES TO STORAGE ROOM ABOVE
BREAK ROOM**Vehicles or Equip. Used**

11-19

Sewer Department**Address**BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST **Ex. 7f (Water Infra.)** PILL BOX,
CALVIN BLVD.**Job Completed**CYCLED BLOWERS AT OAKLAND **Ex. 7f (Water Infra.)****Employees on Job**

K.M.

Vehicles or Equip. Used

15

Meter Readers**Employees on Job****Areas - Read****Vehicles Used****General Foreman**

Frank J. Pace

Date 6-20-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O.

Jobs Completed

LOCATES

Employees on Job

F.P. - B.S. - T.C.
GAR 5HR

Vehicles or Equip. Used

14-11-8

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP
AT CHURCH RD., PITTSBURG, 75TH

Ex. 7f (Water Infra.)

Job Completed

PUT DISCHARGE HOSE INTO DISCHARGE
LINE AT 75TH

Ex. 7f (Water Infra.)

Employees on Job

K.M.
5HR

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

T.C. & K.M. - F.P.
3HR 2HR

FINISHED

19-T.C. & K.M. -

RADIO READS F.P.

Areas - Read

Vehicles Used

7-8

General Foreman

Frank J. Pace

Date 6-19-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

SERVICE TRUCK WORK ORDERS

Jobs CompletedREMOVED HYDRANT 6" 8" BRANCH VALVE
INSTALLED 36" RESTRAINING NIPPLE +
ONE 6" GATE VALVE IN SAUGET - 500**Employees on Job**F.P. - B.S. - K.M.
3THCFT. EAST OF **Ex. 6 (Personal Privacy)** PARKWAY
DR. (GASKET & SCALE)**Vehicles or Equip. Used**

14-11-15-BACKHOLE

Sewer Department**Address****Job Completed**BY-PASS PUMPED WITH 3" GAS PUMP AT
715 **Ex. 7f (Water Infra.)** PILL BOX**Employees on Job**

K.M.

CYCLER BLOWERS AT ORKLAND +

Ex. 7f (Water Infra.)**Vehicles or Equip. Used**

15

Meter Readers**Employees on Job**

T.C.

FINISHED
24 @ 26**Areas - Read****Vehicles Used****General Foreman**

Frank G. Pace

Date 6-18-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address***OVER TIME CALL OUT***Jobs Completed***SHUT DOWN VALVES ALONG SAUGET
Ex. 6 (Personal Privacy) TO ISOLATE HYDRANT
THAT WAS HIT BY POWER***Employees on Job***F.P. - K.M.
3HR 2HR***Vehicles or Equip. Used***14***Sewer Department****Address****Job Completed****Employees on Job****Vehicles or Equip. Used****Meter Readers****Employees on Job****Areas - Read****Vehicles Used****General Foreman***Franky Pace*

Date 6-18-19

Daily Job Sheet

Sheet of **Water Department****Comments**

Address

SERVICE TRUCK W.O.

Jobs Completed

CUT 14" CLAY RISER TO RAISE BOX,
INSTALLED ONE RESETTER WITH NEW
SHUT OFF & R.R. METER AT

Ex. 6 (Personal Privacy)

Employees on Job

F.R. - B.S.

DUG OUT BOX, RAISED BOX WITH ONE ROW
OF BRICK & INSTALLED RESETTER AT

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

11-14

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

K.M.

FINISHED
22

Areas - Read

STARTED
24

Vehicles Used

8

General Foreman

Franky Pace

Date 6-17-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O.

Jobs Completed

REPAIRED 24 P.I.C. main Break on
Ex. 6 (Personal Privacy) ONE 2" S.S. REPAIR
CLAMP - BACKFILLED WITH SPOIL

Employees on Job

F.P.-B.S.

Vehicles or Equip. Used

11-14- BACKHOLE

Sewer Department

Address

BY-PASS PUMPED WITH 2" GAS PUMPS AT
71ST Ex. 7f (Water Infra.) PILL BOX,
CHURCH RD.

Job Completed

CYCLED BLOWERS AT OAKLAND

Ex. 7f (Water Infra.)

Employees on Job

K.M.
5 HR

Vehicles or Equip. Used

15

REPLACED 3" DISCHARGE HOSE AT CHURCH
RD. STATION BY-PASS

Meter Readers

Employees on Job

K.M.-T.C.
3 HR

FINISHED

20+21-T.C. - 23-K.M.

Areas - Read

STARTED

Vehicles Used

8

General Foreman

Frank J. Pace

Date 10-14-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

Employees on Job

B.S.

Vehicles or Equip. Used

11

Sewer Department

Address

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMPS
AT 715 **Ex. 7f (Water Infra.)** PILL BOX,
25TH **Ex. 7f (Water Infra.)**

Employees on Job

K.M.

CYCLED BLOWERS AT OAKLAND &

Ex. 7f (Water Infra.)

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

F.P.

FINISHED

17018 & RADIO READS

Areas - Read

Vehicles Used

7

General Foreman

Frank J. Price

Date 6-14-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

REPAIRED 4" A.C. MAIN BREAK AT NELSON - USED TWO 50' EXTREME FITTINGS & 22' OF 4" C-900 P.V.C.

Ex. 6 (Personal Privacy)

Jobs Completed

BACK FILLED WITH ONE BUCKET OF CLEAN ROCK & SPOIL - NEED TO REPAIR YARD & DRIVEWAY

Employees on JobF.P. - K. M. H. Shrs
ea.

OVERTIME

Vehicles or Equip. Used

14 - BACKHOE

Sewer Department**Address****Job Completed****Employees on Job****Vehicles or Equip. Used****Meter Readers****Employees on Job****Areas - Read****Vehicles Used****General Foreman**

Frank J. Ace

Date 6-13-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O.

Jobs Completed

Employees on Job

G.P.

Vehicles or Equip. Used

11

Sewer Department

Address

BY-PASS PUMPED WITH BOTH 3" GAS
PUMPS AT 715 **Ex. 7f (Water Infra.)** PILL BOX
CALVIN BLVD, & CHURCH RD.

Job Completed

CYCLED BLOWERS AT OAKLAND

Ex. 7f (Water Infra.)

Employees on Job

K.M.

CHECKED FOR SEWER BACKUP AT
WESTWOOD - CUST. PROBLEM**Ex. 6 (Personal Privacy)**

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

F.P. - B.S.

FINISHED

14 - B.S.

15 - F.P.

Areas - Read

STARTED

17 - B.S.

18 - F.P.

Vehicles Used

7-8

General Foreman

Frank J. Pace

Date 6-12-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

SERVICE TRUCK - WORK ORDERS

LOCATES

Jobs CompletedREPAIRED 4" A.C. MAIN HIT BY BORE
CRAW. A **Ex. 6 (Personal Privacy)** USED ONE 4" A.C.
S.S. REPAIR CLAMP - BACKFILLED WITH SAND &**Employees on Job**

F.P. - B.S. - G.F.

DIRT FROM SHOP - HAULED OFF SPOIL

FILLED IN HOLE WITH DIRT & ROCK AT
UPPER CAHOKIA**Ex. 6 (Personal Privacy)****Vehicles or Equip. Used**

14-15-11 - BACKHOP

LOCATED METER BOX AT

Ex. 6 (Personal Privacy)**Sewer Department****Address****Job Completed****Employees on Job****Vehicles or Equip. Used****Meter Readers****Employees on Job**

K.M.

FINISHED

12 & 13

Areas - Read**Vehicles Used**

8

General Foreman

Frank J. Rose

Date 6-11-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK W.O. (OKR)

Jobs Completed

REPLACED NEW P.V.C. LINE UNDER ROAD AT
Ex. 6 (Personal Privacy) USED 42' OF 3/4" P.V.C.
 TUBING, 4' OF 2" COLLIER TUBING, TWO 3/4"

Employees on Job

C.F. - F.P. - B.S.
2me

INSERTS, ONE 3/4" X 3/4" COMP. FITTING. COPPER
 OUT OF BOX ON BOTH SIDES CONNECTED TO P.V.C.
 RE-USED METER SHUT OFF + BOX RING/LID
 44' METER TO MAIN

Vehicles or Equip. Used

11-14- BACKHOE

SHUT DOWN VALVES TO ISOLATE LEAK AT
Ex. 6 (Personal Privacy)

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
Ex. 7f (Water Infra.) PILL BOX, CSRD
Ex. 7f (Water Infra.) CHURCH RD.

Job Completed

CYCLED BLOWERS AT OAKLAND **Ex. 7f (Water Infra.)**

Employees on Job

K.A.A.

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

C.F.
6meFINISHED
11

Areas - Read

STARTED
12

Vehicles Used

11

General Foreman

Frank J. Pace

Date 6-10-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

Pull job
Ex. 6 (Personal Privacy)
new set (1) corp, 40' copper
copper to copper,

Jobs Completed**Employees on Job**

G.F., B.S., K.M.

Vehicles or Equip. Used

14, 15, Backhoe

Sewer Department**Address****Job Completed****Employees on Job****Vehicles or Equip. Used****Meter Readers****Employees on Job****Areas - Read****Vehicles Used****General Foreman** _____

Date 6-7-19

Daily Job Sheet

Sheet ___ of ___

Water Department**Comments****Address**

W.O / Locates

Jobs Completed**Employees on Job**

G.F.

Vehicles or Equip. Used

11

Sewer Department**Address**Bypass pumped 71st + pillbox.
Bypass pumped Church Road.**Job Completed**

Cycled oakland

Ex. 7f (Water Infra.)**Employees on Job**

T.C., K.M.

Vehicles or Equip. Used

8, 15

Meter Readers**Employees on Job**


K.M., T.C.

Radio Reads cycle 3
Dipped out flooded meters**Areas - Read**

RR

Vehicles Used

8, 13

General Foreman

Date 6-6-19

Daily Job Sheet

Sheet of **Water Department****Comments**

Address

W.O. / Locates

Jobs Completed

Employees on Job

G.F., B.S.

Vehicles or Equip. Used

11, 14**Sewer Department**

Address

Installed motor @ oakland stationCycled oakland **Ex. 7f (Water Infra.)**

Job Completed

Bypass pumped clinton stations**Ex. 7f (Water Infra.)**

Employees on Job

B.S., K.M.

Vehicles or Equip. Used

15, 14**Meter Readers**

Employees on Job

T.C.Finished9Started & finished10

Areas - Read

9-10

Vehicles Used

8

General Foreman

[Signature] McCall

Date 6-5-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

Pull o **Ex. 6 (Personal Privacy)** copper to copper,
(1) load of 7 inch clean rock, 5 buckets of CMR rock
40 feet of copper

Jobs Completed

W/O / Locates

Employees on Job

KM, TC, BS

Vehicles or Equip. Used

¹⁴
Dumptruck, Backhoe

Sewer Department**Address**

Jet job @ **Ex. 6 (Personal Privacy)**

Job Completed

Bypass pumped at Church **Ex. 7f (Water Infra.)**

Employees on Job

T.C, B.S

Vehicles or Equip. Used

Jettruck

Meter Readers**Employees on Job****Areas - Read****Vehicles Used****General Foreman**

 M. Call

Date 6-4-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address***W.O. / Locates***Jobs Completed****Employees on Job***GF***Vehicles or Equip. Used***11***Sewer Department****Address***Bypass pumped Church Road
Bypass pumped Calvin Blvd***Job Completed****Employees on Job***B.S., KM***Vehicles or Equip. Used***Backhoe, 15***Meter Readers****Employees on Job***T.C., BS**Finished**Started**5, 6 (T.C.) 8 (BS) 9 (BS)***Areas - Read***5, 6, 8***Vehicles Used***8, 7***General Foreman***[Signature] / Call*

Date 6-3-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

W.O. / Locates

Jobs Completed

Employees on Job

G.F., B.S.

Vehicles or Equip. Used

11Sewer Department

Address

Bypass pumped 71st & pillbox, cycled crockett station
replaced breaker @ oakland

Job Completed

Employees on Job

K.M., B.S.

Vehicles or Equip. Used

15, 14Meter Readers

Employees on Job

T.C.started & finished / started
4 / 5

Areas - Read

4, 5

Vehicles Used

8

General Foreman

K. Hall

Date 7-31-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address		SERVICE TRUCK W.O.
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		
Sewer Department		
Address		BY-PASS PUMPED WITH 3" GAS PUMP AT 7:30 Ex. 7f (Water Infra.) RICE BOX CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.)
Job Completed		DUG TOP OFF OF WET WELL AT BLUFF, STARTED TO VACUUM SOLIDS OFF TOP THEN UNIT 9 BACK ENGINE SHUT DOWN.
Employees on Job F.P. - B.S. - K.M. - T.C. DWR		EXPOSED LATERAL + FOUND BAD CONNECTION AT UPRIGHT VERTICAL TO MAIN - CUT OUT 13' OF LATERAL - NEEDED TO HOOK UP LATERAL Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 14-15 - BACKHOE-9-		TO VERTICAL AT
Meter Readers		
Employees on Job C.F. T.C. DWR		FINISHED TO 6 + 7 - T.C. & G.F.
Areas - Read		STARTED 8 T.C.
Vehicles Used 8		
General Foreman <u>Frank - Pace</u>		

Date 7-30-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS MRT PLUMBER ON PILOT JOB ABOUT TAPPING OUR MAIN	
Jobs Completed	REPLACED METER SHUT OFF AT STERLING - CRIMPED LINE IN BOX & REPLACED SHUT OFF -	
Employees on Job F.P. - B.S. - C.F. 4 PR	REPLACED SHUT OFF AT CAMOKIA - CRIMPED LINE OFF IN BOX & REPLACED SHUT OFF	
Vehicles or Equip. Used		
11-14 - BACKHOLE		
Sewer Department		
Address	CHECKED STATIONS ON 8 JND & M.H.S TESTED TWO PUMPS FOR BLUFF. BOTH GOOD	
Job Completed	CYCLE Ex. 6 (Personal Privacy) Y-PASS PUMP	
Employees on Job F.P. - B.S. - K.M. 4 PR	BY-PASS PUMPED WITH 3" GAS PUMP AT G3RD Ex. 7f (Water Infra.) PALVIN	
Vehicles or Equip. Used		
14-15 - BACKHOLE		
Meter Readers		
Employees on Job T.C.	FINISHED 5	
Areas - Read	STARTED 6	
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		

Date 7-29-19

Daily Job Sheet

Sheet of

<u>Water Department</u>	<u>Comments</u>
Address	W.O. / Locates
Jobs Completed	
Employees on Job G.F, B.S	
Vehicles or Equip. Used 11, 14	

<u>Sewer Department</u>	
Address	Check Stations ; Bypass pumped 715 [±] • pillbox, oakland, crockett stations
Job Completed	
Employees on Job K.M, B.S	
Vehicles or Equip. Used 15, 14	

<u>Meter Readers</u>	
Employees on Job T.C, B.S	<u>Finished</u> <u>Started</u> • Radio Read meters 4 5
Areas - Read 4, 5	
Vehicles Used	

General Foreman 

Date 7-26-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 11		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 715 Ex. 7f (Water Infra.) PULL BOX,	
Job Completed	CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.) CYCLED BY-PASS PUMP AT Ex. 6 (Personal Privacy) RUNNING NOW - LEFT ON.	
Employees on Job F.P. - B.S. - K.M.	REPLACED BAD MOTOR AT BRIDGE DALE & PULLED BACK OFF PUMP & CLEANED.	
Vehicles or Equip. Used 7-14-15 - BACKHOE	Ex. 6 (Personal Privacy) PUMPED DOWN DITCHES ON BOTH ST. AT 3" PUMP - DUG SUMP HOLE TO PUMP OUT OF.	
<u>Meter Readers</u>		
Employees on Job T.C.	FINISHED 3	
Areas - Read	STARTED 4	
Vehicles Used 8		
General Foreman	Franky Pace	

Date 7-25-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

Employees on Job

F.P. G.F.
JHAR

Vehicles or Equip. Used

7-11

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
7151 **Ex. 7f (Water Infra.)** PILL BOX,
CALVIN BLVD.

Job Completed

CYCLED BLOWERS AT OAKLAND **Ex. 7f (Water Infra.)**
CYCLED BYPASS PUMP AT **Ex. 6 (Personal Privacy)**

Employees on Job

B.S. - K.M. - T.C.

CHECKED STATION'S - NEED TO PULL BACK
OFF & CLEAN OUT RAGS AT BRIDGE DALE -
NEED TO PULL & CLEAN PUMP #2 **Ex. 6 (Personal Privacy)**

Vehicles or Equip. Used

14-15

PUMPED/DIPPED OUT CANS AT BLUFF &
Ex. 7f (Water Infra.)

Meter Readers

Employees on Job

F.P.
G.H.R.FINISHED
RADIO READS

Areas - Read

Vehicles Used

7

General Foreman

Franky Pace

Date 7-24-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed	LOCATES	
Employees on Job C.F. F.P. 2 HR 2 HR		
Vehicles or Equip. Used 11 - 14		
<u>Sewer Department</u>		
Address	PUMPED DOWN SYSTEM AT Ex. 6 (Personal Privacy) SET 2" ELECTRIC BY-PASS PUMP IN WALL AT Ex. 6 (Personal Privacy) USED TO PUMP CAN DRY	
Job Completed	TURNED ON FLYING J Ex. 6 (Personal Privacy) AT END OF DAY - BOTH PUMPING TO Ex. 6 (Personal Privacy)	
Employees on Job F.P. - B.S. - T.C. - K.M. 2 HR 4 HR		
Vehicles or Equip. Used BACKHOE - 8-14-15		
<u>Meter Readers</u>		
Employees on Job T.C. - K.M. 4 HR	FINISHED 29 - PUMPED OUT VAULTS	
Areas - Read		
Vehicles Used 15		
General Foreman	Frank J. Price	

Date 7-23-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address		SERVICE TRUCK WORK ORDERS
Jobs Completed		
Employees on Job C.F.		
Vehicles or Equip. Used 11		
Sewer Department		
Address		WORKED ON FLOODED WELL & CAN AT Ex. 6 (Personal Privacy) PUMPED DOWN SYSTEM & CAN WITH 6" 3" & 2" PUMPS - WATER/SEWAGE
Job Completed		COMING INTO CAN FROM WELL WE THINK COULD NOT CONFIRM WHERE ITS COMING FROM. Ex. 6 (Personal Privacy) OFF.
Employees on Job F.P. - B.S. - K.M. - T.C. 2WK		BY-PASS PUMPED WITH 3" GAS PUMP AT 715. Ex. 7f (Water Infra.) 63RD Ex. 7f (Water Infra.)
Vehicles or Equip. Used 7-14-15- BACKHOLE-6" PUMP		CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.)
Meter Readers		
Employees on Job T.C. 6WK		FINISHED 1 & 2
Areas - Read		
Vehicles Used 8		
General Foreman <u>Frank J. Pace</u>		

Date 7-22-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

Employees on Job

C.P. - T.C.
4 PR

Vehicles or Equip. Used

8-11

Sewer Department

Address

REPAIRED HOSES FOR 3" PUMPS

Job Completed

CHECKED STATIONS - PULLED BACK OFF OF
PUMP & CLEANED OUT RAGS AT BRIDGEMAR
STATION IS OUT & CAN IS FULL OF

Employees on Job

F.P. - B.S. - K.M.
4 PRSEWAGE - WORKS ON PREPPING PUMPS
FOR BY-PASS TOMORROW

Vehicles or Equip. Used

14-15

Meter Readers

Employees on Job

T.C. - K.M.
4 PR

STARTED

29

Areas - Read

Vehicles Used

8

General Foreman

Frank J. Pace

Date 7-19-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS
LOCATED

Jobs Completed

Ex. 6 (Personal Privacy)

HOOKED UP BACKSIDE TO NEW LINE AT
LEFT METER OFF UNTIL
CUSTOMER HOOKS UP NEW LINE IN HOUSE

Employees on Job

F.P. - T.C. - G.F.
4 HR - 3 HR - 5 HRCOPPER ON MAIN SIDE (DOUBLE SET) - COPPER
TAILS OUT OF BOX TO P.V.C. AT
& GALVANIZED AT

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

11-14 - BACKHOLE

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
715 Ex. 7f (Water Infra.) PILE BOX

Job Completed

CYCLED BLOWERS AT OAKLAND

Ex. 7f (Water Infra.)

Employees on Job

T.C.
5 HR

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

G.F. - F.P.
3 HR 4 HR

FINISHED AREAS

18 - F.P. & G.F.

RADIO READS - F.P.

Areas - Read

Vehicles Used

8-14

General Foreman

Frank J. Poci

Date 7-18-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	<u>SERVICE TRUCK WORK ORDERS</u> <u>LOCATES</u>	
Jobs Completed	REPLACED BROKEN RING & LID WITH HEAVY DIAMOND SLIP LID & RING AT Ex. 6 (Personal Privacy)	
Employees on Job <u>F.P. & B.S. - G.F. - K.M.</u> <u>WHR</u>	EXPOSED COPPER TAIL COMING OUT OF BOX TO HOOK UP NEW LINE BUT CUSTOMER DIDN'T HAVE NEW LINE RAN YET. AT Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used	<u>11-14-15 - BACKHOLE</u>	
Sewer Department		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job <u>T.C. - F.P. & B.S.</u> <u>WHR</u>	FINISHED <u>19 - F.P. & B.S. - 24 - T.C.</u>	
Areas - Read		
Vehicles Used <u>8-14</u>		
General Foreman	<u>Frank J. Pace</u>	

Date 7-17-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

SERVICE TRUCK WORK ORDERS

Jobs CompletedINSTALLED R.R. METER SET BOX & BACKFILLED
AT **Ex. 6 (Personal Privacy)** LFT OFF PER HOME
OWNERS REQUEST - THEY ARE RUNNING NEW
LINE FROM HOUSE TO METER TOMORROW.**Employees on Job**C.F. - K.M.
4 HR**Vehicles or Equip. Used**

11-15

Sewer Department**Address**BY-PASS PUMPED WITH 3" GAS PUMP AT
7151 **Ex. 7f (Water Infra.)** PILE BOXCYCLED BLOWERS AT OAKLAND & **Ex. 6 (Personal Privacy)****Job Completed**JETTED LINE TO RELIEVE BACK
BORA - JETTED 6" CLEANOUT BEHIND
Ex. 6 (Personal Privacy)**Employees on Job**K.M. - E.P.-BS.-T.C.
4 HR 4 HR 2 HRPULLED BOTH PUMPS & CLEANED OUT RAGS
AT **Ex. 7f (Water Infra.)****Vehicles or Equip. Used**

15-14-9

Meter Readers**Employees on Job**T.C.
6 HRFINISHED
22-23**Areas - Read****Vehicles Used**

8

General Foreman

Frank Pace

Date 7-16-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**SERVICE TRUCK WORK ORDERS
SHUT-OFFS**Jobs Completed**PUMPED OUT BOX & FOUND LEAK ON HUB
AT **Ex. 6 (Personal Privacy)** LEDS GASKETS REPLACED**Employees on Job**F.P. - B.J. - G.F. - K.M.
G.M.R. 4HRREBUILT SERVICE FOR **Ex. 6 (Personal Privacy)** USED
ONE T.P. X 3/4" COMP. FITTING, 5' OF 3/4" COPPER
ONE WATER COUPLING - REPLACED GASKET
ON COMP. NUT FOR DOUBLE SET IN BOX.**Vehicles or Equip. Used**

NEED TO SET BOX DUE TO HEAVY RAIN

11-7-14-15

Sewer Department**Address**JACKETED LATERAL TO RELIEVE BACKUP AT
Ex. 6 (Personal Privacy) RELIEVED BACKUP &
CLEANOUT WAS DOWN**Job Completed**CHECKED BACKUP AT **Ex. 6 (Personal Privacy)** MORTAR
WAS KICKED OUT AT VIOLET **Ex. 6 (Personal Privacy)**
RESET STARTER & PUMPING NOW AT 19 AMPS**Employees on Job**F.P. - B.J. - T.C.
2HR 2HR**Vehicles or Equip. Used**

14-9

Meter Readers**Employees on Job**T.C.
G.M.R.FINISHED
80421**Areas - Read**STARTED
22**Vehicles Used**

8

General Foreman

Date 7-15-19

Daily Job Sheet

Sheet of Water DepartmentCommentsAddress

SERVICE TRUCK W.O.

FOUND LEAK ON LOWER HUB AT
Ex. 6 (Personal Privacy)Jobs CompletedCLEANED & OILED TAP MACHINE
CHANGED OIL IN BOTH 3" GAS PUMPSEmployees on JobG.F. - F.P. - B.S.
G.H.R.Vehicles or Equip. Used

11-14-7

Sewer DepartmentAddressBY-PASS PUMPED WITH 3" GAS PUMP AT
71ST
63RD
Ex. 7f (Water Infra.)
PLC BOX,
BLVD.Job Completed

CYCLED BLOWERS AT OAKLAND

Ex. 7f (Water Infra.)

Employees on Job

K.M.

CHECKED BACKUP AT
CUST. PROBLEM

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

15

Meter ReadersEmployees on JobF.P. - B.S. T.C.
J.H.R.

FINISHED

18-T.C.

MANUAL READS IN AREA 14
F.P. & B.S.Areas - ReadSTARTED
20-T.C.Vehicles Used

14-8

General Foreman

Franky Price

Date 7-12-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

Employees on Job

G.F. F.P.
GHR JHR

Vehicles or Equip. Used

11

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST Ex. 7f (Water Infra.) 712 BOX

Job Completed

CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.)

Employees on Job

K.M.
GHRCHECKED BACKUP AT Ex. 6 (Personal Privacy)
OUR LINE IS DOWN. TALKED TO
LANDLORD.

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

F.P. - K.M.
GHR JHRFINISHED
17 + RADIO READS - F.P.

Areas - Read

STARTED
12 - K.M.

Vehicles Used

8-14

General Foreman

Frank J. Pace

Date 7-11-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

SERVICE TRUCK WORK ORDERS

Jobs Completed

EXPOSED 4" C.I. MAIN, INSTALLED 4" SADDLE & 3/4" CORP. STOP, MADE WEST TAP INTO MAIN, INSTALLED 16' OF 3/4" P.V.C. TUBING,

Employees on Job

GIF - F.P. - B.S. - T.C.

ONE 18" X 30" METER SET, RADIO READ METER, 18" X 30" P.V.C. METER BOX, RING & LID BACKFILLED ROAD WITH CLEAN 1" ROCK & C-M-Φ ROCKS BACKFILLED YARD WITH DIRT SPOIL AT

Vehicles or Equip. Used

Ex. 6 (Personal Privacy) HAULED REST OF ROCK TO

11-14-G-BACKHOE

SHOP / CHECKED LEAK AT Ex. 6 (Personal Privacy) NEEDED TO CRIMP & CHANGE DOUBLES SET NO.

Sewer Department**Address****Job Completed****Employees on Job****Vehicles or Equip. Used****Meter Readers****Employees on Job**

K.M.

FINISHED
14 & 15**Areas - Read****Vehicles Used**

8

General Foreman

Frank J. Pace

Date 7-10-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

SERVICE TRUCK WORK ORDERS

Jobs Completed**Employees on Job**G.F. - K.M.
2100**Vehicles or Equip. Used**

11-15

Sewer Department**Address**CHECKED STATIONS - PULLED PUMP #2
AND CLEANED OUT MOP AT **Ex. 6 (Personal Privacy)**
PULLED BACK OFF PUMP & CLEANED OUT RAGS**Job Completed**

AT BRIDGE DALE - ALL OTHERS GOOD.

Employees on JobF.P. - B.S. - K.M.
G.M.R.BY-PASS PUMPED WITH 3" GAS PUMP AT
TIS **Ex. 7f (Water Infra.)** FILL BOX**Vehicles or Equip. Used**

14-15 - BACKHOLE

CYCLED BLOWERS AT OAKLAND **Ex. 7f (Water Infra.)****Meter Readers****Employees on Job**

T.C.

FINISHED
12413**Areas - Read****Vehicles Used**

8

General Foreman

Frank J. Pace

Date 7-9-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

SERVICE TRUCK WORK ORDERS

Jobs CompletedPULLED NEW PVC LINE UNDER ROAD
FOR **Ex. 6 (Personal Privacy)** USED 35' OF 3/4" P.V.C.
TUBING, ONE 4" FLANGE A COMP. FITTING, ONE**Employees on Job**

F.P. - B.S. - G.E. - K.M.

METER SET, ONE RE-SLITER, ONE 18" X 30"
P.V.C. METER BOX, TWO 3/4" INSERTS, BACKFILLED
WITH ROCK IN DRIVEWAY & SPOIL - P.V.C.
TUBING MAIN TO METER - COPPER ON HOUSE SIDE**Vehicles or Equip. Used**

INSTALLED RADIO READ METER

11-14-15-BACKHOLE

Sewer Department**Address****Job Completed****Employees on Job****Vehicles or Equip. Used****Meter Readers****Employees on Job**

T.C.

FINISHED
10-11-**Areas - Read**STARTED
12**Vehicles Used**

8

General Foreman

Frank J. Price

Date 7-8-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK W.D. LOOKED FOR METER BOX AT Ex. 6 (Personal Privacy) COULDN'T FIND
Jobs Completed	REPLACED SADDLE & CORP FOR PIGGOOT & INSTALLED 6" A.C. S.S. REPAIR CLAMP - USED ONE 6" A.C. S.S. CLAMP, ONE Ex. 6 (Personal Privacy)
Employees on Job F.P. - T.C. - G.P. G.P.R.	6" A.C. SADDLE, ONE 3/4" CORP STOP, ONE 3/4" X 3/4" COMP FITTING, 4' OF 3/4" COPPER TUBING, BACKFILLED WITH ONE BUCKET OF SAND FROM SHOP & SPOIL
Vehicles or Equip. Used	POT - HOLDS MAIN FOR PILOT TRUCK STOP SOUTH OF Ex. 6 (Personal Privacy)

Sewer Department

Address	PULLED BOTH PUMPS & CLEANED OUT RAGS/MOP HEADS AT Ex. 7f (Water Infra.)
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) PILL BOX, PITTSBURG Ex. 7f (Water Infra.) PLVA,
Employees on Job F.P. - T.C. G.P.R.	CYCLD BLOWERS AT OAKLAND Ex. 7f (Water Infra.)
Vehicles or Equip. Used	14-15 - BACKHOE

Meter ReadersEmployees on JobAreas - ReadVehicles Used

General Foreman

Frank J. Pace

Date 7-5-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address****Jobs Completed****Employees on Job****Vehicles or Equip. Used****Sewer Department****Address****Job Completed****Employees on Job****Vehicles or Equip. Used****Meter Readers****Employees on Job****Areas - Read****Vehicles Used****General Foreman**Frank J. Pace

Date 7-4-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address****Jobs Completed****Employees on Job****Vehicles or Equip. Used****Sewer Department****Address****Job Completed****Employees on Job****Vehicles or Equip. Used****Meter Readers****Employees on Job****Areas - Read****Vehicles Used****General Foreman**Frank J. Pace

Date 7-3-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

Employees on Job

F.P. - G.F.
4MRTOOK MAIL TO POST OFFICE
TOOK 2" PUMP TO 12-MO

Vehicles or Equip. Used

11-19

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST Ex. 7f (Water Infra.) EDNA

Job Completed

CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.)

Employees on Job

K.M.
6MR

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

T.C. F.P. - B.S. - K.M.
4MR 6MR 2MR

FINISHED

9-T.C. 7-B.S. 8-B.S. & K.M.

RADIO READS
F.P.

Areas - Read

Vehicles Used

8-7-14

General Foreman

Frank J. Pore

Date 7-2-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

SERVICE TRUCK W.O.

Jobs Completed**Employees on Job**

G.F.

Vehicles or Equip. Used

11

Sewer Department**Address**WORKED ON **Ex. 7f (Water Infra.)** TOOK
CHECK VALVE ON DISCHARGE LINE APART &
TRIED TO JET HEADER - DID NOT CLEAR LINE**Job Completed**WENT INTO WELL & CLEANED OUT SHOR
INLET & JETTED LINE - CLEARED LINE &
PUMP IS PUMPING NOW**Employees on Job**F.P. - B.S. - T.C.
GHR**Vehicles or Equip. Used**

7-14-15 BACKHOE

Meter Readers**Employees on Job**T.C. - K.M.
GHRFINISHED
G - T.C. & K.M.**Areas - Read**STARTED
7-K.M.**Vehicles Used**

8

General Foreman

Franky Pace

Date 7-1-19

Daily Job Sheet

Sheet of **Water Department****Comments****Address**

SERVICE TRUCK W/O.

Jobs Completed**Employees on Job**

G.F.

Vehicles or Equip. Used

11

Sewer Department**Address**BY-PASS PUMPED WITH 3" GAS PUMP AT
7151 Ex. 7f (Water Infra.) ALL BOX, G3RD +
Ex. 7f (Water Infra.) VD.**Job Completed**CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.)
CYCLED PUMP Ex. 7f (Water Infra.) PUMP TO PULL #1**Employees on Job**FIR - B.S. - K.M. - T.C.
JNRFOUND 5 MANHOLES BEHIND Ex. 6 (Personal Privacy)
SKIPPED LINE TO RELIEVE BACKUP CALLED
IN BY Ex. 6 (Personal Privacy)**Vehicles or Equip. Used**

14-15-9- BACKHOE

PULLED PUMP #1 Ex. 7f (Water Infra.) HEADER
IS BLOCKED + NEEDS WORKED ON**Meter Readers****Employees on Job**GDR
T.C.FINISHED
5**Areas - Read**STARTED
6**Vehicles Used**

8

General Foreman

Frank J. Pace

Date 8-30-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 3		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 7151 Ex. 7f (Water Infra.) ALL BOX	
Job Completed	CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.) CYCLED PUMPS AT Ex. 7f (Water Infra.) 53RD, 53RD OFF Ex. 6 (Personal Privacy) FOR WEEKEND	
Employees on Job T.C. 4 HR		
Vehicles or Equip. Used 5		
<u>Meter Readers</u>		
Employees on Job F.P. - T.C.	FINISHED 9 - F.P. & T.C. RADIO READS - F.P.	
Areas - Read	STARTED 10 - T.C.	
Vehicles Used 1-4		
General Foreman	Frank J. Rice	

Date 8-29-19

Daily Job Sheet

Sheet of

Water Department	Comments
Address	SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed	RAKED OUT YARD WHERE HYDRANT WAS REPAIRED AT Ex. 6 (Personal Privacy)
Employees on Job F.P. - G.F. - K.M. DHR	
Vehicles or Equip. Used 1-3	


Sewer Department	
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 63RD Ex. 7f (Water Infra.) BEVO
Job Completed	VACUMED OUT MANHOLE AT AMES TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy) Ex. 6 (Personal Privacy)
Employees on Job F.P. - B.S. - K.M. - T.C. 4HR 6HR 8HR	CYCLING BLOWERS AT OAKLAND Ex. 7f (Water Infra.) CYCLING PUMPS AT Ex. 6 (Personal Privacy) 53RD ALL OFF NOW
Vehicles or Equip. Used 14-5-9	

Meter Readers	
Employees on Job F.P. - T.C. 2HR 6HR	FINISHED 8 - F.P. & T.C.
Areas - Read	STARTED 9 - T.C.
Vehicles Used 1-4	
General Foreman <u>Frank Pace</u>	

Date 8-28-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address	W.O. / Locates	
Jobs Completed		
Employees on Job	G.F.	
Vehicles or Equip. Used	3	
Sewer Department		
Address	Bypass pumped 71 st Cycle Ex. 6 (Personal Privacy) rockett, oakland and 53 rd stations	
Job Completed	Installed box pump into checked stations Ex. 6 (Personal Privacy)	
Employees on Job	B.S. - K.M.	
Vehicles or Equip. Used	Backhoe, 5, 2	
Meter Readers		
Employees on Job	Started/finished/Started T.C. 6 / 7	
Areas - Read	6, 7	
Vehicles Used	4	
General Foreman		

Date 8-07-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK W.O. LOCATES	
Jobs Completed	CUT LOCK PINS OFF AT Ex. 6 (Personal Privacy) ON DORIS Ex. 6 (Personal Privacy)	
Employees on Job F.P. G.F. JHR	DUG UP BOX BURIED BY SILT FROM PUMP DUE TO FLOODING AT Ex. 6 (Personal Privacy) SHOT METER OFF	
Vehicles or Equip. Used	3-14	
Sewer Department		
Address	BY-PASS PUMPED WITH 3" PUMP & WORKED ON ELECTRIC AT FIELD FROM Ex. 6 (Personal Privacy) FITTED UP NEW PUMP	
Job Completed	CYCLED 53RD Ex. 7f (Water Infra.) HAND CYCLED Ex. 6 (Personal Privacy)	
Employees on Job F.P.-B.S. - K.M. GHR	PUMPED DOWN CAN WITH SUMP PUMP AT Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used	PUMP #2 NOT PUMPING AT Ex. 7f (Water Infra.) PUMP #1 ON AUTO - ELECTRICAL PROBLEM SHOCKING MEN WHEN TOUCHING DOOR TO BOX	
Meter Readers		
Employees on Job T.C.	FINISHED 5	
Areas - Read	STARTED 6	
Vehicles Used 4		
General Foreman	Frank J. Pace	

Date 8-26-19

Daily Job Sheet

Sheet ____ of ____

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATES	
Jobs Completed	HOOKED UP BACKSIDE AT Ex. 6 (Personal Privacy) USED ONE 3/4" X 3/4" COMP. FITTING, ONE WATER COUPLING, ONE 18" X 30" P.V.C. WATER BOX & 4" OF 3/4" COPPER - BACKFILLED WITH SPOIL	
Employees on Job	G.F. - F.P. - B.S. 6HR 4HR	
Vehicles or Equip. Used	3-14-BACKHOLE-1	
Sewer Department		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 7157 Ex. 7f (Water Infra.) PILL BOX, & IN FIELD FROM Ex. 6 (Personal Privacy)	
Job Completed	PULLED PUMP FROM FIELD FROM Ex. 6 (Personal Privacy) PUMP & RECEPTACLE WAS BURNED UP - REMOVED FROM POWER SOURCE AT LAUREL	
Employees on Job	NEEDS NEW PUMP & RECEPTACLE K.M. - B.S. - F.P. 4HR 2HR PULLED & CLEANED TRANSDUCER AT 53RD & Ex. 7f (Water Infra.) NOT PUMP ON AUTO - PUMPS ON HAND	
Vehicles or Equip. Used	CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.) CYCLED PUMP AT Ex. 6 (Personal Privacy) 53RD.	
Meter Readers		
Employees on Job	T.C. FINISHED 304	
Areas - Read	STARTED 5	
Vehicles Used	4	
General Foreman		

Date 8-23-19

Daily Job Sheet

Sheet ____ of ____

Water DepartmentComments

Address	W.D. Locates Water
Jobs Completed	
Employees on Job	
GF	
Vehicles or Equip. Used	
3	

Sewer Department

Address	Bypass pumped 71 st Ex. 7f (Water Infra.) Check Stations
Job Completed	Cycled Oakland Ex. 7f (Water Infra.)
Employees on Job	
B.S., K.M.	
Vehicles or Equip. Used	
2, 5	

Meter ReadersEmployees on Job

BS

Radio Reads

Areas - ReadVehicles Used

2

General Foreman

Date 8-21-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

fixed fire hydrant leak @ the corner of Donald
Ex. 6 (Personal Privacy) used 4" ac clamp to repair.

W.O. / Locates

Jobs Completed

Employees on Job

G.F., T.C (4), B.S.

Vehicles or Equip. Used

Backhoe, 15, 14, 2, 3, 4

Sewer Department

Address

Took vactruck to dump + clean

Bypass 7st, cycled crockett, oakland
stations

Ex. 6 (Personal Privacy)

Job Completed

Employees on Job

KM, T.C (1)

Vehicles or Equip. Used

Vactruck, 5

Meter Readers

Employees on Job

T.C (3)

Started + Finished


23

Areas - Read

Vehicles Used

4

General Foreman



Date 8-20-19

Daily Job Sheet

Sheet ____ of ____

<u>Water Department</u>		Comments
Address	w.o. / Locates	
Jobs Completed		
Employees on Job	GF ⁽¹²⁾ , BS ⁽²⁾	
Vehicles or Equip. Used	2, 3	
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job	<u>Started & Finished</u> B.S(6), G.F(6) TC, KM 19, 20, 21, 22, 24, 26	
Areas - Read	19, 20,	
Vehicles Used	2, 3, 4, 15	
General Foreman	K. McCall	

Date 8-19-19

Daily Job Sheet

Sheet ____ of ____

Water Department

Comments

Address

W.O.

Repaired yard

Ex. 6 (Personal Privacy)

Jobs Completed

Employees on Job

B.S., T.C., G.F.

Vehicles or Equip. Used

Backhoe, 14, 3

Sewer Department

Address

Bypass pumped 71st, Bluff

Cycled many man, climb

Ex. 7f (Water Infra.)

Job Completed

Check Stations

Employees on Job

KM, BS, TC

Vehicles or Equip. Used

15


Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman



Date 8-16-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK W.O.	
Jobs Completed	RAISED METER BOX WITH 7" CLAY RISER CUT AT SHOP AT Ex. 6 (Personal Privacy)	
Employees on Job G.F. T.C. 2HR		
Vehicles or Equip. Used 3-14		
Sewer Department		
Address	BY-PASS PUMPER WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) - PITTSBURGH	
Job Completed	CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.) CYCLED BY-PASS PUMP AT Ex. 6 (Personal Privacy)	
Employees on Job K.M. F.P. - T.C. 4HR 2HR	CHANGED OIL IN BLOWERS AT OAKLAND Ex. 6 (Personal Privacy) INSTALLED NEW HOSE ON BLOWER AT CROCKETTS	
Vehicles or Equip. Used	INSTALLED SUMP PUMP AT SUPERIOR	
Meter Readers		
Employees on Job T.C. F.P. 4HR 4HR	FINISHED CYCLE 5 RADIO READS F.P. / 26 + 22 F.O.W. T.C.	
Areas - Read		
Vehicles Used 1 & 4		
General Foreman <u>Frank J. Pace</u>		

Date 8-15-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATAS	
Jobs Completed	REBUILT BACKSIDE AT Ex. 6 (Personal Privacy) USED ONE $\frac{3}{4}$ " X $\frac{3}{4}$ " COMP. FITTING, ONE METAL COUPLING & 12" OF COPPER TUBING	
Employees on Job G.F. - F.P. 4HR		
Vehicles or Equip. Used 1-3		
Sewer Department		
Address	BY-PASS PUMPED WITH 5" GAS PUMP AT 7157 Ex. 7f (Water Infra.) PILL BOX; PITTSBURG Ex. 7f (Water Infra.)	
Job Completed	CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.) CYCLED BY-PASS PUMP AT Ex. 6 (Personal Privacy)	
Employees on Job F.P. - K.M. 4HR	REPLACED PUMP AT Ex. 7f (Water Infra.) BROUGHT BAD PUMP TO SHOP & CLEANED	
Vehicles or Equip. Used 1-14-15	CHECKED STATIONS - NEEDED TO REPLACE HOSE ON BLOWER AT CROCKETTS	
Meter Readers		
Employees on Job T.C.	FINISHED 2342H	
Areas - Read	STARTED 86	
Vehicles Used 41		
General Foreman	Frank J. Pace	

Date 8-14-19

Daily Job Sheet

Sheet ___ of ___

Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F.	
Vehicles or Equip. Used 3	

Sewer Department

Address	REPLACED BAD MOTOR AT Ex. 7f (Water Infra.) FRONT - ALL STATIONS ON NOW & PUMPING
Job Completed	CYCLED Ex. 6 (Personal Privacy) INSTALLED SUMP PUMP AT SUPERIOR
Employees on Job F.P. - K.M.	
Vehicles or Equip. Used 14-15	

Meter Readers

Employees on Job T.C.	FINISHED 21922
Areas - Read	
Vehicles Used 4	

General Foreman Frank J. Ball

Date 8-14-19

Daily Job Sheet

Sheet ____ of ____

Water DepartmentComments

Address	$\frac{1}{2}$ HOUR OVERTIME
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

Sewer Department

Address	PUMPED OUT CAN WITH 3" GAS PUMPER INSTALLED SUMP PUMP AT SUPERIOR
Job Completed	
Employees on Job F.P. - K.M.	
Vehicles or Equip. Used 14-15	

Meter ReadersEmployees on JobAreas - ReadVehicles UsedGeneral Foreman Frank J. Pace

Date 8-13-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK W.O. LOCATES
Jobs Completed	
Employees on Job F.P. - G.F. 2HR 8HR	
Vehicles or Equip. Used 1-3	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) L BOX, CALVIN
Job Completed	CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.) CYCLED PUMP AT Ex. 6 (Personal Privacy)
Employees on Job F.P. - T.C. - K.M. 6HR 2HR 8HR	PULLED BACK OFF PUMP #2 & CLEANED OUT RAGS AT SUPERIOR - PUMPING & CYCLING NOW CHECKED STATIONS & NEED SUMP PUMP AT SUPERIOR
Vehicles or Equip. Used 1-14-15	CHECKED MOTOR ON PUMP #1 AT Ex. 7f (Water Infra.) FRONT - MOTOR IS MAKING VERY LOUD NOISE & NEEDS REPLACED.

Meter Readers

Employees on Job T.C. 6HR	FINISHED 20
Areas - Read	STARTED 21
Vehicles Used 4	

General Foreman

Frank J. Pace

Date 8-12-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address	2 NR. CALL OUT - OVERTIME
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

Sewer Department

Address	CALL OUT TO SUPERIOR - PUMP #2 WAS STARTER KICKED OUT - RESET BUT IT KICKED OUT AGAIN AFTER
Job Completed	5 MINUTES OR LESS - RUNNING ON PUMP 1 ONLY NOW - NEED TO PULL BACK OFF PUMP 2 & CHECK.
Employees on Job F.P.	
Vehicles or Equip. Used 14	

Meter ReadersEmployees on JobAreas - ReadVehicles Used

General Foreman

Frank J. Pace

Date 8-12-19

Daily Job Sheet

Sheet ____ of ____

Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed	MOVED TRUCKS, CLEANED UP SCRAP HYDRANTS IN SHOP
Employees on Job G.F. - F.P. - T.C. GHR 3MR	GRADED ROCK IN ROAD WHERE MAIN BREAK WAS REPAIRED AT Ex. 6 (Personal Privacy)
Vehicles or Equip. Used	
3-1-BACKHOLE	

Sewer DepartmentAddress

CHECKED STATIONS

Job CompletedPULLED BY-PASS PUMP AT Ex. 6 (Personal Privacy)
& CLEANED OUT RAGS/ PLASTIC TOY
PUMPING NOWEmployees on JobK.M. F.P. - T.C.
5MR 2MR 2MRVehicles or Equip. Used

15-14-BACKHOB,

Meter ReadersEmployees on JobT.C. - K.M.
5MRFINISHED
19Areas - ReadVehicles Used

4

General Foreman

Franky Pace

Date 8-9-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATES	
Jobs Completed	HAULED IN DEBT & ROCK TO REPAIR YARD AT Ex. 6 (Personal Privacy) DRIVEWAY AT Ex. 6 (Personal Privacy) HARE PULL WAS MADE - GRADED & SEEDDED YARD	
Employees on Job	G.F. - F.P. - B.S. - T.C. 4 HR 2 HR	
Vehicles or Equip. Used	1-9-14 - BACKHOE - G	
Sewer Department		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 7157 Ex. 7f (Water Infra.) PILL BOX, BLUFF Ex. 7f (Water Infra.)	
Job Completed	CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.) CYCLED PUMP AT Ex. 6 (Personal Privacy) LEFT ON FOR WEEKEND	
Employees on Job	PULLED BOTH PUMPS AT Ex. 7f (Water Infra.) CLEANED OUT RACS - PUMPING & CYCLING NOW	
Vehicles or Equip. Used	PULLED PUMP AT Ex. 6 (Personal Privacy) CLEANED OUT RACS & PIECE OF WOODEN LATH - PUMPING & CYCLING NOW	
Meter Readers		
Employees on Job	F.P. FINISHED RADIO READ METERS	
Areas - Read		
Vehicles Used	1	
General Foreman	Frank J. Pace	

Date 8-8-19

Daily Job Sheet

Sheet of

Water Department	Comments
Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	REPLACED HYDRANT AT FALLING SPRINGS & Ex. 7f (Water Infra.) ED ONE 6" MICA-LUG FLANGE, ONE 6" T-BOLTS, BACKFILLED WITH ONE BUCKET CLEAN ROCK & SPOIL
Employees on Job F.P. - B.S. - G.F. - K.M. GHR	EXPLORED AREA AROUND HYDRANT & FOUND A 12" VALVE WITH TRACER WIRE 9' 5" E, S.E. OF HYDRANT - DON'T KNOW HOW ITS TAPPED OR WHAT LEADS TO HYDRANT - NEED TO EXPLORE MORE
Vehicles or Equip. Used 3-14-15-BACKHOLE	OR TRACE LINK WITH LOCATOR

Sewer Department	
Address	CHECKED BACKUPS A Ex. 6 (Personal Privacy) Ex. 6 (Personal Privacy) BOTH CUSTOMERS PROBLEMS CHECKED SOME STATIONS -
Job Completed	CYCLED Ex. 6 (Personal Privacy)
Employees on Job T.C. - K.M. GHR	
Vehicles or Equip. Used 4	

Meter Readers	
Employees on Job T.C. GHR	FINISHED 18
Areas - Read	
Vehicles Used 4	
General Foreman <u>Franky. Pace</u>	

Date 8-7-19

Daily Job Sheet

Sheet ___ of ___

Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

PUSHED BRUSH PILE OUT OF WAY, FOUND
BRANCH VALVE, BROUGHT BROKEN HYDRANT
AT JUDITH **Ex. 6 (Personal Privacy)** TO SHOP

Employees on Job

GIF - F.P.-B.S.
1 PR

Vehicles or Equip. Used

3-14-BACKHOE

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST **Ex. 7f (Water Infra.)** ALL BOX, CALVIN BLVD,
BLVD **Ex. 7f (Water Infra.)**

Job Completed

CYCLED BLOWERS AT OAKLAND **Ex. 7f (Water Infra.)**
CYCLED PUMP AT **Ex. 6 (Personal Privacy)**

Employees on Job

K.M. - F.P.-B.S.
7 PRPULLED NEW FLOAT BALLS & WIRED IN AT
VIOLET **Ex. 7f (Water Infra.)** CYCLING NOW

Vehicles or Equip. Used

14-15-BACKHOE

PULLED PUMP & REPLACED FLOAT BALL AT
Ex. 6 (Personal Privacy)
PULLED PUMP & CLEANED OUT RAGS AT
Ex. 6 (Personal Privacy)

Meter Readers

Employees on Job

T.C.

FINISHED
15417

Areas - Read

Vehicles Used

4

General Foreman

Frank J. Rose

Date 8-6-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F.	
Vehicles or Equip. Used 3	

Sewer Department

Address	BY-PASS PUMPED AT 82ND CYCLED PUMP AT Ex. 6 (Personal Privacy) Ex. 7f (Water Infra.)
Job Completed	REPLACED PUMP AND DISCHARGE LINE AT Ex. 7f (Water Infra.) VIOLET WETWELL ~ NEEDED TO REPLACE FLOAT BALLS - WON'T SHUT OFF
Employees on Job F.P. - B.S. - K.M. G.M.	PULLED PUMP & CRAWLED OUT RAGS AT Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 1-14-15 - BACKHOE	<u>LOCATES</u> TOOK PUMP TO 12 MB FROM VIOLET & Ex. 7f (Water Infra.)

Meter Readers

Employees on Job T.C.	FINISHED 13 + 14
Areas - Read	STARTED 15 TOOK MAIL TO POST OFFICE
Vehicles Used 4	

General Foreman

Frank J. Pace

Date 8-5-19

Daily Job Sheet

Sheet ____ of ____

Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

Employees on Job

G.F.

Vehicles or Equip. Used

3

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
7157 **Ex. 7f (Water Infra.)** + 88ND

Job Completed

CYCLED BLOWERS AT OAKLAND
CYCLED PUMP AT**Ex. 7f (Water Infra.)****Ex. 6 (Personal Privacy)**

Employees on Job

B.S. - K.M.
4HRCHECKED STATIONS - NEED TO PULL PUMPS
AT **Ex. 7f (Water Infra.)** VIOLAT.**Ex. 7f (Water Infra.)**

Vehicles or Equip. Used

2 - 15

Meter Readers

Employees on Job

F.P

FINISHED
11 & 12

Areas - Read

STARTED
13

Vehicles Used

1

General Foreman

Frank Pace

Date 8-2-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS
MKT WITH PLUMBER ON LOVES JOB &
DRBW UP TAP, VALVE & FITTINGS FOR SERVICE

Jobs Completed

LOCATES

Employees on Job

F.P.-B.S. - T.C.
GARR

Vehicles or Equip. Used

7-14-BACKHOP

Sewer Department

Address

BY-PASS PUMPED WITH 2" GAS PUMP AT
715. [REDACTED] PIPE BOX,

Job Completed

CYCLED BLOWERS AT OAKLAND [REDACTED] Ex. 7f (Water Infra.)

Employees on Job

K.M.

Vehicles or Equip. Used

15

Meter Readers

Employees on Job

T.C

FINISHED
10

Areas - Read

Vehicles Used

General Foreman

Frank J. Ponce

Date 8-1-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	Hauled in dirt, raked out dirt, seeded & strawed yard where repair was made at Ex. 6 (Personal Privacy)
Employees on Job K.M. <u>F.P.-B.S.</u> 2 HR	
Vehicles or Equip. Used BACKHOLE-11-14	

Sewer DepartmentAddressHOOKED UP SEWER LATERAL AT **Ex. 6 (Personal Privacy)**
USED ONE 4" SCH 40 X 4" SCH 35 COUPLING, ONE
4" X 4" SCH 35 COUPLING, 100' OF SCH 35 PIPE,Job CompletedTWO 4" SCH 35 STRAIGHT ELS; GROUTED LINE
INTO VERTICAL CLAY RISER & USED 1 BAG
OF QUICK CRTE AROUND COUPLINGS - BACKFILLEDEmployees on JobF.P.-B.S.
6 HRWITH ONE BUCKET OF CLEAN ROCK & SPOIL.
NEED TO GO BACK & GRADE ALLEY AFTER
GROUND SETTLES.Vehicles or Equip. Used

14 - BACKHOLE

CYCLED OAKLAND, **Ex. 6 (Personal Privacy)**
CHECKED PING PONG - BELLEVUE STILL UP
BUT CATCHING UP SLOWLYMeter ReadersEmployees on Job

T.C.

FINISHED
8 & 9Areas - ReadVehicles Used

8

General ForemanFrank J. Pace

Date 9-30-19

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	TOOK UNIT 14 TO ALLTYPE AUTO FOR BATTERY
Employees on Job T.C. - B.S. GAR GAR	
Vehicles or Equip. Used 2-4	

Sewer Department

Address

LOCATED MANHOLDS & JETTED MAIN LINE AND LATERAL TO RELIEVE BACKUP AT

Ex. 6 (Personal Privacy)

Job Completed

CHECKED STATIONS - DISCHARGE LINE AT SNOWS IS BROKEN - MAY HAVE BEEN HIT BY MOWER.

Employees on Job

T.C. - F.P. - B.S.
GAR GAR

CLEANED SUMP PUMP AT FRONT - PUMPING NOW.

Ex. 7f (Water Infra.)

Vehicles or Equip. Used

9-1-2

CYCLES 53 **Ex. 6 (Personal Privacy)** KLANA, CROCKETS

BY-PASS PUMPED WITH 3" GAS PUMP AT

715 **Ex. 7f (Water Infra.)** TELL BOX,63R **Ex. 7f (Water Infra.)** LVS,

Meter Readers

Employees on Job

F.P.
GAR

FINISHED

CYCLE 3 RADIO READS

Areas - Read

Vehicles Used

1

General Foreman

Frank J. Price

Date 9-27-19

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS CHECKED LEAK AT Ex. 6 (Personal Privacy) WATER RUNNING OUT OF BUILDING CUSTOMER PROBLEM
Jobs Completed	WORKED WITH BORING CREW IN SAUGET IND. TO LOCATE OUR WATER MAIN.
Employees on Job F.P. - B.S.	
Vehicles or Equip. Used 1-4-14	

Sewer Department

Address	BY-PASS PUMPED WITH 5" GAS PUMP AT 71ST Ex. 7f (Water Infra.) PILL BOX
Job Completed	CYCLRD BLOWERS AT OAKLAND Ex. 7f (Water Infra.) CYCLRD PUMPS AT Ex. 6 (Personal Privacy)
Employees on Job K.M.	
Vehicles or Equip. Used 5	

Meter Readers

Employees on Job T.C.	FINISHED 9 & 10
--------------------------	--------------------

Areas - Read

Vehicles Used 4	
--------------------	--

General Foreman	Frank J. Pace
-----------------	---------------

Date 9-26-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed	SHUT OFF SERVICE AT MAIN FOR WHAT WE BELIEVE 1 Ex. 6 (Personal Privacy) AT CORP. STOP	
Employees on Job G.F. - F.P. - B.S. - K.M. 4HR	SHUT OFF SERVICE FOR VACANT HOUSE AT Ex. 6 (Personal Privacy) STOP ON MAIN.	
Vehicles or Equip. Used 3-14-5-BACKHOL	REPAIRED YARD WHERE MAIN BREAKS WERE REPAIRED A Ex. 6 (Personal Privacy) CORNER OF NELSON Ex. 6 (Personal Privacy)	

Sewer Department

Address	Bypass pumped 82 nd Ex. 7f (Water Infra.) Cycle Ex. 6 (Personal Privacy) 53RD	
Job Completed		
Employees on Job 4HR K.M.		
Vehicles or Equip. Used 5		

Meter Readers

Employees on Job T.C.	<u>started</u> 5, 6, 9	<u>Finished</u> 5, 6
Areas - Read 5, 6, 9		
Vehicles Used 4		

General Foreman

Frank J. Pace

Date 9-25-19

Daily Job Sheet

Sheet ____ of ____

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS WORKED WITH BORING CREW IN SAUGET IND. MET WITH CONTRACTOR AT 75TH	
Jobs Completed	EXPOSED 6" A.C. MAIN & FOUND TAP FOR	
Employees on Job	G.I.F. - F.P. - B.S.	
Vehicles or Equip. Used	3-14- BACKHOE	
Sewer Department		
Address	WORKED WITH VILLAGE OF CAHOKIA SETTING LINE IN	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST	
Employees on Job	K.M. T.C. 2HR	
Vehicles or Equip. Used	5- 9	
Meter Readers	FINISHED 4	
Areas - Read	STARTED 5	
Vehicles Used	4	
General Foreman	Frank J. Pace	

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Ex. 7f (Water Infra.)

Ex. 7f (Water Infra.)

Date 9-24-19

Daily Job Sheet

Sheet of

<u>Water Department</u>	<u>Comments</u>
Address	W.O. / Locates
Jobs Completed	
Employees on Job	
B.S., GF	
Vehicles or Equip. Used	
2, 3	


Sewer Department

Address	Bypass pumped; Calvin, Pittsburg, Bluff cycled Ex. 6 (Personal Privacy) 53rd stations
Job Completed	
Employees on Job	
KM	
Vehicles or Equip. Used	
5	

Meter Readers

Employees on Job	<u>Finished</u>	<u>started</u>
F.O.P., T.C., B.S.	7, 8, 3	4, 9
Areas - Read		
3, 4, 7, 8, 9		
Vehicles Used		
1, 2, 4		

General Foreman



Date 9-20-19

Daily Job Sheet

Sheet ___ of ___

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
LOCATED

Jobs Completed

HAULED IN TWO BUCKETS OF DIRT FROM SHOP
GRADED DIRT & REPLACED FENCE WHERE LEAK
WAS REPAIRED AT Ex. 6 (Personal Privacy)

Employees on Job

F.P. - G.F. - K.M.
4 HR 2 HR

Vehicles or Equip. Used

1-3-14

Sewer Department

Address

BY-PASS DUMPED WITH 3" GAS PUMP AT
71ST Ex. 7f (Water Infra.) PILL BOX,
83

Job Completed

CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.)
CYCLED PUMPS AT Ex. 6 (Personal Privacy) 3 RD.

Employees on Job

K.M.
6 HR

Vehicles or Equip. Used

5

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 9-23-19

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job C.F.	
Vehicles or Equip. Used 3	

Sewer Department

Address	BY-PASS PUMPED WITH 3" PUMP AT 71ST Ex. 7f (Water Infra.) RILL BOX
Job Completed	CYCLAD BLOWERS AT OAKLAND Ex. 7f (Water Infra.) CYCLAD PUMPS AT Ex. 6 (Personal Privacy) JRD
Employees on Job F.P. - B.S. - T.C. - K.M.	DUG OFF LTD, VACUMED OFF SOLIDS, CHIPPED OUT GROUT AROUND EDUCTOR DISCHARGE LINE, TOOK CLAMP OFF OF AIR LINE, AND
Vehicles or Equip. Used 4-5-9-14 - BACKHOL	REMOVED EDUCTOR FROM DISCHARGE LINE IN PREP FOR BY-PASS PUMP INSTALLATION. AT Ex. 7f (Water Infra.)

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 9-21-19

Daily Job Sheet

Sheet ____ of ____

Water Department

Comments

Address	2 HR D.T. CALL OUT
Jobs Completed	CHECKED ON CALL ABOUT A MAIN BEING HIT BY CONTRACTOR - IT WAS A STORM SEWER THAT WAS HIT AT
Employees on Job K.M.	Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 14	

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 9-19-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed	LOCATES	
Employees on Job G.F. - F.P. IMR		
Vehicles or Equip. Used 1-3		
<u>Sewer Department</u>		
Address	CYCLER PUMPS A Ex. 6 (Personal Privacy) 53RD.	
Job Completed		
Employees on Job F.P. IMR		
Vehicles or Equip. Used 1		
<u>Meter Readers</u>		
Employees on Job F.P. - T.C. - K.M. G.M.R. 4MR	FINISHED AREA 30 - T.C. & K.M.	CYCLE 2 RADIO READS F.P.
Areas - Read		
Vehicles Used 1-4		
General Foreman		

Date 9-18-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS
LOCATHS

Jobs Completed

REBUILT SERVICE AT **Ex. 6 (Personal Privacy)**
ONE 3/4" P.V.C. BARB X COMP. FITTING, ONE 3/4" X 3/4"
COMP. FITTING, ONE METER SHUT OFF, ONE METER COUPLING,
10' OF 3/4" COPPER TUBING, RE-USED CLAY

Employees on Job

F.A. - T.C. - G.F.
GMRMETER BOX, BACKFILLED WITH ONE BUCKET
SAND & SPOIL - INSTALLED RADIO READ METER

Vehicles or Equip. Used

3-1-14-BACKHOL

Sewer Department

Address

PULLED BACK OFF PUMP & CLEANED OUT RAGS
AT BRIDGE DALE **Ex. 7f (Water Infra.)** PULLED OUT
RAGS

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST **Ex. 7f (Water Infra.)** PILL BOX, CALVINI
634

Employees on Job

K.M. - F.P. - T.C.
JMRCYCLED BLOWERS AT OAKLAND **Ex. 7f (Water Infra.)**
CYCLED PUMPS AT **Ex. 6 (Personal Privacy)** 53RD

Vehicles or Equip. Used

5-14

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Date 9-17-19

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	REPAIRED SERVICE LEAK AT USED ONE $\frac{3}{4}$ " X $\frac{3}{4}$ " COMP. FITTING, ON WATER COUPLING & 6' OF $\frac{3}{4}$ " COPPER TUBING
Employees on Job G.F. - F.P. - T.C. - K.M.	NEED TO PUT FENCE BACK WHEN IT DRIES UP AND GRADE YARD.
Vehicles or Equip. Used	
3-5-14-BACKHOLE	

Ex. 6 (Personal Privacy)

Sewer Department

Address	CYCLED PUMPS A. Ex. 6 (Personal Privacy) - 53RD.
Job Completed	NEED 23 $\frac{1}{2}$ " SEWER LID AT 71ST PIG BOX WRT WELL - LID THERE IS TOO SMALL
Employees on Job	
Vehicles or Equip. Used	

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 9-16-19

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

Employees on Job

C.F.

Vehicles or Equip. Used

3

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST **Ex. 7f (Water Infra.)** PILL BOX

Job Completed

CYCLED BLOWERS
CYCLED PUMPS AT**Ex. 7f (Water Infra.)**

Employees on Job

F.P. - T.C. - K.M.

PULLED PUMPS AT **Ex. 7f (Water Infra.)** CLEANED
PULLED PUMP AT **Ex. 7f (Water Infra.)** + CLEANED
CLEANED WEEDS AROUND DISCHARGE M.H. AT 75TH

Vehicles or Equip. Used

5-14- BACKHOC

CHECKED STATIONS - ALL GOOD

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 9-13-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS

MISC. WORK ORDERS

Jobs Completed

FLUSHED WATER MAIN ON WHITE ST.

Employees on Job

F.P. - G.F. - T.C.
3 HR 6 HR

Vehicles or Equip. Used

1-3-4

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
7151 Ex. 7f (Water Infra.) RILL BOX

Job Completed

CYCLED BLOWERS
CYCLED PUMPS AT

Ex. 7f (Water Infra.)

Employees on Job

K.M.

53RD OFF

Vehicles or Equip. Used

5

Meter Readers

Employees on Job

F.P. - T.C.
5 HR 2 HR

FINISHED

19-F.P. & T.C.

CYCLE 5
RADIO READS F.P.

Areas - Read

Vehicles Used

1-4

General Foreman

Frank J. Pace

Date 9-12-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS LOCATED FOR PASS COM BORING
Jobs Completed	REPLACE GASKETS ON RA-SETTER TO STOP LEAK IN BOX AT Ex. 6 (Personal Privacy)
Employees on Job F.P. - B.S. - G.F. - K.M.	REPAIRED 2" C.I. MAIN BREAK AT Ex. 6 (Personal Privacy) USED ONE 2" C.I. S.S. REPAIR CLAMP - NEEDED ROCK IN ROAD
Vehicles or Equip. Used 3-5-14 - BACKHOE	CLEANED UP MUD ON WHALEN LOCATED FLUSHING HYDRANT ON WHITE

Sewer Department

Address	
Job Completed	CYCLED Ex. 6 (Personal Privacy) 3RD
Employees on Job	
Vehicles or Equip. Used	

Meter ReadersEmployees on Job

T.C.

FINISHED

24 & 26

Areas - ReadVehicles Used

4

General Foreman

Frank J. Price

Date 9-11-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

PUMPED OUT DITCHES, EXPOSED 2" C.I.
MAIN TO LOCATE LEAK. REPAIRED LEAK
WITH ONE 2" C.I. S.S. REPAIR CLAMP.
BACKFILLED WITH ROCK FROM SHOP & SPOIL -

Employees on Job

F.P. - B.S. - C.F. - K.M.
4 HR

NEED TO HAUL OFF SPOIL LEFT ON SITE. AT

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

1-14-5-3 BACKHOLE

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST **Ex. 7f (Water Infra.)** FILL BOX

Job Completed

CYCLED BLOWERS
CYCLED PUMPS AT**Ex. 7f (Water Infra.)**

Employees on Job

K.M.
4 HR

Vehicles or Equip. Used

5

Meter Readers

Employees on Job

T.C.

FINISHED
22 * 23

Areas - Read

Vehicles Used

4

General Foreman

Frank J. Pace

Date 9-10-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

LOOKED FOR LEAK ON BELLEVUE BETWEEN
CHURCH RD **Ex. 6 (Personal Privacy)** IMPROVED DITCHES & SCRAPPED
OUT MUD IN DITCH BUT COULDN'T FIND LEAK

Employees on Job

F.P. - B.S. - K.M. - G.P.
5HR 4HRCYCLES **Ex. 6 (Personal Privacy)** 3RD STATIONS

Vehicles or Equip. Used

1-3-5-14-BACKHOLE

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

F.P. - T.C.
3HR

FINISHED

20421 - T.C.

RADIO READS - F.P.

Areas - Read

STARTED

22 - T.C.

Vehicles Used

1-4

General Foreman

Franky Rice

Date 9-9-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

REPAIRED MAIN BREAK AT
USED ONE 4" A.C. S.S. REPAIR CLAMP, BACKFILL
WITH ONE BUCKET OF SAND FROM SHOP & SPILL

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - B.S. - T.C. - G.F.
4 MC

Vehicles or Equip. Used

3-4-14-BACKHOC

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST
63RD
PILL BOX,
BLVD.

Ex. 7f (Water Infra.)

Job Completed

CYCLRO BLOWERS
CYCLRO PUMPS AT

Ex. 7f (Water Infra.)

Employees on Job

K.M.

Vehicles or Equip. Used

5

Meter Readers

Employees on Job T.C.

FINISHED
AREA 18

Areas - Read

Vehicles Used

4

General Foreman

Frank J. Pace

Date 9-6-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed	LOCATES FOR PASS COM BORING	
Employees on Job G.F. - K.M. - <u>F.P.-B.S.</u> 4HR 4HR 2HR		
Vehicles or Equip. Used		
3-5-14		
Sewer Department		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) RILL BOX	
Job Completed	CYCLED BLOWERS AT Ex. 7f (Water Infra.) CYCLED PUMPS AT Ex. 6 (Personal Privacy) 53RD OFF	
Employees on Job K.M. - <u>F.P.-B.S.</u> T.C. Ex. 6 (Personal Privacy) 4HR 6HR 8HR Ex. 6 (Personal Privacy)	LOCATED MANHOLLS BETWEEN LOUISE & Ex. 6 (Personal Privacy) LINDA CINE TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy) JETTED TWO	
Vehicles or Equip. Used	MANHOLLS TO GET THROUGH BLOCK.	
5-14-9-BACKHOR		
Meter Readers		
Employees on Job T.C. 6HR	FINISHED 17	
Areas - Read	STARTED 18	
Vehicles Used 4		
General Foreman <u>Franky Price</u>		

Date 9-5-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed	LOCATED LINES ALONG OLD MO. FOR PASS COM BORING	
Employees on Job F.P. - B.S. - G.F.	WORKED WITH PASS COM BORING TO LOCATE OUR 8" A.C. MAIN AT BOND & Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used	3-14 - BACKHOLE	
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) FILL BOX, GSRD & Ex. 6 (Personal Privacy)	
Job Completed	CYCLED BLOWERS AT OAKLAND & Ex. 7f (Water Infra.) CYCLED PUMPS AT Ex. 6 (Personal Privacy) O.	
Employees on Job K.M.		
Vehicles or Equip. Used 5		
<u>Meter Readers</u>		
Employees on Job T.C.	FINISHED 13 - 14 & 15	
Areas - Read		
Vehicles Used 4		
General Foreman	Franky Pace	

Date 9-4-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

PULLED NEW LINE FOR
USED 90' OF 3/4" P.V.C. TUBING, TWO 3/4" X 3/4"
COMP. FITTINGS, ONE 3/4" FLARE X COMP. FITTING,
HOOKED P.V.C. ONTO COPPER TAIL COMING

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - B.S. - T.C. - G.F.
GHROUT OF WATER BOX, P.V.C. FROM TAIL TO
MAIN. BACKFILLED WITH SPOIL

Vehicles or Equip. Used

6-14-3 - BACKHOLE

LOCATED ALONG BOND &
BORING CREW

Ex. 6 (Personal Privacy)

Sewer Department

Address

Job Completed

CYCLED

Ex. 6 (Personal Privacy)

3RD

Employees on Job

K.M.

PUMPED OUT YARD FOR D.T.

Vehicles or Equip. Used

5

Meter Readers

Employees on Job

K.M. - T.C.
2HR

STARTED

15 - T.C.

13 - K.M.

Areas - Read

Vehicles Used

4-5

General Foreman

Frank J. Pace

Date 9-3-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

W.O. / Locates

Jobs Completed

Employees on Job

GF, BS

Vehicles or Equip. Used

2, 3

Sewer Department

Address

Check stations

Bypass pumped clinton, 71st + pillbox

Job Completed

Cycled crockett, oakland and
53rd

Ex. 6 (Personal Privacy)

Employees on Job

BS & KM

Switch motor to starter @ pershing

Vehicles or Equip. Used

2, 5

Meter Readers

Employees on Job

TC

Started + Finished

10, 11, 12


Areas - Read

10, 11, 12

Vehicles Used

4

General Foreman



Date 9-2-19

Daily Job Sheet

Sheet ____ of ____

<u>Water Department</u>		Comments
Address		H
Jobs Completed		O
Employees on Job		L
Vehicles or Equip. Used		1 D A
<u>Sewer Department</u>		
Address		
Job Completed		L
Employees on Job		A
Vehicles or Equip. Used		B O R
Meter Readers		D
Employees on Job		A
Areas - Read		y
Vehicles Used		
General Foreman <u>Frank Pace</u>		

Date 10-31-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS

SAW CUT AROUND BOXES AT

Ex. 6 (Personal Privacy)

Jobs Completed

REPLACED CRUSHED PAPER BOX AT
UPPER CAHOKIA - REMOVED CONCRETE SIDEWALK,
REMOVED OLD BOX, SET NEW 18"X30" P.I.C. METER

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - G.F. - T.C. - K.M.

BOX, CHANGED LID, BACKFILLED WITH SPOIL
& ONE BUCKET OF C-M-G ROCK AROUND RING
& LID.

Vehicles or Equip. Used

1-3-14-BACKHOL

RAISED METER BOX WITH 6" CLAY RISER
CUT AT SHOP AT

Ex. 6 (Personal Privacy)

Sewer Department

Address

CYCLED PUMP AT

Ex. 6 (Personal Privacy)

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Franky. Pace

Date 10-30-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed		
Employees on Job F.P. - G.F. G.M.		
Vehicles or Equip. Used 1-3		
Sewer Department		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT Ex. 7f (Water Infra.) PKC BOX, 63RD	
Job Completed	CYCLED BLOWERS AT OAKLAND PERSHING, CYCLED PUMPS AT Ex. 6 (Personal Privacy) Ex. 7f (Water Infra.)	
Employees on Job K.M. - T.C. - F.P. J.M.	DIPPED OUT CANS & INSTALLED TARPS AT BEECHLAND Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 1-5	BELLEVUE PUMPING BUT WELL IS UP DUE TO RAIN.	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	<u>Frank J. Pace</u>	

Date 10-29-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed	LOCATES	
Employees on Job F.P. - G.F. JMR		
Vehicles or Equip. Used 1-3		
Sewer Department		
Address	MOVED BRUSH + DEBRIS TO FIND MANHOLES IN PARKSIDE - HAULED 4 BUCKET OF ROCK TO M.H. AT AMES Ex. 6 (Personal Privacy)	
Job Completed	PUMPED OUT CAN AT Ex. 6 (Personal Privacy) CYCLED BLOWERS AT PERSHING Ex. 7f (Water Infra.) CROCKETTS - CYCLED PUMP AT Ex. 7f (Water Infra.)	
Employees on Job F.P. - T.C. - K.M. GAR	BY-PASS PUMPED WITH 3" GAS PUMP AT CALVIN BLVD, Ex. 6 (Personal Privacy) NEED TARPS FOR BRACHLANDY Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 1-14-5- BACKHOE	PUT DISCHARGE LINE BACK IN AT CLINTON.	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Franky Pace</u>		

Date 10-28-19

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

SEPERATED COPPER & BRASS IN SHOP

Employees on Job

G.F. - T.C.
GRR.

Vehicles or Equip. Used

3

Sewer Department

Address

RE PLACED PUMP AT **Ex. 6 (Personal Privacy)** PULLED
PUMP & CHECKED FOR RAGS/DEBRIS - NOTHING
IN PUMP BUT NOT WORKING.

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST **Ex. 7f (Water Infra.)** PILL BOX.

Employees on Job

F.P. - K.M. - T.C.
GRR. GRR.LOOKED FOR MANHOLE BEHIND **Ex. 6 (Personal Privacy)**
COULDN'T FIND - NEED LOCATOR & BACKHOLE
MOVE BRUSH & FALLEN TREE

Vehicles or Equip. Used

CYCLED BLOWERS AT OAKLAND
PERSHING, CYCLED PUMPS AT
Ex. 6 (Personal Privacy)**Ex. 7f (Water Infra.)**

Meter Readers

Employees on Job

F.P.
GRR.

FINISHED RADIO READ METERS

Areas - Read

Vehicles Used

1

General Foreman

Frank J. Pace

Date 10-25-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS

LOCATES

Jobs Completed

Employees on Job

G.P. F.P.
1 EWR,

Vehicles or Equip. Used

3 1

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST **Ex. 7f (Water Infra.)** PILL BOX

Job Completed

CYCLAD BLOWERS AT OAKLAND,
PERSHING, CYCLAD PUMPS AT
Ex. 6 (Personal Privacy)

Ex. 7f (Water Infra.)

Employees on Job

K.M. - F.P. - T.C.
 & NR

CHECKED STATIONS - VIOLAT, PARKFIELD
BRIDGE DALE, SIGNAL HILL.

Vehicles or Equip. Used

5 - 1

Meter Readers

Employees on Job

F.P. - T.C.
SWR GMR

FINISHED

8+10 - F.P. 9 - T.C.

Areas - Read

Vehicles Used

1

General Foreman

Frank J. Pace

Date 10-24-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATES	
Jobs Completed	MET WITH KEN FROM KELLER CONST. AT R&L TO LOCATE FIRE LINE VALVES	
Employees on Job G.F. - F.P. - B.S.	CLEARED BRUSH FROM AROUND HYDRANT AT Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 3-14-BACKHOE	RAISED METER BOX WITH 4" CLAY RISER CUT AT SHOP AT Ex. 6 (Personal Privacy)	
Sewer Department		
Address	CYCLED BLOWERS AT OAKLAND, CROCKETTS & PERSHING CYCLED PUMPS AT CLINTON Ex. 6 (Personal Privacy)	
Job Completed		
Employees on Job F.P. - B.S. JHR		
Vehicles or Equip. Used 14		
Meter Readers		
Employees on Job T.C. - K.M.	FINISHED 546-T.C. 728-K.M.	
Areas - Read		
Vehicles Used 4		
General Foreman <u>Franky Pace</u>		

Date 10-23-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATAS	
Jobs Completed	RAISED BOX WITH 2" CLAY RISER CUT AT SHOP, HAULED IN DIRT, RAKED, SEEDBOX STRAWED YARD AT Ex. 6 (Personal Privacy)	
Employees on Job G.F. - F.P. - B.S. 6 HR	PROBED OUT MAIN AT PKWY. FOR LOW VOLT ELECTRIC LOCATE, Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used	M&T Ex. 6 (Personal Privacy) AT Ex. 6 (Personal Privacy) ABOUT LOCATE	
3-14- BACKHOL		

Sewer Department

Address	PULLED & CLEANED PUMP #1 AT Ex. 6 (Personal Privacy) CHECKED STATIONS ON SOUTH END	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT Ex. 7f (Water Infra.) PILE BOX, 82ND &	
Employees on Job F.P. - B.S. 2 HR	CYCLED BLOWERS AT OAKLAND, CROCKETS CROCKETS PERSHING, CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used	14- BACKHOL	

Meter Readers

Employees on Job T.C.	FINISHED 344
Areas - Read	STARTED 5
Vehicles Used	DROPPED OFF BY 143


General Foreman

Frank J. Price

Date 10-22-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address	W.O. / Locates Repaired leak Ex. 6 (Personal Privacy) used 3' copper, (1) 3/4 copper to plastic, (1) 3/4 shutoff	
Jobs Completed	Repaired leak Ex. 6 (Personal Privacy) shutoff @ main	
(KM, BS, TC) Employees on Job	saw cut prep @ Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used	Backhoe, 14	
Sewer Department		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman		

Date 10-21-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATES	
Jobs Completed		
Employees on Job G.P. - F.P. - B.S. 2 H.R.		
Vehicles or Equip. Used 3-14		
Sewer Department		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) PILL BOX, CLINTON, 63RD Ex. 6 (Personal Privacy) LVD.	
Job Completed	CYCLOD BLOWERS AT OAKLAND, PERSHING, CROCKETTS - CYCLOD PUMPS AT CLINTON, Ex. 6 (Personal Privacy)	
Employees on Job F.P. - B.S. - T.C. - K.M. G.H.R.	FOUND MANHOLE BEHIND CLEANED BRUSH & MATTRESSES AWAY SO WE CAN BY-PASS IF NEEDED Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 5-14- BACKHOE	PULLED & CLEANED PUMP AT CLINTON, TIED OFF DISCHARGE HOSE INTO DISCHARGE LINE CHECKED SOME STATIONS / ^{ADJUSTED} FLOAT BALLS 75TH	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	<u>Franky Pace</u>	

Date 10-18-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATES	
Jobs Completed		
Employees on Job G.F. - F.P. - T.C. 4 HR		
Vehicles or Equip. Used 1-3-14		
<u>Sewer Department</u>		
Address	REPAIRED DISCHARGE LINE AT SNOWS USED ONE 4"x4" BLUE COUPLING & 15' OF 4" SCH 35 P.V.C. PIPE	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT T Ex. 7f (Water Infra.) TILL BOX, AME	
Employees on Job B.S. - F.P. - T.C. 4 HR 6 HR	CYCLED BLOWERS AT OAKLAND, CROCKETTS, PERSHING, CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 2-5-14		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Thomas J. Price</u>		

Date 10-17-18

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATES	
Jobs Completed	CLEANED OUT TRUCKS + JWEPT SHOP	
Employees on Job G.F. - F.P. - T.C. 3HR 6HR		
Vehicles or Equip. Used 1-3		
Sewer Department		
Address	BY-PASS PUMPS WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) ILL BOX	
Job Completed	CYCLED BLOWERS AT OAKLAND, CROCKETTS + PERSHING, CYCLED PUMPS AT CLINTON + Ex. 6 (Personal Privacy)	
Employees on Job B.S. - T.C. 2HR	PUT DISCHARGE HOSE BACK INTO DISCHARGE LINE AT CLINTON.	
Vehicles or Equip. Used 5	270' FROM M.H. TO WELL AT 71ST ST. 175' M.H. TO WELL AT CLINTON	
Meter Readers		
Employees on Job F.P. 5HR	FINISHED CYCLE 5 RADIO READS	
Areas - Read		
Vehicles Used 1		
General Foreman <u>Franky Pace</u>		

Date 10-16-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATES	
Jobs Completed	DID METER TEST FOR COST AT CHURCH RD - METER TESTED GOOD	
Employees on Job	F.P. - B.S. - G.F. 3 hrs 2 HR	
Vehicles or Equip. Used	1-2-3	
<u>Sewer Department</u>		
Address	WORKED ON 3" GAS PUMP - WON'T PICK UP - O RING INSIDE VALVE IS LOOSE	
Job Completed	CYCLED BLOWERS AT OAKLAND, CROCKETS PERSHING	
Employees on Job	CYCLED PUMPS AT PERSHING	
B.S. GHR	Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used	CHECKED STATIONS	
2-5		
<u>Meter Readers</u>		
Employees on Job	FINISHED 29-F.P. & T.C. 142-T.C.	
F.P. - T.C. 5 HR		
Areas - Read		
Vehicles Used	1	
General Foreman	Frank J. Pace	

Date 10-15-19

Daily Job Sheet

Sheet of

<u>Water Department</u>	
Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	REPLACED CORP. STOP THAT WAS TAPPED INTO 4" A.C. MAIN WITHOUT A SADDLE - USED ONE 4" A.C. SADDLE, ONE 3/4" CORP. STOP, ONE 3/4" X 3/4" COMP. FITTING, 3' OF 3/4" COPPER TUBING,
Employees on Job G.F. - F.P. - B.S. - T.C. GMR GMR	BACKFILLED WITH SPOIL AT Ex. 6 (Personal Privacy)
Vehicles or Equip. Used	
3-14 - BACKHOE	
<u>Sewer Department</u>	
Address	PULLED & CLEANED RAGS OUT OF PUMPS AT Ex. 7f (Water Infra.)
Job Completed	CYCLD BLOWERS AT OAKLAND, CROCKETT, & PERSHING CYCLD PUMPS AT CLINTON Ex. 6 (Personal Privacy)
Employees on Job F.P. - B.S. - T.C. 2 HR	
Vehicles or Equip. Used	
14 - BACKHOE	
Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	
General Foreman	<u>Frank J. Pace</u>

Date 10-14-19

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

LIFTED D.T. ONTO ROOF TO REPAIR ROOF
CLEANED SHOP & UNIT 14

Employees on Job

F.P. - G.P. - T.C.
SHOP
4 HR

Vehicles or Equip. Used

1-8-BACKHOE

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST **Ex. 7f (Water Infra.)** ALL BOX,
75TH **Ex. 7f (Water Infra.)**

Job Completed

CYCLED BLOWERS &
CYCLED PUMP AT

Ex. 7f (Water Infra.)

Employees on Job

F.P. - B.S.
4 HR

NEED TO PULL PUMPS AT
Ex. 7f (Water Infra.)

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

14-5

PUT DISCHARGE HOSE BACK INTO DISCHARGE
LINE AT **Ex. 6 (Personal Privacy)**

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Rice

Date 10-11-19

Daily Job Sheet

Sheet ____ of ____

Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

REPLACED CRUSHED PAPER BOX WITH NEW
18" X 30" P.V.C. METER BOX - RE-USED RING
LID AT Ex. 6 (Personal Privacy)

Employees on Job

F.P. - B.S. - T.C. - G.F.
4HR 2HR 4HR 2HRTOOK UNIT 14 TO ALL TYPE FOR BATTERY
INSTALLATION

Vehicles or Equip. Used

1-3-4-14-BACKHOLE

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST Ex. 7f (Water Infra.) PILL BOX

Job Completed

CYCLED BLOWERS AT OAKLANDS Ex. 7f (Water Infra.)
CYCLED PUMP AT Ex. 6 (Personal Privacy)

Employees on Job

B.S. - K.M.
6HRCHECKED STATIONS - Ex. 7f (Water Infra.)
LINE. NEED TARPS FOR BEECHLAND
Ex. 7f (Water Infra.)

Vehicles or Equip. Used

2-5

Meter Readers

Employees on Job

F.P. - T.C.
4HR 4HRFINISHED
2A & FLOWS - T.C.CYCLE 4 RADIO READS
F.P.

Areas - Read

Vehicles Used

1-4

General Foreman

Franky Pace

Date 10-9-199 10-10-19 Daily Job SheetSheet of

Water Department		Comments
Address	REPAIRED 2" C.I. MAIN BREAK AT Ex. 6 (Personal Privacy) USED TWO 8" DRESSERS & 81" OF 2" P.V.C. PIPE	
Jobs Completed		
Employees on Job F.P. - K.M. - T.C.		
Vehicles or Equip. Used 14-6 - BACKHOE		
Sewer Department		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 10-10-19

Daily Job Sheet

 Sheet of
Water Department
Comments

Address	SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed	BACK FILLED WHERE MAIN BREAK WAS REPAIRED WITH CLEAN ROCK AROUND MAIN & CM-Q ROCK IN ROAD. AT Ex. 6 (Personal Privacy)
Employees on Job F.P. - B.S. - T.C. 3HR 7HR 4HR	POSHED OFF DEBRIS DUMPED AT SNOWS.
Vehicles or Equip. Used 1-6-BACKHOLE-3	

Sewer Department

Address	JETTED LATERAL AT Ex. 6 (Personal Privacy) COULD NOT GET THROUGH BLOCK.
Job Completed	PUT MAN HOLE RING & LID BACK ON M.H. IN Ex. 6 (Personal Privacy) NO, HIT BY MOWER
Employees on Job F.P. - B.S. - T.C. 1 HR	
Vehicles or Equip. Used 1-14-9	

Meter Readers

Employees on Job F.P. - K.M. - T.C. 4HR 8HR 3HR	FINISHED 19-F.P. & K.M. / 24 & 26 K.M.
Areas - Read	STARTED 22-T.C.
Vehicles Used 1-4-5	

 General Foreman Frank J. Price

Date 10-9-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATES	
Jobs Completed	LOCATED VALVES NORTH OF R4L FOR CONTRACTOR BUILDING NEW PARKING LOT.	
Employees on Job	F.P. - B.S. - G.F. 2 HR	
Vehicles or Equip. Used	1-14-3	

Sewer Department		
Address	PULLED PUMPS & CLEANED OUT MOPS/RAGS Ex. 6 (Personal Privacy) LOWRY AT Ex. 6 (Personal Privacy) MET ELECTRICIAN & INSTALLED GROUNDS ON BOX & TRANSFORMER	
Job Completed	JETTED LINE TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy) AND MANHOLE BEHIND GOING IN FROM LARRAINE &	
Employees on Job	JETTED TO Ex. 6 (Personal Privacy) STILL HOLDING A. ARE DOWN CYCLED BLOWERS & Ex. 7f (Water Infra.) CYCLED PUMP AT	
Vehicles or Equip. Used	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) PILL BOX	

Meter Readers	
Employees on Job	FINISHED T.C. 20421
Areas - Read	
Vehicles Used	4
General Foreman	Frank J. Rice

Date 10-8-19

Daily Job Sheet

Sheet _____ of _____

Water Department	Comments
Address	SERVICE TRUCK LHO.
Jobs Completed	REPLACED LEAKING SADDLE WITH ONE S.S. REPAIR CLAMP WITH 3/4" TAP, ONE 3/4" CORR STOP, 2' OF 3/4" COPPER, ONE 3/4" X 3/4" COMP. FITTING. BACKFILLED WITH CLEAN ROCK & BPOK
Employees on Job F.P. - B.S. - C.F. - T.C. G.M.	AT Ex. 6 (Personal Privacy) FOR HOUSE ACROSS STREET
Vehicles or Equip. Used	
1-3-14-BACKHOE	

Sewer Department	
Address	CYCLED PUMP AT CYCLED PUMPS AT FULL ~KEEP KICKING OUT.
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers	
Employees on Job	K.M. FINISHED 23
Areas - Read	STARTED 24
Vehicles Used	5
General Foreman	Frank J. Pace

Date 10-7-19

Daily Job Sheet

Sheet ____ of ____

Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed	HAULED OFF DIRT WHERE LEAKS WERE REPAIRED AT PARIS Ex. 6 (Personal Privacy) HAULED IN DIRT & GRADED AT CENTRAL Ex. 6 (Personal Privacy)
Employees on Job F.P. - B.S. - T.C. - G.F. GAR 4 HR	HAULED IN DIRT, GRADED & SEEDED AT Ex. 6 (Personal Privacy) MET AMERIN CROWD & PROBES OUT MAIN SO THEY COULD ASKER FOR POLE BETWEEN Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 1-14-6 - BACKHOE	RAISED METER BOX WITH ONE ROW OF BRICKS & 1/2 BUCKET C-M-L ROCK FROM SHOP AT Ex. 6 (Personal Privacy)

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) PILE BOX, CALV TSBURG
Job Completed	CYCLAD BLOWERS AT Ex. 7f (Water Infra.) CYCLAD PUMP AT
Employees on Job K.M.	
Vehicles or Equip. Used 5	

Meter Readers

Employees on Job T.C. - F.P. 4 HR 2 HR	FINISHED 18-T.C. CYCLE 4 RADIO READS - F.P.
Areas - Read	
Vehicles Used 1-4	

General Foreman

Frank J. Pace

Date 10-4-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

OPENED VALVES & FLUSHED HYDRANT IN
SAUGET IND.

Employees on Job

F.P. - B.S.
4 PR

INSTALLED FITTINGS ON NEW 2" PUMP

Vehicles or Equip. Used

14-2-3

Sewer Department

Address

CHECKED STATIONS ON SOUTH SIDE
NEED TO PULL PUMPS AT **Ex. 6 (Personal Privacy)**
BOTH PUMPS WERE KICKED OUT

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT
7" **Ex. 7f (Water Infra.)** PILL BOX,

Employees on Job

K. M.

CYCLED BLOWERS & **Ex. 7f (Water Infra.)**
CYCLED PUMP AT

Vehicles or Equip. Used

5

Meter Readers

Employees on Job

T.C.

FINISHED
17

Areas - Read

STARTED
18

Vehicles Used

4

General Foreman

Franky Pace

Date 10-3-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK WORK ORDERS CHECKED LOW PRESSURE PROBLEM AT DIVITA DUE TO HOLTAN FILLING TANK AGAIN	
Jobs Completed	LOCATES BACK FILLED AROUND HYDRANT + SET VALVE BOX AT Ex. 6 (Personal Privacy) NEED TO GRADE YARD	
Employees on Job K.M. - F.P. - B.S.	POT HOLE MAIN BETWEEN ANDREWS & Ex. 6 (Personal Privacy) POLK - CALLED SITE CONTACT BECAUSE WE ARE IN CONFLICT WITH	
Vehicles or Equip. Used	STAKE THEY HAVE SET FOR POLK	
1-3-14-BACKHOLE		

<u>Sewer Department</u>	
Address	CYCLED PUMP AT Ex. 6 (Personal Privacy)
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers	
Employees on Job T.C.	FINISHED 14-15
Areas - Read	STARTED 17
Vehicles Used 4	
General Foreman	Frank J. Pace

Date 10-2-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	REMOVED HYDRANT & VALVE FROM TEE IN MAIN, INSTALLED OUR 12" RESTRAINING NIPPLE + ONE 10" RESTRAINING NIPPLE. REPLACED
Employees on Job F.P. - T.C. - B.S. - K.M. 4HR 6HR 4HR	HYDRANT & VALVE BACK INTO TEE WITH RESTRAINING NIPPLES TO REPAIR LEAK AT Ex. 6 (Personal Privacy) LED TO BACKFILL
Vehicles or Equip. Used 1-14-3-BACKHOLE	CHECKED VALVES FOR LOW PRESSURE IN Ex. 6 (Personal Privacy) THINK IT WAS DUE TO HOLTEN FLUSHING TANK - VALVES OPEN

Sewer Department

Address	MET WITH JEFF TO INSTALL TRANSDUCER AT 53RD. - RUNNING ON AUTO NOW.
Job Completed	CYCLER PUMPS AT Ex. 6 (Personal Privacy) 3RD CYCLER BLOWERS AT Ex. 7f (Water Infra.)
Employees on Job B.S. K.M. 2HR 4HR	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) ALL BOX
Vehicles or Equip. Used BACKHOLE	

Meter Readers

Employees on Job T.C. 4HR	FINISHED 13
Areas - Read	
Vehicles Used 4	

General Foreman Frank J. Pace

Date 10-1-19

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed <i>10-1-19</i>	EXPOSED MAIN, TEL, VALVE & HYDRANT SHOR TO FIND LEAK ON VALVE AT Ex. 6 (Personal Privacy) NEED TO REPLACE FROM TEL TO HYDRANT
Employees on Job <i>K.M. - F.P. - B.S. C.M.R.</i>	
Vehicles or Equip. Used <i>1-3-14-BACKHOE</i>	

Sewer Department

Address	REPAIRED 4" SCH 35 DISCHARGE LINK AT SNOWS - USED 5'4" PIECE OF 4" SCH 35 PIPE, ONE 4" X 4" GLOBE COUPLING & ONE 4" X 4" FARNCO
Job Completed	CYCLD PUMPS AT Ex. 6 (Personal Privacy) 53RD.
Employees on Job <i>F.P. - B.S. C.M.R.</i>	
Vehicles or Equip. Used <i>1</i>	

Meter Readers

Employees on Job <i>T.C.</i>	FINISHED 11-12
Areas - Read	STARTED 13
Vehicles Used <i>4</i>	

General Foreman

Frank J. Pace

Date 11-29-17

Daily Job Sheet

Sheet of **Water Department****Comments**

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Franky. Rice

Date 11-28-19

Daily Job Sheet

Sheet of Water Department

Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

THANKS

61VW6

HOLIDAY

Frank J. Pace

Date 11-21-17

Daily Job Sheet

Sheet 1 of 1

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed		
Employees on Job F.P.		
Vehicles or Equip. Used 3		
Sewer Department		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT Ex. 7f (Water Infra.) PILL BOX	
Job Completed	CYCLED BLOWERS AT OAKLAND, CROCKETTS, PERSHING, CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)	
Employees on Job B.S. - T.C. - K.M.	WORKED ON POLICE STATION FRONT - PUMPING & CYCLING NOW.	
Vehicles or Equip. Used 2-14-5	CHECKED STATIONS	
Meter Readers		
Employees on Job F.P. S.M.R.	FINISHED CYCLE 3 RADIOS	
Areas - Read		
Vehicles Used 3		
General Foreman	Franky Pace	

Date 11-26-19

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed		
Employees on Job F.P.		
Vehicles or Equip. Used 3		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP IN FIELD FROM Ex. 6 (Personal Privacy)	
Job Completed	WORKED ON CHANGING STARTER AT STATION FRONT - STILL NOT SHUTTING DOWN WITH FLOATBALLS Ex. 7f (Water Infra.)	
Employees on Job B.S. - K.M. - T.C. GIVE	CLEANED FLOATBALLS AT REAR + Ex. 7f (Water Infra.) Ex. 7f (Water Infra.)	
Vehicles or Equip. Used 5-14-2-BACKHOLE	Ex. 7f (Water Infra.) Ex. 6 (Personal Privacy) OFF DUE TO Ex. 7f (Water Infra.)	
Meter Readers		
Employees on Job T.C. GIVE	FINISHED 9410	
Areas - Read		
Vehicles Used DROP OFF		
General Foreman	Frank Face	

Date 11-25-14

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS	
	LOCATES	
Jobs Completed		
Employees on Job F.P. GAR		
Vehicles or Equip. Used		
3		

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71st Ex. 7f (Water Infra.) ALL BOX	
Job Completed	CYCLED BLOWERS AT OAKLAND, CROCKETTS, PERSHING, CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)	
Employees on Job F.P. - B.S. - K.M. JNR	PULLED PUMP IN FIELD FROM NEED TO BY-PASS PUMP TOMORROW. Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used	D.T. FOUND BAD STARTER AT FRONT- 51ST, 53RD, Ex. 6 (Personal Privacy) 5-14- BACKHOE Ex. 7f (Water Infra.) STATION REAR ALL OFF.	

Meter Readers

Employees on Job T.C.	FINISHED 6, 7, 8
Areas - Read	STARTED 9
Vehicles Used	DROP OFF
General Foreman	Franky. Pace

Date 11-22-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDER REMOVED METERS	
Jobs Completed		
Employees on Job F.P. - B.S. 4 HR		
Vehicles or Equip. Used 2 - 3		
Sewer Department		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) PILL BOX	
Job Completed	CYCLED BLOWERS AT OAKLAND & CROCKETTS, FLOSHING - CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)	
Employees on Job B.S. 4 HR		
Vehicles or Equip. Used 5		
Meter Readers		
Employees on Job T.C.	FINISHED 5	
Areas - Read	STARTED 6	
Vehicles Used DROP OFF		
General Foreman	Frank J. Pace	

Date 11-21-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATES	
Jobs Completed		
Employees on Job F.P. - G.F. 3 HR		
Vehicles or Equip. Used 1 - 3		
Sewer Department		
Address	CHECKED FOR BACKUP AT CUST. PROBLEM	
Job Completed	PULLED PUMP & CLEANED OUT RAGS AT PUMPING FULL PIPE NOW	
Employees on Job F.P. - B.S. 5 HR	BY-PASS PUMPED WITH 3" GAS PUMP AT 7157 Ex. 7f (Water Infra.) PILL BOX, Ex. 7f (Water Infra.)	
Vehicles or Equip. Used 5-14 BACKHOL	CYCLED BLOWERS AT OAKLAND, CROCKETTS & PERSHING - CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)	
Meter Readers		
Employees on Job T.C.	FINISHED 3 & 4	
Areas - Read	STARTED 5	
Vehicles Used DROP OFF		
General Foreman	Frank J. Pace	

Date 11-20-19

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

REPLACED LEAKING SADDLE + REBUILT
SERVICE A **Ex. 6 (Personal Privacy)** USED ONE
6" A.C. SADDLE, ONE 3/4" CORP STOP, ONE

Employees on Job

G.F. - F.P. - B.S. - T.C.

3/4" x 5/8" METER SET, ONE 3/4" x 3/4" COMP.
FITTING, ONE 18" x 30" P.V.C. METER BOX +
20' OF 3/4" P.V.C. TUBING. - MAIN IS

Vehicles or Equip. Used

3-5-14-BACKHOLE

BEHIND METER BOX & SET IS IN BOX
BACKWARDS - BACK FILLED WITH TWO
BUCKETS OF SAND FROM SHOP & SOIL.Sewer Department

Address

CYCLD PUMP AT **Ex. 6 (Personal Privacy)**

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Price

Date 11-19-19

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	EXPOSED MAIN/TAP & SHUT OFF SERVICE LINE AT CORP. STOP - Ex. 6 (Personal Privacy)
Employees on Job F.P. - B.S. - G.P. - T.C.	EXPOSED MAIN/TAP, CUT ROOTS & DUG OUT AROUND MAIN/TAP SO IT CAN BE REPLACED TOMORROW AT Ex. 6 (Personal Privacy)
Vehicles or Equip. Used	
3-14-BACKHOLE	

Sewer Department

Address	CYCLERA Ex. 6 (Personal Privacy)
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank Pace

Date 11-18-14

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed		
Employees on Job G.F. - T.C. 4MR		
Vehicles or Equip. Used 3		
Sewer Department		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) Pipe Box	
Job Completed	CYCLED BLOWERS AT OAKLAND, CROCKETTS, PERSHING. CYCLED PUMPS AT 70TH Ex. 6 (Personal Privacy)	
Employees on Job F.P. - T.C. 4MR		
Vehicles or Equip. Used 5		
Meter Readers		
Employees on Job F.P. 4MR	FINISHED RADIO READ METERS	
Areas - Read		
Vehicles Used 1		
General Foreman <u>Frank J. Lee</u>		

Date 11-15-19

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F. - T.C. 1 PR	
Vehicles or Equip. Used 3	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) REC BOX
Job Completed	CYCLED BLOWERS AT OAKLAND, CROCKETTS, PERSHING, CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)
Employees on Job F.F. 4 PR	
Vehicles or Equip. Used 5	

Meter Readers

Employees on Job F.F. - T.C. 4 PR 7 PR	FINISHED AREA 29 MANUAL READS
Areas - Read	
Vehicles Used 1	

General Foreman

Frank J. Rose

Date 11-14-19

Daily Job Sheet

Sheet ___ of ___

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed	
Employees on Job G.F. F.P. 1 HR	
Vehicles or Equip. Used 1-3	

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
Ex. 7f (Water Infra.)

Job Completed

CYCLAD BLOWERS AT CARLINA, CROCKETS, &
PERSHING CYCLAD PUMPS AT CLINTON
Ex. 6 (Personal Privacy)

Employees on Job

B.S. - T.C. - F.P.
4 HR 6 HR 3 HR

PULLED PUMP AT **Ex. 6 (Personal Privacy)**
FOR RAGS/BLOCKAGE - NOTHING IN PUMP
PUMP IS PUMPING ALL IT CAN I GUARD

Vehicles or Equip. Used

5-1

Meter Readers

Employees on Job

F.P. - T.C.
5 HR 3 HR

FINISHED

CYCLE 5 RADIOS - F.P.

Areas - Read

STARTED

39 - F.P. & T.C.

Vehicles Used

General Foreman

Frank J. Price

Date 11-13-19

Daily Job Sheet

Sheet ___ of ___

Water Department	
Address	Comments
	SERVICE TRUCK WORK ORDERS
	LOCATES
Jobs Completed	EXPOSED MAIN & SHUT OFF CORP. STOP AT Ex. 6 (Personal Privacy)
Employees on Job F.P.-B.S. - G.F. G.H.R.	EXPOSED SERVICE LINE OUTSIDE BOX & CUT & CRIMPED OFF LINE AT Ex. 6 (Personal Privacy)
Vehicles or Equip. Used	
3-14-BACKHOE	
Sewer Department	
Address	CYCLED PUMP AT Ex. 6 (Personal Privacy)
Job Completed	LOOKED FOR SEWER LEAK ON 83ND DID NOT SEE LEAK IN STREET.
Employees on Job F.P.-B.S. A.H.R.	CHECKED Ex. 7f (Water Infra.) - BOTH GOOD,
Vehicles or Equip. Used	
14	
Meter Readers	
Employees on Job KM, TC	Started & Finished 20, 21, 22
Areas - Read 20, 21, 22	
Vehicles Used 5	
General Foreman Frank J. Pace	

Date 11-12-19

Daily Job Sheet

Sheet ___ of ___

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

GARAGE DOOR ON EAST SIDE OF SHOP
NEEDS HELP TO LIFT, OPEN

Employees on Job

F.P. - G.F.

4 hrs

Vehicles or Equip. Used

1-3

Sewer Department

Address

MEASURES FOR MAN HOLE RISERS ON

Ex. 6 (Personal Privacy)

Job Completed

CHECKED STATIONS - PULLED PUMPS AT
Ex. 7f (Water Infra.) LEANED OUT RACS.

Employees on Job

B.S. - T.C. - F.P. - K.M.
4 hrsFOUND M.H. & CHECKED FOR BACKUP AT
Ex. 6 (Personal Privacy) WAS BROKEN WATER LINE
IN HOUSE - COST, PROBLEM.**Ex. 6 (Personal Privacy)**

Vehicles or Equip. Used

14-1- BACKHOLE-5

SWITCHED ALTERNATOR AT CRESTON - STILL
NOT ALTERNATING.

Meter Readers- SEWERS

Employees on Job

BY-PASS PUMPED WITH 3" GAS PUMP AT
713 **Ex. 7f (Water Infra.)** BOX, G3RD &
Ex. 7f (Water Infra.) VD.

Areas - Read

CYCLED BLOWERS AT OAKLAND, CROCKETT'S
PERSHING, CYCLED PUMPS AT **Ex. 6 (Personal Privacy)**

Vehicles Used

General Foreman

Frank P. Pace

Date 11-11-14

Daily Job Sheet

Sheet of Water Department

Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

HOLIDAY

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

VETERANS

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

DAY

General Foreman

Frank J. Price

Date 11-8-14

Daily Job Sheet

Sheet ___ of ___

Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed	CRIMPED OFF LINES IN BOX & REPLACED METER SHUT OFF VALVES AT Ex. 6 (Personal Privacy)
Employees on Job F.P. - B.S. - G.P. S.H.R. J.H.R.	
Vehicles or Equip. Used 1-3	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 715. Ex. 7f (Water Infra.) ALL BOX, G3RD & P.
Job Completed	CYCLED BLOWERS AT OAKLAND, CROCKETTS, PERSHING, CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)
Employees on Job K.M.	
Vehicles or Equip. Used 5	

Meter Readers

Employees on Job B.S. - F.P. J.H.R. 3 H.R.	FINISHED 23, 24 & 26 - T.C. 19 - F.P. & B.S.
Areas - Read	
Vehicles Used 1 + DRO. OFF	
General Foreman	Franky Pace

Date 11-7-19

Daily Job Sheet

Sheet ____ of ____

Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

Employees on Job

F.P. - G.F.

4 HRS

Vehicles or Equip. Used

1-3

Sewer Department

Address

BY-PASS PUMPS WITH 3" GAS PUMP AT
TIS
CALVIN BLVD.
Ex. 7f (Water Infra.) PILE BOX

Job Completed

CYCLED BLOWERS AT OAKLAND, CROCKETT &
PERSHING - CYCLED PUMPS AT CLINTON &
Ex. 6 (Personal Privacy)

Employees on Job

K.M. - B.S. - T.C. - F.P.
JHRCHECKED STATIONS - PUMP #2 AT VIOLET
OUTNEEDS PULLED, SUPERIOR STILL NOT
ALTERNATING WITH NEW ALTERNATOR

Vehicles or Equip. Used

LOCATED M.H. AT CLARITA & EXPOSED IT

Meter Readers

Employees on Job

F.P.
JHR

FINISHED

RADIO READ METERS

Areas - Read

Vehicles Used

1

General Foreman

Frank J. Price

Date 11-6-19

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed	MADE PUSH UNDER OLD MO. FOR OLD MO. - USED 60' OF $\frac{3}{4}$ " P.V.C. TUBING, ONE $\frac{3}{4}$ " x $\frac{3}{4}$ " COMP. FITTING, TWO $\frac{3}{4}$ " P.V.C. INSERTS	
Employees on Job F.P. - B.S. - K.M. - T.C. G.M.	RAN P.V.C. FROM MAIN TO OUTSIDE OF BOX. BACK FILLED WITH SPOIL.	
Vehicles or Equip. Used 3 5-14 - BOTH BACKHOES		
Sewer Department		
Address	CYCLER PUMP AT	
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job T.C. J.H.R.	FINISHED 18	
Areas - Read		
Vehicles Used DEEP OFF		
General Foreman	Franky Pace	

Date 11-5-19

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

TRIED TO MAKE PULL ACROSS OLD MO.
AVE - COULDN'T GET CABLE THROUGH LINE
EXPOSED TAP & TAIL OUT OF BOX, DUG PUSH

Employees on Job

F.P. - B.S. - G.F. - K.M.
GFRHOLES FOR PUSH TOMORROW, BARRICADED &
RIBBONED OFF HOLES AT

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

3-5-14 - BACKHOE

Sewer Department

Address

CYCLED PUMP AT

Ex. 6 (Personal Privacy)

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

T.C.

FINISHED
15 & 17

Areas - Read

STARTED
18

Vehicles Used

DROP OFF

General Foreman

Franky Pace

Date 11-1-14

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed		
Employees on Job Cof.		
Vehicles or Equip. Used 3		
Sewer Department		
Address	PULLED BOTH PUMPS & CLEANED OUT RAGS FROM #1 PUMP AT CRAYTON	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 715' Ex. 7f (Water Infra.) PLE. BOX	
Employees on Job F.P. - K.M. T.M.R.	CYCLED BLOWERS AT OAKLAND CROCKETTS - PERSHING - CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 5-14- BACKHOE		
Meter Readers		
Employees on Job T.C.	FINISHED 11/2/12	
Areas - Read	STARTED 13	
Vehicles Used DROPPED OFF		
General Foreman	Frank J. Rice	

Date 11-4-14

Daily Job Sheet

Sheet of

Water Department		Comments
Address	<u>SERVICE TRUCK WORK ORDERS</u> <u>LOCATES</u>	
Jobs Completed		
Employees on Job <u>G.F. - F.P.</u> <u>JAR</u>		
Vehicles or Equip. Used <u>1-3</u>		
Sewer Department		
Address	<u>PULLED BOTH PUMPS & CLEANED OUT RAGS</u> <u>AT CRESTON - NOT ALTERNATING TO</u> <u>PUMP #2 - PUMP #1 RUNNING EVERY TIME</u>	
Job Completed	<u>BY-PASS PUMPED WITH GAS PUMP AT</u> <u>7151 Ex. 6 (Personal Privacy) PILL BOX</u>	
Employees on Job <u>F.P. - K.M.</u> <u>CMR</u>	<u>CYCLED BLOWERS AT OAKLAND, CROCKETT,</u> <u>PERSHING, CYCLED PUMPS AT CLINTON &</u> <u>Ex. 6 (Personal Privacy)</u>	
Vehicles or Equip. Used <u>1-5-14 - BACKHOE</u>		
Meter Readers		
Employees on Job <u>T.C.</u>	<u>FINISHED</u> <u>13714</u>	
Areas - Read	<u>STARTED</u> <u>15</u>	
Vehicles Used <u>DROP OFF</u>		
General Foreman	<u>Frank Pace</u>	

Date 12-2-19

Daily Job Sheet

Sheet 1 of 1**Water Department****Comments**

Address

W.O. / Locates

Jobs Completed

Employees on Job

B.S., T.C., K.M.

Vehicles or Equip. Used

2, 5

Sewer Department

Address

Pulled pump @ **Ex. 6 (Personal Privacy)** and bypassed
Bypass pumped @ **Ex. 6 (Personal Privacy)**

Job Completed

Pulled pump @ creston cleaned and replaced
Dipped out water at Oakland station

Employees on Job

Checked Stations

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman



Date 12-3-14

Daily Job Sheet

Sheet 1 of 1

Water Department

Comments

Address

W.O. / Locates

Jobs Completed

Employees on Job

GF, BS.

Vehicles or Equip. Used

2, 3

Sewer Department

Address

Bypass pumped @ 71st, 71st (pillbox)

Cycled Oakland & crockett stations

Job Completed

Cycled **Ex. 6 (Personal Privacy)**

Replaced lid & ring on sewer manhole on Clarita

Employees on Job

KM.

Lock removed, returned to power station (Berchland)

Checked stations

Vehicles or Equip. Used

2, 5, Backhoe

Meter Readers

Employees on Job

T.C.

Finished

11, 12, 13


Started

14

Areas - Read

Vehicles Used

General Foreman



Date 12-4-17

Daily Job Sheet

Sheet 1 of 1

Water Department

Comments

Address

W.O. / Locates

Jobs Completed

Employees on Job

G.F.

Vehicles or Equip. Used

3

Sewer Department

Address

Ex. 6 (Personal Privacy)

Checked stations

Pulled #1 pump @ Creston; cleaned and replaced

Job Completed

Pump burned out Ex. 7f (Water Infra.)

3" pump cycled

Pulled both pumps replaced, Pump #1 running

Employees on Job

Pump #2 @ Violet Dring is stretched (left off)

B.S., K.M.

motor burned out @ superior station, 1 pump running

Vehicles or Equip. Used

5/14, Backhoe

Meter Readers

Employees on Job

Started & Finished

T.C.

14, 15, 17

Areas - Read

14, 15, 17

Vehicles Used

General Foreman

K. M. Hall

Date 12-0-17

Daily Job Sheet

Sheet 1 of 1

Water Department

Comments

Address

W.D. / Locates

Installed 2" domestic (turned on) and 2" irrigation left off

Jobs Completed

Records & turnoffs

Employees on Job

GF, DC, BS, KM

Vehicles or Equip. Used

3, 2nd

Sewer Department

Address

Cycled

Ex. 6 (Personal Privacy)

Oakland & Crockett, Persian and Stanton

Job Completed

Employees on Job

KM

Vehicles or Equip. Used

5

Meter Readers

Employees on Job

started & finished

BS, TC

18 & radio reads


Areas - Read

18

Vehicles Used

2

General Foreman



Date 12-10-17

Daily Job Sheet

Sheet 1 of 1

Water Department**Comments**

Address

W.O./Locates

Jobs Completed

Employees on Job

GF

Vehicles or Equip. Used

3

Sewer Department

Address

Bypass pumped 71st, pillbox, Renois

Cycled oakland, crockett Ex. 6 (Personal Privacy) clinton

Job Completed

Checked Stations

Pulled rag @ bridgevale

Employees on Job

BS, KM

Vehicles or Equip. Used

2, 5

Meter Readers

Employees on Job

TC, BS, KM

Started

Finished

24

19, 20, 23

Areas - Read

19, 20

Vehicles Used

5

General Foreman

Date 12-11-17

Daily Job Sheet

Sheet 1 of 1

Water Department

Comments

Address

W.O. / Locates

Jobs Completed

Employees on Job

GF

Vehicles or Equip. Used

3

Sewer Department

Address

Checked stations

Pulled rag from

Bypass pump

Ex. 7f (Water Infra.) station

Job Completed

Cycled

Ex. 7f (Water Infra.)

+ crocketh

Check broken

Ex. 7f (Water Infra.)

Employees on Job

BS, KM

Vehicles or Equip. Used

Backhoe, 2, 5

Meter Readers

Employees on Job

TC

Started + finished

21, 22, 24

Areas - Read

21, 22, 24

Vehicles Used

General Foreman



Date 12-10-17

Daily Job Sheet

Sheet 1 of 1

Water Department**Comments**

Address

W.O. / Locate

Rebuild

Ex. 6 (Personal Privacy)4' copper, (1) copper - copper^(3/4) (1) 3/4 backside

Jobs Completed

Employees on Job

G.F., T.C., K.M.

Vehicles or Equip. Used

3, 14, Backhoe

Sewer Department

Address

Bypass @

Ex. 6 (Personal Privacy) (field)

checked stations

Job Completed

Pulled back off bridge/dale station, removed rags

Employees on Job

K.M., B.S.

Vehicles or Equip. Used

5, 14

Meter Readers

Employees on Job

T.C., B.S.

Started ~ Finished

Radio Reads, 24

Areas - Read

Radio Reads, 24

Vehicles Used

2

General Foreman

Date 12-11-11		Daily Job Sheet		Sheet 1 of 1	
Water Department			Comments		
Address		W.O./Locates			
Jobs Completed					
Employees on Job		GF			
Vehicles or Equip. Used					
Sewer Department					
Address		Checked stations Cycled oakland, crockett, pershing, clinton, Ex. 6 (Personal Privacy)			
Job Completed		Bypassed Bluff station Located manholes from Ex. 6 (Personal Privacy)			
Employees on Job		BS, KM, TC			
Vehicles or Equip. Used		Backhoe, 5, 2			
Meter Readers					
Employees on Job					
Areas - Read					
Vehicles Used					
General Foreman		K. J. McCall			

Water Department		Comments
Address	W.O./Locates	
Jobs Completed		
Employees on Job	GF, BS, TC	
Vehicles or Equip. Used	2, 3	
Sewer Department		
Address	Replaced flapper in Ex. 7f (Water Infra.) Inserted ball in Ex. 6 (Personal Privacy) stop groundwater in system	
Job Completed	Bypass pumped Ex. 6 (Personal Privacy) (field) Pulled Ex. 6 (Personal Privacy) cleaned & cycled	
Employees on Job	BS, KM	
Vehicles or Equip. Used	14, 5, Backhoe	
Meter Readers		
Employees on Job	Started & Finished 29, 1, 2	
Areas - Read	29, 1, 2	
Vehicles Used	3	
General Foreman	K. Hall	

Date 12-14-11

Daily Job Sheet

Sheet 1

Water Department	
	Comments
Address	W.O
Jobs Completed	
Employees on Job	
GF	
Vehicles or Equip. Used	
3	

Sewer Department	
Address	Pulled Ex. 6 (Personal Privacy) bags, replaced cycled pumps @ oakland Ex. 7f (Water Infra.)
Job Completed	
Employees on Job	
BS. KM	
Vehicles or Equip. Used	
Backhoe, 5, 2	

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman	K. J. 14-11-11
-----------------	----------------

Water Department

Comments

Address

12-13-19

W.O. / Locates

Jobs Completed

Employees on Job

GF

Vehicles or Equip. Used

3

Sewer Department

Address

Cycled

Ex. 6 (Personal Privacy)

Oakland stations

Bypass pumped

Ex. 7f (Water Infra.)

Job Completed

Employees on Job

KM

Vehicles or Equip. Used

5

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman



Date 12-11-17

Daily Log Sheet

Water Department	
Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job	G.F.
Vehicles or Equip. Used	3

Sewer Department	
Address	BY-PASS PUMPED Ex. 7f (Water Infra.) BOX CYCLED BLOWERS AT OAKLAND, CROCKETTS, PERSHAW, CYCLED PUMPS AT CLINTON
Job Completed	Ex. 6 (Personal Privacy) CHECKED STATIONS
Employees on Job	TRIED TO PULL PUMP AT CRESTON - B.S., K.M., - F.P. 2HR DROPPED PUMP IN WELL - RETRIEVED CHAIN, BUT DIDN'T PULL PUMP DUE TO TIME
Vehicles or Equip. Used	5-2-14-7-BACKHOE

Meter Readers	
Employees on Job	F.P. FINISHED GHR CYCLE 2 RADIO READS
Areas - Read	
Vehicles Used	

General Foreman	Frank Prince
-----------------	--------------

Date 12-18-19

Daily Job Sheet

Water Department		Comments
Address	12-18-19	SERVICE TRUCK WORK ORDERS
Jobs Completed		HOOKEO UP BACKSIDE A USED ONE 3/4" X 3/4" COMP. FITTING & ONE 3/4" P.V.C. INSERT, HOOKEO P.V.C. HOUSE LINE TO
Employees on Job	C.F. - F.P. - B.S. - K.M. 4 HR	COPPER TAIL OUTSIDE BOX, BACKFILLED WITH SPOIL
Vehicles or Equip. Used		
	3-14-5- BACKHOC	

Ex. 6 (Personal Privacy)

Sewer Department		
Address		PULLED, INSPECTED & RESET PUMP AT CRESTON - NEED TO VACUUM OUT WELL
Job Completed		BY-PASS PUMPED WITH 3" GAS PUMP AT FIELD FROM
Employees on Job	F.P. - B.S. - K.M. 4 HR	
Vehicles or Equip. Used		
	5-14- BACKHOC	

Ex. 6 (Personal Privacy)

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman Franky Pace

Date 12-17-11

Daily Job Sheet

Sheet 1 of 1

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

LOCATES

Jobs Completed

Employees on Job

G.F. - F.P.
4HR

Vehicles or Equip. Used

3-14

Sewer Department

Address

BY-PASS PUMPER WITH 3" GAS PUMP AT
Ex. 7f (Water Infra.) BOX

Job Completed

CYCLED BLOWERS AT OAKLAND, CROCKETTS
PERSONAL CYCLED PUMPS AT CLINTON &
Ex. 6 (Personal Privacy) ERD TO PULL PUMP AT
Ex. 6 (Personal Privacy)

Employees on Job

F.P. - B.S.
4HRPULLED PUMP & CLEANED OUT RAGS AT
Ex. 6 (Personal Privacy) PUMPING NOW.

Vehicles or Equip. Used

5-14- BACKHOE

WORKED ON PUMP CO.
FITTINGS FOR Ex. 6 (Personal Privacy) IN SHOP

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Water Department		Comments
Address	W.O. / Locates	
Jobs Completed		
Employees on Job		
Vehicles or Equip. Used		

Sewer Department		Comments
Address	Bypass pumped Ex. 7f (Water Infra.) Bellevue Cycled oakland & crickett stations	
Job Completed		
Employees on Job		
Vehicles or Equip. Used		

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman	
-----------------	--

Water Department	
Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job	G.F.
Vehicles or Equip. Used	3

Sewer Department	
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT Ex. 7f (Water Infra.) BOX
Job Completed	CYCLED BLOWERS AT OAKLAND CROCKETTS, PERSHING, CYCLED PUMPS AT Ex. 6 (Personal Privacy)
Employees on Job	F.P. - B.S. - K.M. WIRED & FITTED UP PUMPS & FLOAT BALLS FOR Ex. 6 (Personal Privacy) FROM Ex. 6 (Personal Privacy) CAVALLER - SET PUMPS IN WELLS & ALL ARE
Vehicles or Equip. Used	PUMPING NOW. 2-5-14- BACKHOLE

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	
General Foreman	Franky Pace

Water Department	Comments
Address 12-27-19	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F.	
Vehicles or Equip. Used 3	

Water Department	Comments
Address	CHECKED STATIONS FRONT LOSSES PRIME CLINTON, POLE
Job Completed	Ex. 7f (Water Infra.) Ex. 6 (Personal Privacy) GETTING WORSE, LEARNING MORE. LOCATED
Employees on Job F.P.	CYCLED BLOWERS AT OAKLAND, CROCKETTS, PERSHING, CYCLED PUMPS AT CLINTON Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 1	
Meter Readers	
Employees on Job T.C. - K.M.	FINISHED AREAS 8-K.M - 5-T.C.
Areas - Read	STARTED AREAS 9-K.M 6-T.C.
Vehicles Used 5	
General Foreman	Frank J. Pace