


Water Department		Comments
Address	1-2-20	SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed	REPAIRED 4" A.C. MAIN BREAK AT ANDREWS - USED ONE 4" A.C. S.S. REPAIR CLAMP & BACKFILLED WITH SPOIL	Ex. 5 (Personal Privacy)
Employees on Job	RE-SET BARRICADES AROUND PATCH IN ROAD WHERE LEAK WAS REPAIRED AT RANGE	Ex. 6 (Personal Privacy)
Vehicles or Equip. Used		
	3-5- BACKHOC	
Sewer Department		
Address	PULLED BACK OFF PUMP & CLEANED OUT RAGS/MOP AT BRIDGE DALE CHECKED STATIONS	
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT LAKE PILL BOX	Ex. 7f (Water Infra.)
Employees on Job	CYCLED BLOWERS AT OAKLAND CROCKETTS & PERSHING, CYCLED PUMPS AT CLINTON &	Ex. 6 (Personal Privacy)
Vehicles or Equip. Used		
	1-14-5	
Meter Readers		
Employees on Job	FINISHED 13 & 14 - T.C.	
Areas - Read	STARTED 18 - T.C.	
Vehicles Used	DROP OFF	
General Foreman	Frank J. Pace	

Water Department		Comments
Address 1-3-20	SERVICE TRUCK WORK ORDERS LOCATES	
Jobs Completed	SHUT OFF CORP. STOPS AT MAINS AT Ex. 6 (Personal Privacy) ST. BARTHOLOMEW	
Employees on Job F.P. - G.F. B.S. - K.M. G.M. J.M.	CRIMPED LINE OFF OUTSIDE BOX AT Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used		
1-3-14- BACKHOE		
Water Department		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT Ex. 7f (Water Infra.) LAKE - CYCLED STATIONS - OAKLAND, CROCKETT, CLINTON, PERSHING, Ex. 6 (Personal Privacy)	
Job Completed	JETTED LINE IN Ex. 6 (Personal Privacy) OF BATTLES TO RELIEVE BACK UP AT Ex. 6 (Personal Privacy) Ex. 6 (Personal Privacy) PER TONY. (VILLAGE TRUCK)	
Employees on Job K.M. - B.S. - G.M. J.M.	CHECKED STATIONS	
Vehicles or Equip. Used		
2-5		
Meter Readers		
Employees on Job F.P. - T.C. J.M.	FINISHED 18 & 20 - T.C.	CYCLE 4 RADIOS - F.P.
Areas - Read		
Vehicles Used 1 - DROP OFF		
General Foreman	Frank J. Pace	

Water Department		Comments
Address	W.O. / Locates	
Jobs Completed		
Employees on Job	G.F., B.S.	
Vehicles or Equip. Used	2, 3	
Sewer Department		
Address	Checked Stations Bypass pumped @ T1st & pillbox	
Job Completed	Cycled crockett, oakland, beechland, pershing & clinton stations	
Employees on Job	* Beechland needs an "on" ball *	
Vehicles or Equip. Used	2, 5	
Meter Readers		
Employees on Job	<u>Started & Finished</u> 19, 21, 22	
Areas - Read	19, 21, 22	
Vehicles Used	2	
General Foreman		

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS NO SHOW FOR LOCATE A [REDACTED] EX. 6 (Personal Privacy) LOCATED NOW	
Jobs Completed	REPLACED TWO SHUT OFFS ON DOUBLE SET AT [REDACTED] EX. 6 (Personal Privacy) EXPOSED & CRIMPED SERVICE LINE OUTSIDE BOX & REPLACED SHUT OFFS	
Employees on Job	F.P. - B.S. - K.M. G.F. 4 HR	
Vehicles or Equip. Used	3-5-14 - BACKHOE	
Sewer Department		
Address	CYCLED BLOWERS AT OAKLAND, CROCKETS, PERSHING & BEECHLAND. CYCLED PUMPS AT CLINTON & [REDACTED] EX. 6 (Personal Privacy)	
Job Completed	LOCATED MANHOLES FOR LOCATE AT [REDACTED] EX. 6 (Personal Privacy)	
Employees on Job	F.P. - B.S. - K.M.	
Vehicles or Equip. Used	REMOVED MOTOR & WIRING HARNESS FOR PUMP #1 AT SUPERIOR	
5-14 - BACKHOE		
Meter Readers		
Employees on Job	T.C. FINISHED 23, 24 & 26	
Areas - Read		
Vehicles Used	DROP OFF	
General Foreman	Frank Pace	

Water Department		Comments
Address	1-8-20	SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed		DISCONNECTED SERVICE AT CORP. STOP/MAIN AT Ex. 6 (Personal Privacy) - EXPOSED MAIN/CORP STOP & SHUT OFF CORP. STOP & CUT COPPER AT MAIN REMOVED BOX & METER SET - BACKFILLED WITH SPOIL & ONE BUCKET C-M-G FROM SHOP
Employees on Job	B.F. <u>F.P. B.S. - T.C.</u> K.M. <u>DKR</u>	REPLACED CRUSHED BOX AT Ex. 6 (Personal Privacy) USED ONE 18" X 30" P.I.C. METER BOX
Vehicles or Equip. Used	3-14 - BACKHOE	
Sewer Department		
Address		BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST & Ex. 7f (Water Infra.)
Job Completed		CYCLED BLOWERS AT OAKLAND, CROCKETTS, PERSHING & Ex. 7f (Water Infra.) CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)
Employees on Job	K.M. - <u>B.S. - T.C.</u> <u>DKR</u> <u>DKR</u>	GRADED ROAD AROUND M.H. AT 86TH & Ex. 6 (Personal Privacy) WITH ONE BUCKET OF C-M-G ROCK FROM SHOP
Vehicles or Equip. Used	5-14 - BACKHOE	PULLED MOTOR OUT & BROUGHT TO SHOP FROM #1 SUPERIOR PUMP
Meter Readers		
Employees on Job	F.P. <u>DKR</u>	FINISHED CYCLE 5 RADIO READS
Areas - Read		
Vehicles Used	1	
General Foreman <u>Frank - Pace</u>		

Comments

SERVICE TRUCK WORK ORDERS
RE-READS

Added new line under driveway at
YOCAMORE - USED 25' OF $\frac{3}{4}$ " COPPER
TUBING, ONE $\frac{3}{4}$ " FLAREX COMP. FITTING, ONE $\frac{3}{4}$ " x $\frac{3}{4}$ "

COMP. FITTING, BACKFILLED WITH SPOIL,
HAD ONE BUCKET OF DIRT & GRADED AROUND
BOX AT Ex. 6 (Personal Privacy) PKWY IN SAUGET,

5-14-3-БАКНОВЕ

CYCLAD

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

FINISHED
102 - T.C.

STARTED
29 - T.C. 2 K.M.

Front page

Water Department

Comments

Address 1-10-20	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job F.R. - Corf. 2 HR 6 HR	
Vehicles or Equip. Used 3	

Sewer Department	
Address	BY-PASS PUMPED AT 715 Ex. 71 (Water Infra.) PILL BOX TRIED TO CYCLE STATIONS BUT E. ST. LOUIS IS NOT TAKING AT 73RD Ex. 6 (Personal Privacy)
Job Completed	PULLED BY-PASS PUMP & REPAIRED DISCHARGE HOSE AT Ex. 6 (Personal Privacy)
Employees on Job F.R. - T.G. - B.S. - K.M. 6 HR 4 HR 6 HR 6 HR	SYSTEM IS BACKED UP ALL OVER DISTRICT- OAKLAND, CROCKETTS, AMES, Ex. 6 (Personal Privacy) CLINTON, PERSHING ALL OFF DUE TO BACKUP
Vehicles or Equip. Used 1-2-5-14-BACKHOE	BRIDGEALL PUMPING AGAINST HEAD,


Meter Readers	
Employees on Job B.S. - K.M. 2 HR	FINISHED 29
Areas - Read	
Vehicles Used 2	
General Foreman	Frank J. Hill

Water Department		Comments
Address	1-12-20	CALL OUT - DOUBLE TIME 2 HR.
Jobs Completed		SHUT OFF METER AT ST. CHRISTOPHER PER COST. REQUEST
Employees on Job	F.P.	
Vehicles or Equip. Used	3	
Sewer Department		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	Frank J. Pace	

Ex. 6 (Personal Privacy)

Water Department		Comments
Address	1-13-20	SERVICE TRUCK WORK ORDERS RE-READS LOCATES
Jobs Completed		
Employees on Job	F.P. - G.F. 4 HR	
Vehicles or Equip. Used	1-3	
Sewer Department		
Address		PUMPED/DIPPED OUT CANS AT OAKLAND, CROCKETTS, BEECHLAND, 63RD.
Job Completed		CHECKED BACKUP AT Ex. 6 (Personal Privacy) OUR PUMPS ARE PUMPING & LINES ARE NOT BLOCKED - DUE TO HEAVY RAIN WE THINK
Employees on Job	B.S. F.P. T.C. - K.M. 4 HR	5157 Ex. 6 (Personal Privacy) Ex. 6 (Personal Privacy) REAR ARE OFF DUE TO HEAVY RAIN/BACKUP
Vehicles or Equip. Used	1-14-5	REPLACED LID ON M.H. AT Ex. 6 (Personal Privacy) MO. - COULDN'T FIND RISER.
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Franky Pace</u>		

Water Department		Comments
Address 1-14-20	SERVICE TRUCK WORK ORDERS	
Jobs Completed		
Employees on Job G.F.		
Vehicles or Equip. Used 3		
Sewer Department		
Address	CYCLED BLOWER AT CROCKETTS WELL IS STILL UP DUE TO E. ST. LOUIS ALL STATIONS OFF NOW	
Job Completed	CYCLED STATIONS ON SOUTH SIDE TO GET SYSTEM DOWN - ALL STATIONS ON AUTO NOW.	
Employees on Job F.P. - B.S. - T.C. - K.M. JHR 4 HR	INSTALLED STARTER AT Ex. 7f (Water Infra.) Ex. 6 (Personal Privacy) STILL PUMPING TO RELIEVE BACKUP	
Vehicles or Equip. Used 1-2-14-BACKHOE	INSTALLED & WIRED MOTOR #1 AT SUPERIOR PULLEY NOT RUNNING TRUE - NEEDS TO BE LOOKED AT	
Meter Readers		
Employees on Job F.P. GHR	CYCLE & RADIO READS	
Areas - Read		
Vehicles Used 1		
General Foreman Frank J. Pace		

Water Department		Comments
Address	W.O / Locates	
Jobs Completed		
Employees on Job	G.F / B.S.	
Vehicles or Equip. Used	2, 3	
Sewer Department		
Address	Checked Stations Pumped bypass valvins Ex. 7f (Water Infra.)	
Job Completed	Cycled Ex. 7f (Water Infra.) beachland	
Employees on Job	B.S / K.M	
Vehicles or Equip. Used	2, 5	
Meter Readers		
Employees on Job	Started & Finished T.C. 3 Started 4	
Areas - Read		
Vehicles Used		
General Foreman	 1-15-20	

Water Department		Comments	
Address		W.O. / Locates	
Jobs Completed			
Employees on Job			
GF/BS			
Vehicles or Equip. Used			
2, 3			
Water Department			
Address		Check Stations	
		Bypassed 71st & Pillbox	
Jobs Completed		Cycled Ex. 7f (Water Infra.) - crockett & oakland	
		installed motor in superior	
Employees on Job			
KM/BS			
Vehicles or Equip. Used			
2, 5			
Meter Readers			
Employees on Job		Finished	Started
TP/BS		4, 5, 7	6, 8
Areas - Read			
4, 5, 6, 7, 8			
Vehicles Used			
2			
General Foreman		1-16-2020	
[Signature]			

Water Department		Comments	
Address		W.O / Locates	
Jobs Completed			
Employees on Job GF			
Vehicles or Equip. Used 3			
Sewer Department			
Address		Bypass T1st + pillbox Cycled Crockett + Oakland	
Job Completed		Check Stations	
Employees on Job KM			
Vehicles or Equip. Used 5			
Meter Readers			
Employees on Job B.S / T.C		Finished 6.8	Started 9
Areas - Read 6, 8, 9			
Vehicles Used 2			
General Foreman		1-17-20	

Ex. 6 (Personal Privacy)

Date 1-21-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	<u>SERVICE TRUCK WORK ORDERS</u>
Jobs Completed	REPAIRED RANGE LN. IN Ex. 6 (Personal Privacy) WHERE MAIN BREAK WAS REPAIRED - HAULED OFF DEBRIS & HAULED IN ROCK.
Employees on Job G.F. - B.S. - D.T. 4PR	
Vehicles or Equip. Used 3-6- BACKHOE	

Sewer Department

Address	BY-PASS PUMPS WITH 3" GAS PUMP AT 71ST Ex. 6 (Personal Privacy) BLVD.
Job Completed	CYCLED BLOWERS AT OAKLAND, CLINTON, PERSHING, CYCLED PUMPS AT 75TH Ex. 7f (Water Infra.) Ex. 6 (Personal Privacy)
Employees on Job K.M. - B.S. 4PR	
Vehicles or Equip. Used 5-2	

Meter Readers

Employees on Job	F.P.	FINISHED / DIPPED OUT F.O.W.'S AREA9 / DEFOGGED & READ METERS
Areas - Read		
Vehicles Used	1	

General Foreman	<u>Franky - Pace</u>
-----------------	----------------------

Comments

SERVICE TRUCK WORK ORDERS

TIGHTENED UP CLAMP ON 12" A.C.
TRANSMISSION LINE IN FRONT OF
(Personal Privacy) BACKFILLED ONE LOAD OF SAND + SPOIL.

F, P. - B, S. - K. M. - G, F.
2hr 2hr 2hr

3-5-14- BACKHOE

SETTLED LINE IN [REDACTED] CLARITA
TO RELIEVE BACK UP AT [REDACTED]

PULLED & CLEANED OUT RAGS FROM PUMP
#2 AT **Ex. 7f (Water Infra.)**

F.P. - B.S. - K.M.
2 Km

RE-WIRED FLOATBALL AT CENTREVILLE
Ex. 7f (Water Infra.)

K. M.
4 Apr

FINISHED
AREA 10 & F.O.W.'S

Vehicles Used
1990-1994
1995-1999
2000-2004
2005-2009
2010-2014
2015-2019
2020-2024
2025-2029
2030-2034
2035-2039
2040-2044
2045-2049
2050-2054
2055-2059
2060-2064
2065-2069
2070-2074
2075-2079
2080-2084
2085-2089
2090-2094
2095-2099
2100-2104
2105-2109
2110-2114
2115-2119
2120-2124
2125-2129
2130-2134
2135-2139
2140-2144
2145-2149
2150-2154
2155-2159
2160-2164
2165-2169
2170-2174
2175-2179
2180-2184
2185-2189
2190-2194
2195-2199
2200-2204
2205-2209
2210-2214
2215-2219
2220-2224
2225-2229
2230-2234
2235-2239
2240-2244
2245-2249
2250-2254
2255-2259
2260-2264
2265-2269
2270-2274
2275-2279
2280-2284
2285-2289
2290-2294
2295-2299
2300-2304
2305-2309
2310-2314
2315-2319
2320-2324
2325-2329
2330-2334
2335-2339
2340-2344
2345-2349
2350-2354
2355-2359
2360-2364
2365-2369
2370-2374
2375-2379
2380-2384
2385-2389
2390-2394
2395-2399
2400-2404
2405-2409
2410-2414
2415-2419
2420-2424
2425-2429
2430-2434
2435-2439
2440-2444
2445-2449
2450-2454
2455-2459
2460-2464
2465-2469
2470-2474
2475-2479
2480-2484
2485-2489
2490-2494
2495-2499
2500-2504
2505-2509
2510-2514
2515-2519
2520-2524
2525-2529
2530-2534
2535-2539
2540-2544
2545-2549
2550-2554
2555-2559
2560-2564
2565-2569
2570-2574
2575-2579
2580-2584
2585-2589
2590-2594
2595-2599
2600-2604
2605-2609
2610-2614
2615-2619
2620-2624
2625-2629
2630-2634
2635-2639
2640-2644
2645-2649
2650-2654
2655-2659
2660-2664
2665-2669
2670-2674
2675-2679
2680-2684
2685-2689
2690-2694
2695-2699
2700-2704
2705-2709
2710-2714
2715-2719
2720-2724
2725-2729
2730-2734
2735-2739
2740-2744
2745-2749
2750-2754
2755-2759
2760-2764
2765-2769
2770-2774
2775-2779
2780-2784
2785-2789
2790-2794
2795-2799
2800-2804
2805-2809
2810-2814
2815-2819
2820-2824
2825-2829
2830-2834
2835-2839
2840-2844
2845-2849
2850-2854
2855-2859
2860-2864
2865-2869
2870-2874
2875-2879
2880-2884
2885-2889
2890-2894
2895-2899
2900-2904
2905-2909
2910-2914

General Foreman Frank J. Pace

Date 1-23-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS SWAPT SHOP/BREAK ROD/CLEANED OUT BACK OF UNIT 14 IN SHOP
Jobs Completed	
Employees on Job G.F. - F.P. - B.S. T.C. 4HR 2HR 4HR	
Vehicles or Equip. Used 1-3-2 - SHOP	

Sewer Department

Address	CLEANED SUMP PUMP & PIT FOR SUMP, PRIMED PUMP #1 AT SUPERIOR - BOTH PUMPS PUMPING & ALTERNATING NOW.
Job Completed	PULLED PUMP & CLEANED OUT RAGS AT Ex. 7f (Water Infra.) - BOTH PUMPS ON & PUMPING NOW.
Employees on Job F.P. - B.S. - K.M. - T.C. 6HR 4HR	SEALED LINE TO RELIEVE BACKUP AT DELORES BYPASS PUMPED WITH 3" GAS COMP AT 71ST.
Vehicles or Equip. Used 1-5-9 - BACKHOE - 14	CYCLED BLOWERS AT CROCKETTS - OAKLAND, PERSHING - CYCLED PUMPS AT 75TH, & Ex. 7f (Water Infra.)

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	
General Foreman <u>Franky Pace</u>	

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS REMOVED METERS	
Jobs Completed		
Employees on Job F.P. - G.F.		
Vehicles or Equip. Used 1-3		
Sewer Department		
Address	DUG OFF MANHOLE/WAT WELL LID & ROTATED LID TO GET TO JUNCTION BOX FOR FLOAT BALLS, WIRED IN NEW TOP/ON BALL AT BEECHLAND	
Job Completed	WORKED ON BY-PASS PUMP FOR BLUFF - HANGER FITS LID - WE HAVE ENOUGH CHAIN BUT NEED CLEVIS TO HOOK UP - MAY NEED MORE LEAD ON PUMP - DON'T KNOW YET	
Employees on Job B.S. - T.C. - K.M.	BY-PASS PUMPED WITH 3" GAS PUMP AT LAKE PILL BOX. CHECKED STATIONS	
Vehicles or Equip. Used 2-5-14 - BACKHOE	CYCLED BLOWERS AT OAKLAND, CROCKETTS & LED PUMPS AT 15TH, & UP BUT PUMPING FULL PIPE	
Meter Readers	NEED TO PULL PUMP IN FIELD FOR RENOIS	
Employees on Job	ELECTRICIAN IS OUT OF DISCHARGE AT BLUFF	
Areas - Read		
Vehicles Used		
General Foreman	Frank J. Pace	

Ex. 7f (Water Infra.)

Ex. 7f (Water Infra.)

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Date 1-27-20

Daily Job Sheet

Sheet ___ of ___

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS LOCATES DROPPED UNIT 1 AT ALLTYPE FOR TIRE
Jobs Completed	REPAIRED SERVICE LEAK AT CAHOKIA - REMOVED SPADLE FOR INSTALLED ONE 2" C.I. S.S. REPAIR CLAMP. Ex. 7f (Water Infra.) Ex. 7f (Water Infra.)
Employees on Job F.P. - B.S. - K.M. - G.F. 6 HR 4 HR	
Vehicles or Equip. Used	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.)
Job Completed	CYCLED BLOWERS AT OAKLAND & CROCKETTS, PARSING, CYCLED PUMPS AT CLINTON Ex. 6 (Personal Privacy)
Employees on Job F.P. - B.S. K.M. 2 HR 4 HR	CHECKED FOR BACKUP AT CUSTOMER PROBLEM Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 14 - 5	WORKED ON PUMP FOR BLUFF

Meter Readers	
Employees on Job T.C.	FINISHED 11412
Areas - Read	STARTED 13
Vehicles Used DROP OFF	
General Foreman <u>Frank J. Ace</u>	

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed	MOVED BRUSH OFF METER BOXES AT FINAL READING AT Ex. 6 (Personal Privacy)	
Employees on Job G.F. - B.S. - K.M. 2 hrs		
Vehicles or Equip. Used BACKHOE - 3-14		
Sewer Department		
Address	BY-PASS PUMPED WITH 3" GAS PUMP IN FIELD FROM RENOIS TO RELIEVE SYSTEM	
Job Completed	CYCLED BLOWERS AT OAKLAND Ex. 6 (Personal Privacy) CYCLED PUMPS AT CLINTON Ex. 6 (Personal Privacy) PULLED CLEANED PUMP AT CLINTON	
Employees on Job F.P. - B.S. - K.M. 4 hrs	PULLED PUMP IN FIELD FROM RENOIS & BROUGHT TO SHOP - BREAKER IS BAD. IN CAN AT VIOLET Ex. 6 (Personal Privacy) REMOVED BREAKER	
Vehicles or Equip. Used 5-14- BACKHOE		
Meter Readers		
Employees on Job T.C.	FINISHED 13 & 14	
Areas - Read	STARTED 15	
Vehicles Used DROP OFF		
General Foreman	Frank J. Pace	

Date 1-29-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	GRADED ROCK IN ROAD AT UPPER CAHOKIA WHERE MAIN BREAK / SADDLE LEAK WAS REPAIRED, Ex. 6 (Personal Privacy)
Employees on Job C.F. - B.S. DNR	
Vehicles or Equip. Used 3 - BACKHOE	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 6 (Personal Privacy)
Job Completed	INSTALLED PLATE ON SUCTION LINE IN PILL BOX CYCLED BLOWERS AT OAKLAND CYCLED PUMPS AT CLINTON Ex. 6 (Personal Privacy)
Employees on Job F.P. - B.S. - K.M. - T.C. GHR IHR	WORKED ON DISCHARGE LINE FOR PUMP AT BLUFF - READY TO GO
Vehicles or Equip. Used 1-5-14 - BACKHOE	JETTED SPUR LINE TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy)

Meter Readers

Employees on Job T.C. 7PR	FINISHED 15, 17, 18
Areas - Read	
Vehicles Used DROP OFF	

General Foreman

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS RE-READS
Jobs Completed	REBUILT SERVICE AT Ex. 6 (Personal Privacy) CAHOKIA USED ONE METER COUPLING, ONE METER SHUTOFF, 8' OF 3/4" COPPER TUBING, ONE 18" X 30" P.I.C.
Employees on Job F.P. - B.S. - G.F. - K.M.	METER BOX, ONE RING & LID FROM SHOP. BACKFILLED WITH SPOK
Vehicles or Equip. Used 1-3-5-14-BACKHOF	

Sewer Department

Address	CYCLED BLOWERS AT OAKLAND, Ex. 7f (Water Infra.) CYCLED PUMPS AT CLINTON Ex. 6 (Personal Privacy)
Job Completed	
Employees on Job	
Vehicles or Equip. Used	
Meter Readers	
Employees on Job T.C.	FINISHED 20 & 21
Areas - Read	STARTED 22
Vehicles Used DROP OFF	
General Foreman <u>Frank f. face</u>	

Date 2-1-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	CALL OUT - DOUBT TIME
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

Sewer Department

Address	PUMP #2 AS SUPERIOR WAS RUNNING BUT WASN'T PUMPING - SWITCHED TO PUMP #1 - PUMPING & CYCLING NOW.
Job Completed	
Employees on Job	K. M. 2PM
Vehicles or Equip. Used	14

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman

Frank J. Pace

Date 2-3-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATES	
Jobs Completed	REPAIRED 2" C.I. MAIN BREAK AT MARKET - ON Ex. 6 (Personal Privacy) USED ONE 2" C.I. S.S. REPAIR CLAMP - NEEDED TO BACKFILL	
Employees on Job F.P. - T.C. - K.M. 4 HR	ROAD WITH ROCK & YARD WITH DIRT.	
Vehicles or Equip. Used 3 - 14 - BACKHOLE		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71574 Ex. 6 (Personal Privacy)	
Job Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING, CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)	
Employees on Job K.M. 4 HR		
Vehicles or Equip. Used 5		
<u>Meter Readers</u>		
Employees on Job T.C. 4 HR	FINISHED 22	
Areas - Read	STARTED 23	
Vehicles Used DROP OFF		
General Foreman	Frank J. Pace	

Date 2-4-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS

LOCATES

Jobs Completed

FILLED IN HOLE ON **Ex. 6 (Personal Privacy)**
MARKET WITH ROCK WHERE MAIN BREAK
WAS REPAIRED

Employees on Job

F.P. - B.S.
4HR 4HR

Vehicles or Equip. Used

1-14-BACKHOE

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST **Ex. 6 (Personal Privacy)**, FIELD FROM RENOIS

Job Completed

PRIMED PUMP #1 AT SUPERIOR - RAN, PUMPED
& CYCLED FOR DAY - REMOVED FLAPPER &
INSPECTED - EDGES OF RUBBER ARE WORN & FRAYED

Employees on Job

F.P. - B.S. - K.M.
4HR 6HRPRIMED PUMP AGAIN & LEFT OFF OVERNIGHT.
PUMP #2 (GORMAN ROPP) ON AUTO NOW.

Vehicles or Equip. Used

14-5-BACKHOE

CYCLED BLOWERS AT OAKLAND
CYCLED PUMPS AT **Ex. 6 (Personal Privacy)****Ex. 7f (Water Infra.)**

Meter Readers

Employees on Job

T.C. - K.M.
2HRFINISHED
23 & 26 - T.C.

Areas - Read

STARTED
19 - T.C. & K.M.

Vehicles Used

DROP
OFF & 5

General Foreman

Frank J. Pace

Date 2-5-20

Daily Job Sheet

Sheet of

<u>Water Department</u>	
Comments	
Address	SERVICE TRUCK WORK ORDERS LOCATES / RE-READS
Jobs Completed	TESTED METER AT Ex. 6 (Personal Privacy) METER TESTED GOOD
Employees on Job F.P. - B.S. - G.F. 4PM 6PM	
Vehicles or Equip. Used 2-3-14	

<u>Sewer Department</u>	
Address	BY-PASS PUMPED AT 21ST Ex. 7f (Water Infra.) CYCLED BLOWERS AT OAKLAND, CROCKETT'S, PERSHING
Job Completed	CYCLED PUMPS AT CLINTON Ex. 6 (Personal Privacy) CHECKED STATIONS
Employees on Job F.P. - B.S. - K.M. T.C. 2PM 2PM 4PM 2PM	WORKED ON SUPERIOR #1 - CHECKED PRIME IN MORNING & IT WAS GOOD - RAN PUMP DURING DAY - PUMP LOST PRIME
Vehicles or Equip. Used 14-5	SOMETIME DURING DAY - RUNNING PUMP & NOW

Meter Readers	
Employees on Job T.C. - K.M. 6PM 4PM	FINISHED 19, 142
Areas - Read	
Vehicles Used DROP OFF 5	
General Foreman	Franky - Prince

Date 2-6-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

HOOKED UP NEW LINE TO COPPER BACKSIDE
AT **Ex. 6 (Personal Privacy)** USED ONE P.V.C, 3/4" X 3/4" COMP.
FITTING - 3/4" P.V.C, FROM BOX TO HOUSE - BACKFILL
SOIL

Employees on Job

F.P. - B.S. - C.F.
4 HR

Vehicles or Equip. Used

3-14- BACKHOLE

Sewer Department

Address

CHECKED FOR BACKUP AT **Ex. 6 (Personal Privacy)**
LINES ARE HOLDING A LITTLE, BUT I THINK
IT IS COST. PROBLEM - TALKED TO COST. - I WILL
CHECK AGAIN TOMORROW AFTER RAINING

Job Completed

CHECKED HOLE IN ROAD AT **Ex. 6 (Personal Privacy)** FOR
SEWER COCCAPSE - LOCATED MANHOLES UPSTREAM &
DOWN STREAM - BOTH ARE CLEAN & FLOWING - FILLED
HOLE WITH COED PATCH

Employees on Job

F.P. - B.S.
4 HR

Vehicles or Equip. Used

14- BACKHOLE

Meter Readers

Employees on Job

T.C. - K.M.

FINISHED
AREA 29 - & F.O.W.'S

Areas - Read

Vehicles Used

5

General Foreman

Franky Pace

Date 2-7-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATED REPLACED FIRE HOSE FOR HYDRANT AT SHOP	
Jobs Completed	REBUILT SERVICE AT Ex. 6 (Personal Privacy) USED ONE 3/4" FLARE X 3/4" COMP. FITTING, ONE 18" X 5/8" METER SET, 10' OF 3/4" COPPER TUBING	
Employees on Job	ONE 18" X 30" P.V.C. METER BOX, INSTALLED NEW RADIO READ METER. BACKFILLED WITH SPOIL F.P. - B.S. - G.F. - K.M. GMR 4MR 2MR	
Vehicles or Equip. Used	CHANGED REGISTERS AT Ex. 6 (Personal Privacy) #8 & #10 3-14-BACKHOE	

<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.)	
Job Completed	CYCLED BLOWERS AT OAKLAND, CROCKETTS, PERSHING, CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)	
Employees on Job	JETTED LATERAL AT Ex. 6 (Personal Privacy) TO RELIEVE BACKUP F.P. - K.M. 2MR GMR	
Vehicles or Equip. Used	5-14-9	

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman

Frank J. Pace

Date 2-10-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	WO/Locates
Jobs Completed	
Employees on Job	
GF, BS, TC	
Vehicles or Equip. Used	

Sewer Department

Address	Bypass pumped 71st & pillbox, pittsburg checked stations
Job Completed	Cycled Ex. 6 (Personal Privacy) Clinton, crockett, oakland and pershing stations
Employees on Job	
KM, BS, TC	
Vehicles or Equip. Used	* oakland needs two new belts size B60 *

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman

[Signature]

Date 2-11-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS LOCATIONS
Jobs Completed	REPLACED HYDRANT # 1-86 AT USED NEW HYDRANT & ONE 6" MORGAN FLANGE KIT FROM SHOP, ONE BUCKET OF CLEAN ROCK
Employees on Job F.P. - B.S. - T.C. - K.M. 7 HR	BACKFILLED WITH SOIL
Vehicles or Equip. Used 5-14 - BACKHOE	

Sewer Department

Address	CYCLED PUMP AT
Job Completed	TIGHTENED BELTS AT OAKLAND
Employees on Job B.S. - T.C. - K.M. 1 HR	
Vehicles or Equip. Used 5-14	

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman Frank J. Pace

Date 2-13-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job C.F.	
Vehicles or Equip. Used 3	

Sewer Department

Address	INSTALLED NEW BREAKER IN BOX AT VIOLAT FOR PUMP IN FIELD - WIRED IN PUMP IN FIELD FROM RENOIS - CHECKED
Job Completed	VOLTAGE - 240 IN & OUT OF BREAKER & 240 IN FIELD - PUMPING WORK. MET WITH Ex. 6 (Personal Privacy) SHOWED HIM M.H. & STATIONS IN PINE HONG AREA & 73RD ST.
Employees on Job F.P. - B.S. - T.C. - K.M. GRR	CYCLED CROCKETTS, OAKLAND, CLINTON & PERSHING - EAST LOUIS MANHOLES UP AT 88ND Ex. 7f (Water Infra.) NOT TAKING SEWAGE FROM US AS NORMAL
Vehicles or Equip. Used 1-5-14-BACKHOF	RAISED FLOAT BALLS AT BEACHLAND - RR - INSTALLED TARP AT 63RD Ex. 7f (Water Infra.) BLOWN OFF BY WIND.

SEWER

Employees on Job	BY-PASSED IN FIELD FROM RENOIS TO SET PUMP.
Areas - Read	CYCLED Ex. 6 (Personal Privacy) CHECKED BACKUP WORK ORDERS
Vehicles Used	

General Foreman Frank Price

Date 2-12-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	HAULED TWO BUCKETS OF ROCK & GRADED ROAD WHERE LEAKS WERE REPAIRED ON RANGE LANE
Employees on Job F.P. - B.S. - G.F. 4HR - 3HR	
Vehicles or Equip. Used 1-14- BACKHOLE	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT CALVIN BEVS, & 2-3 HOURS AT 71ST
Job Completed	CYCLED BLOWERS AT CROCKETS, OAKLAND 3HR PERSHIAN 3HR - CYCLED PUMPS AT CLINTON 3HR
Employees on Job K.M. - T.C. - B.S. - P.P. 6HR 4HR	REMOVED OLD BLOWER & REPLACED WITH NEW BLOWER, INSTALLED BELTS AT OAKLAND
Vehicles or Equip. Used 5-14	PREPPED NEW PUMP FOR INSTALATION IN FIELD FROM RENOIS

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman Frank J. Pace

Date 2-14-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS RE-READS REMOVES
Jobs Completed	HOOKE UP BACKSIDE AT Ex. 6 (Personal Privacy) THIS WAS A 1" SERVICE HUBBED DOWN TO 3/4" WE RAN NEW 3/4" TAIL OUT OF BOX & HOOKED UP TO 3/4" P.V.C. RUN BY COST. - USED ONE 3/4" X 3/4"
Employees on Job F.P. - B.S. - K.M. 6 HR 2 HR	COMP. FITTING, 3' OF 3/4" COPPER TUBING + ONE 3/4" X 3/8" METAL COUPLING. - 3/4" P.V.C. FROM TAIL TO HOUSE - 1" COPPER IN BOX ON
Vehicles or Equip. Used 1-2-3-14-5-BACKHOE	OUR SIDE OF METER. BACKFILLED WITH SPOIL

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.)
Job Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING, CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy) - E. ST. LOUIS NOT TAKING FULLY
Employees on Job F.P. - B.S. - K.M. 2 HR 6 HR	CHECKED STATIONS
Vehicles or Equip. Used 1-5	

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman

Frank J. Price

Date 2-17-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS
REMOVES

Jobs Completed

Employees on Job

G.F. - B.S.
4 HR

Vehicles or Equip. Used

2-3

Sewer Department

Address

BY-PASS PUMPED WITH 2" GAS PUMP AT
71ST + **Ex. 6 (Personal Privacy)**

Job Completed

CYCLED BLOWERS AT CROCKETTS, OAKLAND,
PERSHING, CYCLED PUMPS AT CLINTON +
Ex. 6 (Personal Privacy)

Employees on Job

K.M.
4 HR

CHECKED FOR BACKUP AT **Ex. 6 (Personal Privacy)**
LINES DOWN CUST. PROBLEM - NO ONE HOME
F.P. & B.S.

Vehicles or Equip. Used

5

Meter Readers

Employees on Job

F.P. - K.M. - B.S.
4 HR

FINISHED
7- F.P. & B.S.

Areas - Read

STARTED
8- F.P. & B.S. 3- K.M. & F.P. ONLY
KINDERGARTEN

Vehicles Used

2-5

General Foreman

Frank J. Pace

Date 2-18-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed		
Employees on Job C.F.		
Vehicles or Equip. Used 3		
<u>Sewer Department</u>		
Address	CHECKED STATIONS E. ST. LOUIS NOT TAKING AT 73RD OR 82ND	
Job Completed	JETTED LINE TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy) - B.5 & D.T. - COULD NOT GET THROUGH - MAY BE DROP MANHOLE	
Employees on Job B.5.	CYCLED CROCKETS & Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 2-9		
<u>Meter Readers</u>		
Employees on Job GPR F.P. - K.M.	FINISHED 344 - F.P. 8 - K.M.	
Areas - Read	STARTED 5 - F.P. - 9 - K.M.	
Vehicles Used 1-5		
General Foreman <u>Frank & Lee</u>		

Date 2-17-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

LOCATES

Jobs Completed

SHUT OFF CORP. STOP AT MAIN FOR
MAPLE TREE - 6" P.V.C. MAIN, BRASS SADDLE,
& COPPER TUBING AT MAIN

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - G.F. - B.S.
4/14/20REMOVED FLARE METER COUPLING IN BOX
AT Ex. 6 (Personal Privacy) MAIN IS UNDER METER
BOX AT THIS ADDRESS

Vehicles or Equip. Used

1 - 3 - BACKHOLE

MOVED TREE LIMBS & DEBRIS OFF OF
MANHOLE AT Ex. 7f (Water Infra.) FOR JET JOB.Sewer Department

Address

BY-PASS PUMPED FROM M.H. TO M.H.
AT Ex. 6 (Personal Privacy)

Job Completed

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST Ex. 7f (Water Infra.) & 63RD Ex. 7f (Water Infra.)

Employees on Job

B.S. - K.M.
4/14/20CYCLED BLOWERS AT CROCKETTS, OAKLAND,
PERSHING, CYCLED PUMPS AT CLINTON &
Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

5 - BACKHOLE

Meter Readers

Employees on Job

T.C.

FINISHED

546 - T.C.

Areas - Read

Vehicles Used

DRO P
OFF

General Foreman

Franky Rose

Date 2-20-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

SHUT OFF SERVICE AT MAIN AT
Ex. 6 (Personal Privacy) - NEED TO REPLACE PVC
SERVICE LINK (PROBE HOLE IN LINK 3' OUTSIDE
BOX

Employees on Job

F.P. - G.F. - T.C. - K.M.
7HR 2HR 4HR

Vehicles or Equip. Used

1-3-14-BACKHOLESewer Department

Address

CYCLED BLOWER AT CROCKETTS
CYCLED PUMP ATEx. 6 (Personal Privacy)

Job Completed

CHECKED STATIONS - E. ST. LOUIS
STILL NOT TAKING FULLY AT
73RDEx. 7f (Water Infra.)

Employees on Job

K.M.
4HR

Vehicles or Equip. Used

5

Meter Readers

Employees on Job

F.P. - T.C.
1HR 6HRFINISHEDPIT METERS - F.P.9410 - T.C.

Areas - Read

Vehicles Used

1-DROP
OFF

General Foreman

Franky Pace

Date 2-21-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS R.F. Tested meters throughout district
Jobs Completed	Swept Break Room & Shop & CLEANED OUT TRUCKS
Employees on Job F.P. - G.F. J.H.D. T.C. G.H.R. T.H.R.	
Vehicles or Equip. Used 1-3-	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST. Ex. 7f (Water Infra.) & CALVIN BLVD.
Job Completed	JETTED LINE TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy) SYSTEM DRAINING SLOW - MAY NEED TO JET AGAIN AT A LATER DATE
Employees on Job F.P. K.M. - T.C. - D.T. G.H.R. I.H.R.	CHECKED SOME STATIONS ON BOTH ENDS E. ST. LOUIS STILL NOT TAKING FULLY
Vehicles or Equip. Used 1-5-9	CYCLED BLOWERS AT OAKLAND, CROCKETT, PERSHING, CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	
General Foreman <u>Frank J. Lee</u>	

Date 2-24-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
LOCATES
REPLACED BAD REGISTERS

Jobs Completed

DUG OFF RING & REMOVED METER AT
Ex. 6 (Personal Privacy)

Employees on Job

F.P. - G.F. - T.C.

CRIMPED OFF SERVICE LINE IN BOX &
REPLACED LEAKING SHUT OFF AT
Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

1-3-14

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST Ex. 7f (Water Infra.)

Job Completed

CYCLD BLOWERS AT CROCKFITS, OAKLAND,
PERSHING - CYCLD PUMPS AT CLINTON &
Ex. 6 (Personal Privacy)

Employees on Job

K.M.

CHECKED STATIONS - E. ST LOUIS STILL
BACKED UP AT 73RD Ex. 7f (Water Infra.)

Vehicles or Equip. Used

5

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Franky Pace

Date 2-25-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed	REPLACED BAD REGISTERS DID R.F. TESTS
Employees on Job F.P. - T.C. - G.E. 4 HR	
Vehicles or Equip. Used 3-14	

Sewer Department

Address	WORKED WITH E. ST. LOUIS TRYING TO FIND MAN HOLES BETWEEN 73RD + 69TH DIDN'T FIND MAN HOLES - TESTED AT 73RD
Job Completed	BUT DIDN'T REACH BLOCK CHECKED STATIONS AT 63RD + Ex. 7f (Water Infra.)
Employees on Job K.M. - F.P. - T.C. 6 HR 4 HR	BY-PASS PUMPED WITH 3" GAS PUMP AT LINDORF Ex. 7f (Water Infra.)
Vehicles or Equip. Used 5-14	CYCLED CROCKETS BUT WALL STILL UP

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman Frank & Rose

Date 2-26-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS SHUT OFFS
Jobs Completed	
Employees on Job Gif. K.M. 2HR	
Vehicles or Equip. Used 3-5	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST & Ex. 7f (Water Infra.) ; LINDORF
Job Completed	CYCLED BLOWERS AT OAKLAND, CROCKETTS & PERSHING, CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy) E. ST. LOUIS STILL NOT TAKING
Employees on Job F.P. - T.C. - K.M. 6HR	WORKED WITH E. ST. LOUIS TO FIND MAN HOLES ALONG STATE ST. BETWEEN Ex. 7f (Water Infra.) 73RD - FOUND ONE - ITS DOWN & FLOWING.
Vehicles or Equip. Used 14-5 - BACKHOLE	

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman Frank J. Pace

Date 2-27-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job K.M. 4 hr	
Vehicles or Equip. Used 3	

Sewer Department

Address	WORKED WITH R. ST. LOUIS TO FIND MANHOLES & JRT LINE SOUTH OF STATE ST. SETTLED LINE & SYSTEM STARTED DROPPING.
Job Completed	CYCLED CROCKETTS STATION FOR 2 HRS. & WRT WALL DROPPED ABOUT 3-4 FEET. CHECKED M.H.'S ON 88ND ST. & THEY
Employees on Job F.P. - T.C. - K.M. 4 hr	ARE MOVING LIKE THE SYSTEM IS DRAINING - STILL GETTING BACKFLOW AT BELLVIEW & WELL IS STILL UP.
Vehicles or Equip. Used 5-14- BACKHOE	

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman Frank J. Pace

Date 3-2-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address	<u>SERVICE TRUCK WORK ORDERS</u> <u>LOCATES</u>
Jobs Completed	
Employees on Job <u>G.F.</u>	
Vehicles or Equip. Used <u>3</u>	

Sewer Department

Address	<u>BY-PASS PUMPED WITH 3" GAS PUMP AT</u> <u>71ST & LINDORF</u> <u>CYCLED OAKLAND, CROCKETT, CLINTON, PERSHINE</u>
Job Completed	<u>WORKED WITH HANKS SETTING & CUTTING LINES</u> <u>ON 88ND</u> <u>JETTED LINE TO RELIEVE BACKUP AT 30</u> <u>(HANKS)</u>
Employees on Job <u>F.P. - B.S. - K.M.</u>	<u>REMOVED 1 H.P. PUMP FROM BELLVIEW &</u> <u>REPLACED WITH NEW 2 H.P. PUMP - PUMPING</u> <u>NOW - WALL WAS DROPPING SLOWLY</u>
Vehicles or Equip. Used <u>5-14- BACKHOLE</u>	

Meter Readers

Employees on Job <u>T.C.</u>	<u>FINISHED</u> <u>12-13-14</u>
Areas - Read	<u>STARTED</u> <u>15</u>
Vehicles Used <u>DROP</u> <u>OFF</u>	

General Foreman Frank P. Price

Date 3-3-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address	<u>SERVICE TRUCK WORK ORDERS</u> <u>LOCATES</u>
Jobs Completed	EXPOSED MAIN & TURNED ON CORP STOP & AT INSTALLED METER AT Ex. 6 (Personal Privacy) - AT Ex. 6 (Personal Privacy) - BOTH IN & ON.
Employees on Job G.F. - F.P. - B.S. 4 HR	REPLACED RE-SETER AT Ex. 6 (Personal Privacy) WHEN TURNING ON BOTTOM SHUT OFF PIPE BROKE BELOW GROUND - NEEDS REBUILT
Vehicles or Equip. Used 3-14-BACKHOLE	CYCLED BLOWERS AT OAKLAND CROCKETTS & PERSHING, CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)

Sewer Department

Address	CHECKED SEWERS ON 82ND Ex. 6 (Personal Privacy) BELCHING BACK & LINES ARE FULL BUT SOME IS GETTING THROUGH - WELL DOWN 3'-4'
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 82ND & Ex. 7f (Water Infra.)
Employees on Job K.M. - F.P. - B.S. 4 HR	PULLED PUMP #1 & CLEANED OUT RAGS AT CRESTON - PUMPING, CYCLING & ALTERNATING NOW.
Vehicles or Equip. Used 1-5-14-BACKHOLE	

Meter Readers

Employees on Job T.C.	FINISHED 15 & 17
Areas - Read	STARTED 18
Vehicles Used DROP OFF	

General Foreman Franky Rose

Date 3-4-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed	REPLACED O-RING & BREAK AWAY FLANGE ON HYDRANT #1-161 (IN PARK BY GOLF COURSE)
Employees on Job G.F. - F.P. - B.S. 4 HR	
Vehicles or Equip. Used 3-14 - BACKHOLE	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST & Ex. 7f (Water Infra.) & 82ND, Ex. 7f (Water Infra.)
Job Completed	CYCLED BLOWERS AT OAKLAND, CROCKETTS, PERSHING - CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)
Employees on Job K.M. - F.P. - B.S. 4 HR	VACUMED OFF SOLIDS AT BLUFF & HUNG & WIRED IN BY-PASS PUMP AT BLUFF - NEED TO SECURE DISCHARGE LINE IN WELL.
Vehicles or Equip. Used 5-14-9 - BACKHOLE	JEKED LINE AT HAZEL & Ex. 6 (Personal Privacy)

Meter Readers

Employees on Job T.C. 4 HR	FINISHED 18
Areas - Read	
Vehicles Used DROP OFF	
General Foreman Frank J. - Pace	

Date 3-5-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	REPLACED BROKEN METER SHUT OFF & METER BOX AT Ex. 6 (Personal Privacy) - EXPOSED MAIN/TAP & SHUT OFF CORR. STOP. REPLACED
Employees on Job <u>G.F. - F.P. - B.S. - K.M.</u> 4 MR	METER SHUT OFF & BOX - BACKFILLED WITH SPOIL.
Vehicles or Equip. Used	
3-5-14- BACKHOLE	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 82ND & Ex. 7f (Water Infra.) BLVD.
Job Completed	SECURED BY-PASS PUMP DISCHARGE LINE AT 82ND & Ex. 7f (Water Infra.)
Employees on Job <u>F.P. - B.S. - K.M.</u> 4 MR	BY-PASS PUMPS AT BELLEVUE & Ex. 7f (Water Infra.) BOTH PUMPING NOW - BOTH ARE BECHING BACK WATER - WELLS ARE HOLDING 3'-4' DOWN
Vehicles or Equip. Used	CYCLED CROCKETS, OAKLAND, Ex. 6 (Personal Privacy)
5-14- BACKHOLE	

Meter Readers

Employees on Job	T.C.	FINISHED
		20, 21, & 22

Areas - Read

Vehicles Used

DROP OFF

General Foreman

Frank J. Rice

Date <u>3-6-20</u>		Daily Job Sheet		Sheet <u> </u> of <u> </u>	
<u>Water Department</u>			<u>Comments</u>		
Address		SERVICE TRUCK WORK ORDERS LOCATES			
Jobs Completed		INSTALLED TWO OUT OF 3 ANTENNAS AT Ex. 6 (Personal Privacy) NEED TO PUMP BOX OUT TO CONNECT THIRD ANTENNA TO METER,			
Employees on Job					
G.F. - F.P. - B.S. 2 PNE					
Vehicles or Equip. Used					
3-14					
<u>Sewer Department</u>					
Address		BY-PASS PUMPED WITH S4 GAS PUMP AT 71ST Ex. 7f (Water Infra.) & 80ND ST. CYCLED CARLAND CROCKETS, PERSHING, CLINTON Ex. 6 (Personal Privacy)			
Job Completed		VACUMED SOLIDS OFF AT Ex. 6 (Personal Privacy) DUMPED LOAD AT STOOKY			
Employees on Job		LOCATED MANHOLE & LAMPHOLE IN ALLEY BEHIND Ex. 6 (Personal Privacy) TO SEE IF THEY CAN TAP INTO MAIN - THEY CAN BUT IT IS A LONG RUN & ELEVATION CONCERNS			
Vehicles or Equip. Used		CHECKED STATIONS - NEED TO PULL & CLEAN PUMP AT CLINTON - ONLY PUMPING HALF PIPE OR SO.			
5-14 - BACKHOE					
Meter Readers					
Employees on Job		T.C. FINISHED 23-24-26			
Areas - Read					
Vehicles Used		DROP OFF			
General Foreman		Frank J. Pace			

Date 3-9-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address

W.O / Locates

Jobs Completed

Employees on Job

GF

Vehicles or Equip. Used

3

Sewer Department

Address

Cycled Ex. 6 (Personal Privacy), Clinton, Pershing, Oakland,
Clinton, Bellevue & Bluff

Job Completed

Pulled, cleared & Replaced 82nd Ex. 7f (Water Infra.)
Started bypass @ 71st, Bypassed 82nd st.

Employees on Job

KM, BS, TC

Vehicles or Equip. Used

Backhoe, 5, 14

Meter Readers

Employees on Job

BS, TC

Finished
19Started
29


Areas - Read

19, 29

Vehicles Used

2

General Foreman



Date 3-10-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	W.O. / Locates	
Jobs Completed		
Employees on Job	GF, B.S., T.C.	
Vehicles or Equip. Used	2, 3	
<u>Sewer Department</u>		
Address	Bypassed 71 st + 82 nd	
	Cycled Stations	
Job Completed	Filled hole on Grandview	
Employees on Job	KM, BS	
Vehicles or Equip. Used	2, 5, Backhoe	
Meter Readers		
Employees on Job	Finished	
	1, 2, 29	
Areas - Read	1, 2, 29	
Vehicles Used		
General Foreman <u>Rafael</u>		

Date 3-11-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	RE-BUILT SERVICE AT Ex. 6 (Personal Privacy) USED ONE 3/4" FLARE X COMP. FITTING, ONE 3/4" X 3/4" COMP. FITTING, ONE METER COUPLING, ONE METER
Employees on Job G.F. - <u>F.P. - B.S. - T.C.</u> 4 HR	SHOT OFF, ONE 18" X 30" P.V.C. METER BOX & 12' OF 3/4" COPPER TUBING - BACKFILL WITH SOIL. COPPER FROM MAIN TO METER & METER TO HOUSE
Vehicles or Equip. Used 3-14 - BACKHOLE	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) & 82ND ST.
Job Completed	CYCLD STATIONS - CROCKETTS, OAKLAND, PERSHING, CLINTON, Ex. 6 (Personal Privacy)
Employees on Job K.M. - <u>F.P. - B.S. - T.C.</u> 4 HR	PULLED & CLEANED OUT PUMPS AT 82ND Ex. 7f (Water Infra.) & CLINTON
Vehicles or Equip. Used 5-14 - BACKHOLE	

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman Frank J. Ace

Date 3-12-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS <u>LOCATES</u>
Jobs Completed	REBUILT FRONT SIDE OF SERVICE TO REPLACE OLD SIDE SHUTOFF - USED ONE METER SHUT OFF & ONE 18" X 30" P.V.C. METER BOX AT
Employees on Job G.F. - F.P. - B.S. - T.C. 6 HR	Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 3-14-1-2 - BACKHOE	SWAPT SHOP - T.C. 2 HR

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 82ND ST., CALVIN BLVD, & 63RD Ex. 7f (Water Infra.)
Job Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING - CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)
Employees on Job K.M. - T.C. 2 HR	
Vehicles or Equip. Used 5	

Meter ReadersEmployees on JobAreas - ReadVehicles UsedGeneral Foreman Frank J. Pace

Date 3-13-20

Daily Job Sheet

Sheet ___ of ___

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed	
Employees on Job F.P.	
Vehicles or Equip. Used 3	

Sewer Department

Address	BY-PASS PUMPS WITH 3" GAS PUMP AT 71ST & 82ND ST. Ex. 7f (Water Infra.)
Job Completed	CYCLD BLOWERS AT CROCKETTS, OAKLAND, PERSHING - CYCLD PUMPS AT CLINTON & Ex. 6 (Personal Privacy)
Employees on Job B.S. - K.M.	CHECKED STATIONS - NEED TO PULL & CLEAN RENCOIS & Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 2-5	

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 3-16-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job F.P. - B.S. - 2 HR	
Vehicles or Equip. Used -14- BACKHOF	

Sewer Department

Address	BY-PASS PUMPED AT 71ST & Ex. 7f (Water Infra.) CYCLED CROCKETTS, OAKLAND, CLINTON, PERSHING, & Ex. 6 (Personal Privacy)
Job Completed	PULLED PUMP IN FIELD FROM RENOIS, CLANED & TOOK TO SHOP PULLED PUMP BEHIND Ex. 6 (Personal Privacy) & ADJUSTED FLOAT BALL - PUMPING NOW.
Employees on Job F.P. - B.S. - T.C. - K.M. 6 HR 4 HR	PULLED #1 PUMP AT Ex. 7f (Water Infra.) CLEANED PUMPING NOW.
Vehicles or Equip. Used 5-14- BACKHOF	

Meter Readers

Employees on Job T.C. - K.M. 9 HR	PUMPED OUT VAULTS WITH 2nd PUMP & READ METERS TO FINISH AREA 3
Areas - Read	STARTED AREA 3
Vehicles Used	

General Foreman Frank J. Rice

Date 3-17-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS R.F. TESTED METERS
Jobs Completed	REPLACED TAIL LIGHT ON UNIT 14
Employees on Job F.P. - B.S. 6 HR 4 HR	
Vehicles or Equip. Used 3-2	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 82ND & Ex. 7f (Water Infra.)
Job Completed	
Employees on Job F.P. - B.S. 2 HR 4 HR	
Vehicles or Equip. Used 14-5	

Meter Readers

Employees on Job T.C.	FINISHED 3 & 4
Areas - Read	STARTED 5
Vehicles Used DROP OFF	
General Foreman Frank J. Rice	

Date 3-18-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address	<u>SERVICE TRUCK WORK ORDERS</u> <u>RE-READS</u>
Jobs Completed	
Employees on Job <u>F.P. - B.S.</u> <u>4 HR</u>	
Vehicles or Equip. Used <u>2-3</u>	

Sewer Department

Address	<u>BY-PASS PUMPER WITH 3" GAS PUMP AT</u> <u>71ST & Ex. 7f (Water Infra.)</u>
Job Completed	<u>CYCLED BLOWERS AT CROCKETTS, OAKLAND,</u> <u>PERSHING. CYCLED PUMPS AT ECINTON &</u> <u>Ex. 6 (Personal Privacy)</u>
Employees on Job <u>B.S.</u>	
Vehicles or Equip. Used <u>5</u>	

Meter Readers

Employees on Job <u>F.P. - T.C.</u> <u>4 HR</u>	<u>FINISHED F.P. & T.C.</u> <u>5 - (A.M.)</u>
Areas - Read	<u>STARTED</u> <u>6 - T.C.</u>
Vehicles Used <u>1 & DROP OFF</u>	

General Foreman Franky Pace

Date 3-19-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS
	RE-READS
	INSTALLED REGISTERS ON R.R. METERS
Jobs Completed	CLEANED BREAKROOM/SHOP
Employees on Job F.P. - B.S. - K.M. - T.C. 2MR 4MR 6MR	
Vehicles or Equip. Used 3-2-14	

Sewer Department

Address	INSTALLED PUMP IN FIELD FROM RENOIS
Job Completed	CHECKED SEWER BACKUP WORK ORDERS - PUMPS ARE PUMPING - DUE TO HEAVY RAIN
Employees on Job B.S. - K.M. - T.C. 4MR 4MR 2MR	STREET COLLAPSING ON 63RD
Vehicles or Equip. Used 5-14 - BACKHOLE	

Ex. 6 (Personal Privacy)

Meter ReadersEmployees on JobAreas - ReadVehicles UsedGeneral ForemanFranky Pace

Date 3-20-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	REPLACED REGISTERS
Employees on Job F.P. - B.S.	
Vehicles or Equip. Used 2-3	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST & Ex. 7f (Water Infra.) CALVIN BLVD.
Job Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING, - CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)
Employees on Job K.M.	
Vehicles or Equip. Used 5	

Meter ReadersEmployees on JobAreas - ReadVehicles Used

General Foreman

Frank J. Pace

Water Department		Comments
Address	<u>SERVICE TRUCK WORK ORDERS</u> <u>R.P. TESTS</u> <u>LOCATES</u>	
Jobs Completed		
Employees on Job G.P. - F.P. JNR		
Vehicles or Equip. Used 3-14		
Sewer Department		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST & Ex. 7f (Water Infra.)	
Job Completed	CYCLED BLOWERS AT OAKLAND, CROCKETTS, PERSHING, CYCLED PUMPS AT CLINTON, Ex. 6 (Personal Privacy)	
Employees on Job F.P. - B.S. - K.M. GMR 4MR	WORKED AT RILL BOX ON PAPER BOX - M.H. DIAM. 22 3/4" <u>CHECKED STATIONS</u>	
Vehicles or Equip. Used 2-5-14		
Meter Readers		
Employees on Job K.M. 4MR	FINISHED 7	
Areas - Read	STARTED 8	
Vehicles Used 5		
General Foreman <u>Franky Lee</u>		

Date 3-24-20

Daily Job Sheet

Sheet of

Water Department	
Comments	
Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	REPLACED METER SHUT OFF & INSTALLED RE-SATPER AT Ex. 6 (Personal Privacy) USED ONE METER SHUT OFF, ONE 18" X 30" P.V.C. METER
Employees on Job G.F. - <u>F.P. - B.S.</u> 4 HR	BOX - BACKFILLED WITH SPOIL & 1 BUCKET OF SAND FROM SHOP, INSTALLED RADIO READ METER - COPPER FROM METER TO HOUSE & COPPER FROM MAIN TO METER
Vehicles or Equip. Used 3-14 - BACKHOLE	

Sewer Department	
Address	CYCLED BLOWERS AT OAKLAND, CROCKETTS PERSHING - CYCLE PUMPS AT CLINTON & Ex. 6 (Personal Privacy)
Job Completed	INSTALLED FLAPPER ON PUMP #1 AT SUPERIOR - COULDN'T GET PRIMED
Employees on Job <u>F.P. - B.S.</u> 4 HR	
Vehicles or Equip. Used 2-14	

Meter Readers	
Employees on Job K.M.	FINISHED 8
Areas - Read	STARTED 9
Vehicles Used 5	
General Foreman <u>Frank - Pace</u>	

Date 3-25-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address		SERVICE TRUCK WORK ORDERS
Jobs Completed		
Employees on Job G.H.		
Vehicles or Equip. Used 3		

<u>Sewer Department</u>		
Address		BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) & PITTSBURGH, CALVIN BLVD.
Job Completed		CYCLAD BLOWERS AT CROCKETTS, OAKLAND, PERSHING, CYCLAD PUMPS AT CLINTON Ex. 6 (Personal Privacy)
Employees on Job K.M.		SUPERIOR IS GOOD - NEEDS SUMP PUMP
Vehicles or Equip. Used 5		

Meter Readers		
Employees on Job F.P.-B.S.		FINISHED 6 FOW.S - 10-B.S. 9-F.P.
Areas - Read		
Vehicles Used 1 & 2		

General Foreman	<u>Frank J. Boel</u>
-----------------	----------------------

Date 3-26-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address	<u>SERVICE TRUCK WORK ORDERS</u> <u>LOCATES</u>	
Jobs Completed		
Employees on Job <u>C.O.F.</u>		
Vehicles or Equip. Used <u>3</u>		

Sewer Department		
Address	<u>REMOVED SUMP PUMP FROM</u> <u>INSTALLED IT AT SUPERIOR</u>	
Job Completed	<u>WASHED OUT RILL BOX ON TISTO</u> <u>REMOVED WIRING FROM PANEL BOX</u>	
Employees on Job <u>F.P. - B.S.</u>	<u>CYCLED BLOWERS AT OAKLAND, CROCKETS,</u> <u>PERSHING, CYCLED PUMPS AT CLINTON</u>	
Vehicles or Equip. Used <u>1-2-14</u>		

Meter Readers		
Employees on Job <u>K.M.</u>	<u>FINISHED</u> <u>11412</u>	
Areas - Read	<u>STARTED</u> <u>13</u>	
Vehicles Used <u>5</u>		

General Foreman	<u>Fronk - Pace</u>	
-----------------	---------------------	--

Date 3-27-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERSLOCATES

Jobs Completed

Employees on Job

G.F. - F.P.
SWR

Vehicles or Equip. Used

1-3Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP
AT 71ST + 82ND**Ex. 7f (Water Infra.)**

Job Completed

CYCLED BLOWERS AT OAKLAND, CROCKETTS,
PERSHING, CYCLED PUMPS AT CLINTON**Ex. 6 (Personal Privacy)**

Employees on Job

B.S. - K.M.
4HR

Vehicles or Equip. Used

2-5

Meter Readers

Employees on Job

F.P. - K.M.
6HR 4HRFINISHED13414 - K.M.15 - F.P.

Areas - Read

Vehicles Used

1-2

General Foreman

Frank J. Pace

Date 3-30-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed		
Employees on Job G.F. 4HR		
Vehicles or Equip. Used 3		
Sewer Department		
Address	BY-PASS PUMPS WITH 3" GAS PUMP AT 71ST & Ex. 7f (Water Infra.) & BLUFF	
Job Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND & PERSHING, CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)	
Employees on Job B.S. - K.M.	CHECKED STATIONS - BLOCKED LINE ON BATES - NEEDS JETTED.	
Vehicles or Equip. Used 2-5	LOCATORS	
Meter Readers		
Employees on Job F.P. - G.F. 4HR	FINISHED 17218	
Areas - Read		
Vehicles Used 1-3		
General Foreman <u>Franky Pace</u>		

Date 3-31-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATES SMART SHOP	
Jobs Completed	R.F. TESTED RADIO BOXES. WIRED BOX IN AT Ex. 6 (Personal Privacy) BUT METER WOULDN'T R.F. TEST. - THINK WE NEED NEW BOX.	
Employees on Job	C.F. I.C. - <u>Phil-BB</u> 4 HR <u>ONE</u>	
Vehicles or Equip. Used	3-2-1	

<u>Sewer Department</u>		
Address	JACKETED LINE IN Ex. 6 (Personal Privacy) BATHS TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy) Ex. 6 (Personal Privacy)	
Job Completed	JACKETED LATERAL TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy) CHECKED BACKUP AT COST PROBLEM	
Employees on Job	D.T. K.M. - <u>E.P. - B.S. - T.C.</u> 6 HR <u>4 HR</u>	
Vehicles or Equip. Used	BY-PASS PUMPED WITH 3" GAS PUMP AT 82ND Ex. 7f (Water Infra.) CYCLED CROCKETS OAKLAND, CLINTON, PERSHING, Ex. 6 (Personal Privacy) CHANGED ON EN BLOWERS AT CROCKETS & Ex. 7f (Water Infra.)	

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman Franky Pace

Date 4-1-00

Daily Job Sheet

Sheet of

Water Department		Comments
Address		SERVICE TRUCK WORK ORDERS
Jobs Completed		REBUILT SERVICE AT Ex. 6 (Personal Privacy) & CHANGED DEAD METER TO RADIO READ METER USED ONE 3/4" X 3/4" COMP. FITTING, ONE METER SHOT OFF, ONE METER COUPLING, 4' OF 3/4"
Employees on Job G.P. - F.P. - B.B.		COPPER TUBING, ONE 12" X 30" S.V.C. METER BOX BACKFILLED WITH SPOIL. + COPPER FROM MAIN TO METER, COPPER FROM HOUSE TO METER
Vehicles or Equip. Used 3-14-BACKHOL		CUT 4" CLAY RISER AT SHOP & RAISED BOX AT Ex. 6 (Personal Privacy) HAULLED IN ONE BUCKET OF DIRT, RAKED OUT & SEEDED & STRAWED YARD WHERE MAIN BREAK WAS REPAIRED AT Ex. 6 (Personal Privacy)

Sewer Department	
Address	
BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST. Ex. 7f (Water Infra.) 82ND Ex. 7f (Water Infra.)	
Job Completed	
CYCLED BLOWERS AT CROCKFORDS, OAKLAND & PERSHING, CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)	
Employees on Job K.M. - T.C.	
Vehicles or Equip. Used 5	

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman

Frank J. Pace

Date 4-2-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F. - F.P. 2 PM 2 PM	
Vehicles or Equip. Used	

Sewer Department

Address	BY-PASS PUMPS WITH 3" GAS PUMP AT 71ST & Ex. 7f (Water Infra.) BLUFF
Job Completed	CYCLAD BLOWERS AT CROCKETTS, OAKLAND, PRESHING, CYCLAD PUMPS AT CLINTON & Ex. 6 (Personal Privacy)
Employees on Job F.P. K.M. - B.S. 2 PM 2 PM 6 PM	
Vehicles or Equip. Used 5-1	

Meter Readers

Employees on Job T.C. ^{B.S.} 2 PM 2 PM 4 PM	STARTED 20 F.P. - 24-T.C.
Areas - Read	FINISHED 23-T.C. 19-F.P.-B.S.
Vehicles Used 1- DROP OFF	
General Foreman	Franky. Pace

Date 4-3-20

Daily Job Sheet

Sheet 1 of 1Water Department

Comments

Address	Service TRUCK
Jobs Completed	
Employees on Job BS	
Vehicles or Equip. Used	

Sewer Department


Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers	
Employees on Job BS	
Areas - Read	24-26
Vehicles Used	3
General Foreman	B. Smith

Date 4-6-20


Daily Job Sheet

Sheet 1 of 1

<u>Water Department</u>		Comments
Address		Service TRUCK
Jobs Completed		LOCATES
Employees on Job BS		
Vehicles or Equip. Used 3		
<u>Sewer Department</u>		
Address		PUMPED 71ST
Job Completed		
Employees on Job		
Vehicles or Equip. Used 5		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman		

Water Department	Comments
Address	Service TRUCK
Jobs Completed	
Employees on Job BS	
Vehicles or Equip. Used 3	

Sewer Department	
Address 50 TH ST	Jetted Line
Job Completed	
Employees on Job BS	
Vehicles or Equip. Used VAC - 14	

Meter Readers	
Employees on Job BS	
Areas - Read 20 - 21	
Vehicles Used 3	
General Foreman	

Date _____

Daily Job Sheet

Sheet 1 of 1Water Department

Comments

Address

WORK orders

Jobs Completed

Employees on Job

BS

Vehicles or Equip. Used

3

Sewer Department

Address

50TH ST

TURNED STATION ON

Job Completed

Pumped Ex. 7f (Water Infra.) ON HAND
for 30 mins

Employees on Job

BS

Vehicles or Equip. Used

3

Meter Readers

Employees on Job

BS


Areas - Read

22

Vehicles Used

3

General Foreman



Date 4-9-20

Daily Job Sheet

Sheet 1 of 1Water Department

Comments

Address	Service TRUCK
Jobs Completed	
Employees on Job BS	
Vehicles or Equip. Used 3	

Sewer Department

Address	Pumped 71ST RAN BLOWERS
Job Completed	Re-SET STARTER AT SUPERIOR
Employees on Job	Helped HANKS AT 50TH ST
Vehicles or Equip. Used	

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman _____

Water Department		Comments
Address		
Jobs Completed	HOL DAY	
Employees on Job		
Vehicles or Equip. Used		
Sewer Department		
Address		
Job Completed	GOOD	
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job	FRIDAY	
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Lee</u>		

Date 4-10-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	CALL OUT DOUBLE TIME	
Jobs Completed		
Employees on Job		
Vehicles or Equip. Used		
<u>Sewer Department</u>		
Address	PULLED BACK OFF PUMP #20 CLEANED OUT RAGS AT SUPERIOR PUMPING FULL PIPE NOW.	
Job Completed	CHECKED FOR BACKUP ON CUREH RD. OUR PUMPS ARE PUMPING & WELL WAS DOWN AT	
Employees on Job	F.P. - B, S, 2.5 HR 2 HR	
Vehicles or Equip. Used	1-14	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	Frank J. Pace	

Ex. 6 (Personal Privacy)

Date 4-13-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

Employees on Job

F.P.
2 HR

Vehicles or Equip. Used

3

Sewer Department

Address

BY-PASS PUMPED WITH 24 GAS PUMP AT
71ST & Ex. 7f (Water Infra.)
CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)

Job Completed

CYCLED BLOWERS AT OAKLAND, CROCKETTS
& PERSHING

Employees on Job

F.P. - B.S.
6 HR

PULLED BOTH PUMPS & CLEANED OUT RAGS
AT CRESTON, PUMP #2 NOT PUMPING
LIKE IT SHOULD.

Vehicles or Equip. Used

5-14- BACKHOLE

PULLED BOTH PUMPS & CLEANED OUT RAGS
AT Ex. 7f (Water Infra.) PUMPING NOW

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 4-14-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS RD - READS	
Jobs Completed		
Employees on Job F.P. - B.S. 1 PR 1 PR		
Vehicles or Equip. Used 1-3		
Sewer Department		
Address	JETTED LINE TO RELIEVE BACKUPS AT Ex. 6 (Personal Privacy)	
Job Completed	CYCLED PUMP AT Ex. 6 (Personal Privacy)	
Employees on Job D.T. - F.P. - B.S. 1 PR		
Vehicles or Equip. Used 1-14-9		
Meter Readers		
Employees on Job F.P. - B.S. 6 PR	FINISHED 122 - B.S. 29 F.P. & B.S.	
Areas - Read		
Vehicles Used 1-2		
General Foreman	Frank J. Pace	

Water Department		Comments
Address	SERVICE TRUCK WORK READS LOCATES RR-READS	
Jobs Completed	REMOVED METERS	
Employees on Job		
F.P. B.S. 4HR		
Vehicles or Equip. Used		
1-3		

Sewer Department		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.)	
Job Completed	CYCLED BLOWERS AT CROCKETT, OAKLAND PERSHING - CYCLED PUMPS AT CLINTON + Ex. 6 (Personal Privacy)	
Employees on Job	B.S. 4HR NERD TO PULL PUMP AT BLUFF - NOT PUMPING - TURNED OFF	
Vehicles or Equip. Used		
5		

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman	Frank J. Face
-----------------	---------------

Date 4-16-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address		SERVICE TRUCK WORK ORDERS
Jobs Completed		
Employees on Job F.P. 1 PR		
Vehicles or Equip. Used 1		
Sewer Department		
Address		PULLED PUMP & CLEANED OUT RAGS AT 82ND Ex. 7f (Water Infra.) DUMPING NOW
Job Completed		CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING; CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)
Employees on Job F.P. - B.S. 2 PR		
Vehicles or Equip. Used 14 - BACKHOE		
Meter Readers		
Employees on Job F.P. B.S. 5 PR 6 PR		FINISHED 3 - F.P. 7-10 - B.S.
Areas - Read		STARTED 8 B.S.
Vehicles Used 1-2		
General Foreman <u>Frank J. Pace</u>		

Date 4-20-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

Employees on Job

B.S.
1 HR

Vehicles or Equip. Used

3

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP
AT 71ST Ex. 7f (Water Infra.)

Job Completed

CYCLED BLOWERS AT OAKLAND, CROCKETT,
PERSHING, CYCLED PUMPS AT CLINTON,
BLUFF, Ex. 6 (Personal Privacy)

Employees on Job

B.S.
3 HR

Vehicles or Equip. Used

5

Meter Readers

Employees on Job

B.S.
F.P. - 4 HR

FINISHED
8-F.P.

Areas - Read

STARTED
9

Vehicles Used

1-3

General Foreman

Frank J. Pocz

Date 4-17-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address		
Jobs Completed		
Employees on Job		
Vehicles or Equip. Used		
<hr/>		
Sewer Department		
Address		CALL OUT - OVERTIME
Job Completed		CHECKED FOR BACKUP AT HAZEL - CUSTOMERS PROBLEM. CHECKED CRESTON STATIONS
Employees on Job F.P.		4 CHECKED MANHOLES BETWEEN BOTH STATIONS - ALL GOOD
Vehicles or Equip. Used 1		
<hr/>		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
<hr/>		
General Foreman		Frank J. Pace

Date 4-17-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address		SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed		
Employees on Job	F.P. 1.5 hr	
Vehicles or Equip. Used	1	

<u>Sewer Department</u>		
Address		BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.)
Job Completed		CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING - CYCLED PUMPS AT CROCKETTS BLUFF Ex. 6 (Personal Privacy)
Employees on Job	F.P. 2.5 hr	
Vehicles or Equip. Used	5	

<u>Meter Readers</u>		
Employees on Job	F.P. 4 hr	STARTED 4 READ SOME IN AREA 8
Areas - Read		
Vehicles Used	1	
General Foreman	Frank J. Pace	

Date 4-21-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

LOCATES

Employees on Job

B.S.
6 HR

Vehicles or Equip. Used

3

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

B.S. F.P.
2 HR

FINISHED

5 - F.P. & B.S. 9 - F.P.

Areas - Read

STARTED

6 - F.P.

Vehicles Used

General Foreman

Frank J. Pace

Water Department	
Address	SERVICE TRUCK WORK ORDERS RE-READS
Jobs Completed	LOCATLS
Employees on Job F.P. - B.S. 3HR 4HR	
Vehicles or Equip. Used 1-3	

Sewer Department	
Address	BY-PASS PUMPED WITH PUMPS RAMP AT 71ST Ex. 7f (Water Infra.)
Job Completed	CYCLED BLOWERS AT OAKLAND, CRACKETS, PERSHING - CYCLED PUMPS AT CLINTON BLUFF Ex. 6 (Personal Privacy)
Employees on Job B.S. 4HR	
Vehicles or Equip. Used 5	

Meter Readers	
Employees on Job F.P. 5HR	FINISHED AREA 6
Areas - Read	
Vehicles Used 1	

General Foreman	Franky-Lee
-----------------	------------

Date 4-23-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERSLOCATESRE-READS

Jobs Completed

Employees on Job

F.P.
6 hrs

Vehicles or Equip. Used

1Sewer Department

Address

CYCLED BLOWERS AT CROCKETTS, OAKLAND, &
PESHING - CYCLED PUMPS AT CLINTON,
BLUFF, Ex. 6 (Personal Privacy)

Job Completed

Employees on Job

F.P.
2 hrs

Vehicles or Equip. Used

1

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 4-27-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	REBUILT SERVICE AT USED TWO $\frac{3}{4}$ " x $\frac{3}{4}$ " COMP. FITTINGS, ONE METER SHUT OFF, ONE METER COUPLING, Ex. 6 (Personal Privacy)
Employees on Job F.P. - B.S. 3.5 HR	5' OF $\frac{3}{4}$ " COPPER TUBING, ONE 18" x 36" P.V.C. METER BOX FROM SHOP (USED) - BACKFILLED WITH SPOIL - COPPER ON BOTH SIDES OF SET.
Vehicles or Equip. Used 1-14-BACKHOL	EXPOSED METER BOX & READ METER AT Ex. 6 (Personal Privacy)

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT TIST Ex. 7f (Water Infra.)
Job Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING - CYCLED PUMPS AT PLANT Ex. 6 (Personal Privacy)
Employees on Job B.S. 4.5 HR	PUMP #2 KICKED OUT AT RESET & PUMPED DOWN WELL - DIDN'T KICK OUT AGAIN. Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 5	

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman Frank J. Pace

Date 4-24-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK W.O.
Jobs Completed	
Employees on Job F.P. 1HR	
Vehicles or Equip. Used 1	

Sewer Department

Address	CHECKED FOR BACKUP AT Ex. 6 (Personal Privacy) OUR LINES ARE DOWN - CUSTOMER PROBLEM
Job Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT 7137 Ex. 6 (Personal Privacy)
Employees on Job F.P. 4HR	CYCLD BLOWERS AT CROCKETS, OAKLAND PERSHING - CYCLD PUMPS AT CINTON Ex. 6 (Personal Privacy) NEED TO PULL BLUFF
Vehicles or Equip. Used 5	PUT TARP BACK ON AT BERCHLAND

Meter Readers

Employees on Job F.P. 3HR	STARTED AREA 11
Areas - Read	
Vehicles Used 1	
General Foreman	Frank J. Ace

Date 4-28-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SEAVICK TRUCK WORK ORDERS

Jobs Completed

CYCLAP

Ex. 6 (Personal Privacy)

Employees on Job

B.S.

4HR

Vehicles or Equip. Used

3

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

F.P. - B.S.
4HR

FINISHED

12 & 11 - F.P.

Areas - Read

STARTED

13 - F.P. 15 - B.S.

Vehicles Used

1-3

General Foreman

Franky. Pae

Date 4-29-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

LOCATES

Jobs Completed

Employees on Job

F.P.
2 MR

Vehicles or Equip. Used

1

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST & Ex. 7f (Water Infra.) FIELD FROM RENOIS

Job Completed

CYCLED BLOWERS AT OAKLAND, CROCKETTS
PERSHING, CYCLED PUMPS AT CLINTON &
Ex. 6 (Personal Privacy)

Employees on Job

F.P. - B.S.
4 MR

Vehicles or Equip. Used

14-5- BACKHOC

PUMPED OUT BASEMENT AT
WITH 3" GAS PUMP.

Ex. 6 (Personal Privacy)

Meter Readers

Employees on Job

F.P.
2 MRFINISHED
13

Areas - Read

Vehicles Used

1

General Foreman

Frank J. Pace

Date 4-30-20Water Department

Daily Job Sheet

Sheet of

Address	Comments
	SERVICE TRUCK WORK ORDERS
	RR-READS
Jobs Completed	
	LOCATES
Employees on Job	
F.P. B.S. 2 HR 3 HR	
Vehicles or Equip. Used	
1-3	

Sewer Department

Address	
	WORKED WITH CENTREVILLE AT 56TH Ex. 6 (Personal Privacy)
Job Completed	
	CYCLED BLOWERS AT OAKLAND & Ex. 7f (Water Infra.) CYCLED PUMPS AT CLINTON Ex. 6 (Personal Privacy)
Employees on Job	
F.P. - D.T. 4 HR	
Vehicles or Equip. Used	
1-9	

Meter Readers

Employees on Job	
B.S. F.P. 5 HR 2 HR	FINISHED 14 & 15 - B.S.
Areas - Read	
	STARTED 17 - F.P.
Vehicles Used	
1-2	

General Foreman

Frank J. Pace

Date 5-1-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address		
Jobs Completed		
Employees on Job		
Vehicles or Equip. Used		
<hr/>		
Sewer Department		
Address		By-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.)
Job Completed		CYCLED BLOWERS AT CROCKETS, OAKLAND PERSHING - CYCLED PUMPS AT CCINTON Ex. 6 (Personal Privacy)
Employees on Job F.P. - B.S. 4WR		PULLED PUMPS & CLEANED OUT RAGS AT Ex. 6 (Personal Privacy) BEHIND Ex. 6 (Personal Privacy) PUMPED OUT BASEMENT AT Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 5-14-BACKHOP		INSTALLED PUMP IN FIELD FROM RENOIS
<hr/>		
Meter Readers		
Employees on Job F.P. 4WR		FINISHED 17
Areas - Read		STARTED 18
Vehicles Used 1		

General Foreman Frank J. Rice

Date 5-4-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	<u>SERVICE TRUCK WORK ORDERS</u> <u>RE-ROADS</u>
Jobs Completed	
Employees on Job F.P. B.S. 2HR 2HR	
Vehicles or Equip. Used 1-3	

Sewer Department

Address	BY-PASS PUMPS WITH 2" GAS PUMP AT 71ST & Ex. 6 (Personal Privacy) FIELD FROM RENOIS
Job Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING, CYCLED PUMPS AT CLINTON & (NEED TO PULL & CLEAN CLINTON) Ex. 6 (Personal Privacy)
Employees on Job B.S. - F.P. 6HR 4HR	PULLED BACK OFF PUMP & CLEANED OUT RAGS AT BRIDGERDALE
Vehicles or Equip. Used 5-14-BACKHOE	PULLED PUMP IN FIELD FROM RENOIS & BROUGHT TO SHOP

Meter Readers

Employees on Job F.P. 2HR	FINISHED 18
Areas - Read	
Vehicles Used 1	

General Foreman Frank J. Paul

Date 5-5-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address		SERVICE TRUCK WORK ORDERS
Jobs Completed		PUMPED OUT VAULT & READ METERS AT Ex. 6 (Personal Privacy)
Employees on Job F.P. B.S. 2 hr 1 hr		
Vehicles or Equip. Used 1-3		
Sewer Department		
Address		BY-PASS PUMPED WITH 3" GAS PUMP AT CALVIN BLVD. CYCLED BLOWERS AT OAKLAND Ex. 7f (Water Infra.) CYCLED Ex. 6 (Personal Privacy)
Job Completed		SETTLED LINE TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy)
Employees on Job D.T. - F.P. - B.S. 6 hr 7 hr		PULLED BOTH PUMPS & CLEANED RAGS OUT OF #2 PUMP AT Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 9-1-5-14-BACKHOE		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 5-6-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address		
Jobs Completed		
Employees on Job		
Vehicles or Equip. Used		
Sewer Department		
Address		PULLED & CLEANED PUMPS AT BLUFF & CLINTON Ex. 7f (Water Infra.)
Job Completed		CYCLED BLOWERS AT CROCKETTS, OAKLAND & PERSHING - CYCLED PUMPS AT BLUFF, CLINTON & Ex. 6 (Personal Privacy)
Employees on Job F.P. - B.S.		TOOK BACK OFF PUMP AT 51ST & Ex. 6 (Personal Privacy) PUMP IS STARVING FOR WATER - PUMPED DOWN WELL WITH 6" DIESEL PUMP
Vehicles or Equip. Used 7-14-6" DIESEL PUMP BACKHOLE		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 5-7-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed		
Employees on Job F.P. 2 HR		
Vehicles or Equip. Used 1		
<u>Sewer Department</u>		
Address	VACUUMS OFF SOLIDS FROM TOP OF WRT WALL - BY-PASS PUMPED WITH 6" DIESEL PUMP TO RELIEVE SYSTEM	
Job Completed		
Employees on Job D.T. - F.P. - B.S. 6 HR		
Vehicles or Equip. Used 7-14-9-6" Diesel Pump		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Date 5-8-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

Employees on Job

K.M.

Vehicles or Equip. Used

2 MR

Sewer Department

Address

PUMPED DOWN WET WELL, VACUMED
OUT WELL, PRIMED PUMP & PUMPING
NOW AT 51ST & Ex. 7f (Water Infra.)

Job Completed

BY-PASS PUMPED AT 71ST & Ex. 7f (Water Infra.)
CALVIN BLVD.

Employees on Job

F.P. - B.S. - K.M.
GMCCYCLED BLOWERS AT CROCKETTS, OAKLAND
PERSHING, CYCLED PUMPS AT CLINTON &
Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

5-7-14-9-6 DIESEL

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 5-11-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address		<u>SERVICE TRUCK WORK ORDERS</u> <u>LOCATES</u>
Jobs Completed		
Employees on Job F.P. - B.S. GHR 2HR		
Vehicles or Equip. Used 1-3		
<u>Sewer Department</u>		
Address		BY-PASS PUMPED WITH 3" GAS PUMP AT FIELD FROM RENOIS - CALVIN BLVD.
Job Completed		SET PUMP IN FIELD FROM RENOIS + WIRED IN TO JUNCTION BOX
Employees on Job F.P. - B.S. 2HR 6HR		JETTED LINE ON CALVIN TO RELIEVE BACKUP
Vehicles or Equip. Used 1-2-14- BACKHOLE - 9		CYCLED BLOWERS AT CROCKETTS + OAKLAND, PARSHING, CYCLED PUMPS AT CLINTON =
Ex. 6 (Personal Privacy)		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Fronk J. Pace</u>		

Date 5-12-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed	
Employees on Job F.P. 4 hrs	
Vehicles or Equip. Used 1	

Sewer Department

Address	BY-PASS PUMPS WITH 3" GAS PUMP AT 71ST & Ex. 7f (Water Infra.)
Job Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING - CYCLED PUMPS AT CLINTON, BLUFF & Ex. 7f (Water Infra.)
Employees on Job B.S. 4 hrs	
Vehicles or Equip. Used 5	

Meter Readers

Employees on Job F.P. - B.S. 2 hrs 4 hrs	STARTED AREA 29
Areas - Read	
Vehicles Used	

General Foreman Frank J. Pace

Date 5-13-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed	LOCATED ALONG OLD MO. FOR BORING JOB.	
Employees on Job <u>F.P. - B.S.</u> 3 HRE		
Vehicles or Equip. Used 1 - 3		
<u>Sewer Department</u>		
Address	RE-SET STARTER ON PUMP TWICE TODAY TO RELIEVE SYSTEM - NEED TO CHANGE STARTER.	
Job Completed	CYCLED PUMP AT Ex. 6 (Personal Privacy)	
Employees on Job <u>F.P. - B.S.</u> 1 HRE		
Vehicles or Equip. Used 1 - 14		
Meter Readers		
Employees on Job <u>F.P. - B.S.</u> 4 HRE	FINISHED AREA 29	
Areas - Read		
Vehicles Used 1 - 2		
General Foreman	<u>Frank J. Pace</u>	

Date 5-14-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address	<u>SERVICE TRUCK WORK ORDERS</u> <u>LOCATES</u>	
Jobs Completed	RR-READS	
Employees on Job <u>F.P. - B.S.</u> <u>3 HR</u>		
Vehicles or Equip. Used <u>1-3</u>		
Sewer Department		
Address	<u>BY-PASS PUMPED IN FIELD FROM RENOIS</u> <u>PULLED PUMP IN FIELD FROM RENOIS</u> <u>I TOOK TO SHOP</u>	
Job Completed	WORKED ON 51ST Ex. 7f (Water Infra.)	
Employees on Job <u>F.P. - B.S.</u> <u>5 HR</u>	JETTED LINE IN Ex. 6 (Personal Privacy) OF BATHS TO RECEIVE BACKUP	
Vehicles or Equip. Used <u>1-14 - BACKHOE</u>	CYCLED PUMP AT Ex. 6 (Personal Privacy)	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	<u>Franky Pace</u>	

Date 5-15-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS LOCATIONS
Jobs Completed	
Employees on Job F.P. 4 BR	
Vehicles or Equip. Used 3	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST & Ex. 6 (Personal Privacy)
Job Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING. - CYCLED PUMPS AT CLINTON, BLUFF, & Ex. 6 (Personal Privacy)
Employees on Job B.S. F.P. D.T. 4 BR	WIRED IN NEW FLOAT BALLS AT 51ST & Ex. 7f (Water Infra.)
Vehicles or Equip. Used 1-5-14	CHECKED STATIONS - SIGNAL HILL, BRIDGE DALE

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman	Frank J. Pace
-----------------	---------------

Date 5-14-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	CALL OUT - DOUBLE TIME	
Jobs Completed	REPAIRED 24" AC. MAIN BREAK AT RENOIS Ex. 6 (Personal Privacy) USED ONE 8" AC. S.S. REPAIR CLAMP - BACKFILLED SPOIL - NEAR ROCK IN ROAD.	
Employees on Job	F.P. - B.S. 4.5 HR	
Vehicles or Equip. Used	14 - BACKHOE	
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	Frank G. Pace	

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATES	
Jobs Completed		
Employees on Job F.P. 3NR		
Vehicles or Equip. Used 1		

Sewer Department		Comments
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST & Ex. 7f (Water Infra.) CALVIN BLVD, PUMPED OUT BASEMENT AT Ex. 6 (Personal Privacy)	
Job Completed	CYCLAD BLOWERS AT CROCKETTS, OAKLAND, PERSHING - CYCLAD PUMPS AT CLINTON & Ex. 6 (Personal Privacy)	
Employees on Job F.P. - B.S. 2NR	REPAIRED 4" DISCHARGE LINE AT SNOWS USED 56' OF 4" SCH 35 P.V.C. PIPE & ONE SCH 35 4" 90°	
Vehicles or Equip. Used 5-1-14		

Meter Readers		
Employees on Job F.P. 3NR	FINISHED AREAS 102	
Areas - Read		
Vehicles Used 1		
General Foreman	Franky. Boe	

Date 5-19-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address	<u>SERVICE TRUCK WORK ORDERS</u> <u>LOCATED MO. AVE.</u>
Jobs Completed	
Employees on Job <u>F.P. - B.S.</u> <u>4 KHR</u>	
Vehicles or Equip. Used <u>1-14</u>	

Sewer Department

Address	<u>PUMPED OUT BASEMENT WITH 2" GAS</u> <u>PUMP AT Ex. 6 (Personal Privacy) (SEAL ON PUMP</u> <u>IS LEAKING AGAIN)</u>
Job Completed	<u>BY-PASS PUMPED WITH 3" GAS PUMP</u> <u>IN FIELD FROM RENOIS</u>
Employees on Job <u>F.P. - B.S.</u> <u>2 KHR</u>	<u>CYCLED Ex. 6 (Personal Privacy)</u>
Vehicles or Equip. Used <u>14 - BACKHOLE</u>	<u>CHECKED BACKUP AT Ex. 6 (Personal Privacy)</u> <u>CUSTOMER'S PROBLEM</u>

Meter Readers

Employees on Job <u>F.P. - B.S.</u> <u>2 KHR</u>	<u>STARTED</u> <u>3 - F.P.</u>	<u>FINISHED</u> <u>7 - B.S.</u>
Areas - Read		
Vehicles Used <u>1-2</u>		

General Foreman Frank J. Pace

Date 5-19-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	CALL OUT - O.T.	
Jobs Completed	MARKED LINES FOR AMEREN AT JUDITH & Ex. 6 (Personal Privacy)	
Employees on Job	F.P. 2 HR	
Vehicles or Equip. Used	1	
Sewer Department		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	<u>Frank J. Pace</u>	

Date 5-20-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	<u>SERVICE TRUCK WORK ORDERS</u> <u>LOCATES</u>	
Jobs Completed	REPAIRED VALVE BOX AT JEROME 4 USED ONE VALVE BOX TOP	
Employees on Job F.P. - B.S. 3MR 1MR	CYCLED Ex. 6 (Personal Privacy) PUMP	
Vehicles or Equip. Used 1-2-14		
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job F.P. - B.S. 5MR 7MR	FINISHED 3-F.P.	
Areas - Read	STARTED 4-F.P.	
Vehicles Used 1-2		
General Foreman	<u>Frank J. Pace</u>	

Date 5-21-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address	INSPECTION INSTALL	
Jobs Completed		
Employees on Job	B.S. 1 HR	
Vehicles or Equip. Used	3	
Sewer Department		
Address	CYCLING BLOWERS AT CROCKETTS & CYCLED PUMP AT	
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job	F.P. - B.S. 7 PK SPRINK FINISHED 445-F.P. 9-B.S.	
Areas - Read		
Vehicles Used	1-2	
General Foreman	Frank J. Pace	

Date 5-22-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS (INSTALLS)
Jobs Completed	HOOKEO UP BACKSIDE & REBUILT SERVICE AT Ex. 6 (Personal Privacy) USED TWO 3/4" X 3/4" COMP. FITTINGS, ONE METER COUPLING, ONE METER
Employees on Job K.M. F.P. 2 HR 2 HR	SHUT OFF, 7' OF 3/4" COPPER TUBING, ONE 18" X 30" P.V.C. METER BOX. BACKFILLED WITH SPOK, - COPPER TO MAIN FORM BOX
Vehicles or Equip. Used 1-14 BACKHOL	P.V.C. FROM BOX TO HOUSE

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST & Ex. 7f (Water Infra.) FIELD FROM RENOIS
Job Completed	CYCLED BLOWERS AT CROCKETS, OAKLAND, PERSHING - CYCLED PUMPS AT CLINTON, BLUFF & Ex. 6 (Personal Privacy)
Employees on Job F.P. B.S. 1 HR 4 HR	
Vehicles or Equip. Used 5- BACKHOL	

Meter Readers

Employees on Job F.P.	FINISHED 6
Areas - Read	STARTED 10 (ONLY BLUE WATER LEFT)
Vehicles Used 1	

General ForemanFrank J. Puce

Date 5-25-20

Daily Job Sheet

Sheet ____ of ____

Water Department

Comments

Address	H O L I D A Y
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

Sewer Department

Address	M E M O R I A L
Job Completed	
Employees on Job	
Vehicles or Equip. Used	
Meter Readers	J A Y
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman Franky. Ace

Date 5-26-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed	LOCATES	
Employees on Job F.P.		
Vehicles or Equip. Used 1		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST & Ex. 7f (Water Infra.) CALVIN BLVD.	
Job Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND PERSHING- CYCLED PUMPS AT CLINTON & BLUFF. Ex. 6 (Personal Privacy)	
Employees on Job B.S.		
Vehicles or Equip. Used 5		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Franky Pace</u>		

Date 5-27-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	SHUT OFF 4" GATE VALVE IN VAULT AT Ex. 6 (Personal Privacy)
Employees on Job B.S. - F.P. 1 HR	
Vehicles or Equip. Used 1-3	

Sewer Department

Address	BY-PASS PUMPS ON FIELD FROM RENOIS
Job Completed	PULLED PUMPS AT Ex. 6 (Personal Privacy) & CLEANED OUT RACS - PUMPING NOW
Employees on Job F.P. - B.S. 7 HR	PULLED PUMP AT Ex. 6 (Personal Privacy) - TOOK TO SHOP INSTALLED PUMP AT Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 14-BACKHOV	PULLED PUMP AT 75TH Ex. 7f (Water Infra.) CLEANED OUT RACS - PUMPING NOW. RAISED PUMP 8" TO GET OUT OF MUCK.

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman Frank J. Pace

Date 5-28-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

TURNED ON WATER AT

Ex. 6 (Personal Privacy)

Employees on Job

B.S.
5 PR

Vehicles or Equip. Used

3-14

Sewer Department

Address

CYCLED BLOWERS AT CROCKETTS &
CYCLED PUMPS AT 75TH

Ex. 7f (Water Infra.)

Ex. 6 (Personal Privacy)

Job Completed

BY-PASS PUMPS WITH 3" GAS PUMP AT
CALVIN BLVD TO RELIEVE BACKUP AT
Ex. 6 (Personal Privacy) LATERALS ARE DOWN NOW

Employees on Job

B.S. - F.P.
3 PR 1 PR

Vehicles or Equip. Used

1-5

Meter Readers

Employees on Job

F.P.
7 PRFINISHED AREAS
11 & 12

Areas - Read

Vehicles Used

1

General Foreman

Frank J. Poel

Date 5-29-80

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

Employees on Job

F.P. - B.S.
1 HR 2 HR

Vehicles or Equip. Used

1-3

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST & Ex. 7f (Water Infra.)

Job Completed

CYCLED BLOWERS AT OAKLAND, CROCKETT,
PERSHING - CYCLED PUMP AT 75TH Ex. 7f (Water Infra.)
PUMPING CONSTANT

Employees on Job

F.P. - B.S.
1 HR 6 HRPUMPED OUT BASEMENT WITH 3" GAS PUMP
AT Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

1-5

Meter Readers

Employees on Job

F.P.
6 HR

FINISHED AREA 14 EXCEPT FOR F.O.W.

Areas - Read

Vehicles Used

1

General Foreman

Francis J. Pace

Water Department		Comments
Address		2HR CALL OUT D.T.
Jobs Completed		LOOKED FOR MAIN BREAK AT Ex. 6 (Personal Privacy) RD. - IT WAS A FORCED SEWER BREAK
Employees on Job F.P.		LOCATED AREA FOR SEWER REPAIR
Vehicles or Equip. Used 1		

Sewer Department	
Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman Frank Pace

Date 6-1-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address		
Jobs Completed		
Employees on Job		
Vehicles or Equip. Used		
Sewer Department		
Address		BY-PASS PUMPED WITH 3" GAS PUMP AT Ex. 7f (Water Infra.) PULL BOX
Job Completed		CYCLED BLOWERS AT CROCKETTS, OAKLAND CYCLED PUMP AT CLINTON
Employees on Job B.S. 4 HRC		Ex. 6 (Personal Privacy) NOT PUMPING - NEED TO PULL & CLEAN
Vehicles or Equip. Used 5		
Meter Readers		
Employees on Job B.S. - F.P. 4 HRC		FINISHED 13 & 14 - B.S. 15 - F.P.
Areas - Read		STARTED 17 - F.P.
Vehicles Used 1-2		
General Foreman		<u>Frank J. Pace</u>

Water Department		Comments
Address		SERVICE TRUCK WORK ORDERS LOCATING
Jobs Completed		
Employees on Job F.P. C, F. (Joc) 1 PR 1 PR		
Vehicles or Equip. Used 1-3		
Sewer Department		
Address		BY-PASS PUMPS WITH 3" GAS PUMP AT 71ST- Ex. 7f (Water Infra.) FIELD FROM RENOIS
Job Completed		CYCLAD BLOWERS AT CROCKETTS, OAKLAND, PERSHING, CYCLAD PUMP AT 75TH Ex. 7f (Water Infra.)
Employees on Job F.P. - B.S. 3 PR		PULLED PUMP & CLEANED OUT RAGS AT Ex. 6 (Personal Privacy) RAISED PUMP 1" - PUMPING NOW
Vehicles or Equip. Used 5-14- BACKHOE		LOCATED FOR BORING CREW ON OLD MO.
Meter Readers		
Employees on Job F.P. - C.F. (Joc) 4 PR 3 PR		FINISHED 17- F.P. 18- C.F. & F.P.
Areas - Read		
Vehicles Used 1-3		
General Foreman Frank J. Pace		

Date 6-3-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

LOCATES

Jobs Completed

HAULD ONE BUCKET OF ROCK TO
RENOIS & FILLED IN HOLE IN FRONT OF
DRIVEWAY

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - B.S.,
JME

Vehicles or Equip. Used

1-3

Sewer Department

Address

BY-PASS PUMPED WITH 3" PUMP AT
FIELD FROM RENOIS
BASEMENT AT

Ex. 6 (Personal Privacy)

Job Completed

CYCLED BLOWERS AT CROCKETS, OAKLAND,
PERSHING, CYCLED PUMPS AT CLINTON

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - B.S.,
GMR

Vehicles or Equip. Used

1-5-BACICHOR

NEEDS JETTED - LATERAL AT
N. 74TH WAS DOWN - TALKED TO COST.

Ex. 6 (Personal Privacy)

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Franky - Pace

Date 6-4-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	<u>SERVICE TRUCK WORK ORDERS</u> <u>LOCATIONS</u>
Jobs Completed	
Employees on Job <u>F.P. - B.S.</u> <u>4 hr</u>	
Vehicles or Equip. Used <u>1-3</u>	

Sewer Department

Address	<u>BY-PASS PUMPED WITH 3" GAS PUMP AT</u> <u>71ST +</u> Ex. 7f (Water Infra.)
Job Completed	<u>CYCLED BLOWERS AT CROCKETTS, OAKLAND</u> <u>+ PERSHING - CYCLED PUMPS AT CLINTON +</u> Ex. 6 (Personal Privacy)
Employees on Job <u>B.S.</u> <u>4 hr</u>	
Vehicles or Equip. Used <u>5</u>	

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman Frank J. Pace

Date 6-5-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed	
Employees on Job F.P. DHR	
Vehicles or Equip. Used 1	

Sewer Department

Address	BY-PASS PUMPED WITH 24 GAS PUMP AT 71ST & Ex. 7f (Water Infra.) CALVIN BLVD.
Job Completed	CYCLING BLOWERS AT CROCKETT, OAKLAND PERFORMING CYCLING PUMPS AT CLINTON & Ex. 6 (Personal Privacy)
Employees on Job F.P. - B.S. GMC	JETTED LINE TO RELIEVE BACKUP AT N. 73RD - JETTED LINE AT Ex. 6 (Personal Privacy) TO RELIEVE BACKUP AT CLINTON PUMP. Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 5-1- VILLAGE JET	RE-INSERTED DISCHARGE LINE & TIED OFF AT 82ND Ex. 7f (Water Infra.) PUMPING NOW.

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman Frank A. Boe

Date 6-8-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

Employees on Job

G.F. - F.P.
2 HR 1 HR

Vehicles or Equip. Used

3-1

Sewer Department

Address

BY-PASS PUMPS WITH 3" GAS PUMP AT
71ST & Ex. 7f (Water Infra.)
FIELD FROM KENOIS

Job Completed

CYCLED BLOWERS AT CROCKETTS,
OAKLAND, PERSHING - CYCLED PUMPS AT
CLINTON & Ex. 6 (Personal Privacy)

Employees on Job

G.F. F.P.
4 HR 1 HRCHECKED STATIONS - NEED TO PULL &
CLEAN PUMP AT VIOLET - PUMP #2
KICKED OUT STARTER AT CRESTON

Vehicles or Equip. Used

5

Meter Readers

Employees on Job

G.F. F.P.
2 HR 6 HRFINISHED
19 - F.P. & G.F.

Areas - Read

STARTED
20 - F.P.

Vehicles Used

General Foreman

Frank J. Pace

Date 6-9-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS RE-READS	
Jobs Completed		
Employees on Job G.F. 4HR		
Vehicles or Equip. Used 3		
Sewer Department		
Address	PULLED & CLEANED OUT RAGS/MOPS AT Ex. 7f (Water Infra.)	
Job Completed	JETTED LATERAL AT Ex. 6 (Personal Privacy)	
Employees on Job F.P. - G.F. 4HR		
Vehicles or Equip. Used S-14-BACKHOLE-1		
Meter Readers		
Employees on Job F.P. 4HR	FINISHED 20421	
Areas - Read		
Vehicles Used 1		
General Foreman <u>Frank J. Pace</u>		

Date 6-10-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

Employees on Job

F.P. - G.F.
8 HR 4 HR

Vehicles or Equip. Used

1-3

Sewer Department

Address

BY-PASS PUMPLED WITH 3" GAS PUMP AT
71579 Ex. 7f (Water Infra.)

Job Completed

CYCLD BLOWERS AT CROCKETS, OAKLAND
PERSHING - CYCLD PUMPS AT CLINTON,
BLUFF, Ex. 6 (Personal Privacy)

Employees on Job

G.F.
4 HR

Vehicles or Equip. Used

5

Meter Readers

Employees on Job

F.P.
6 HR

FINISHED
22

Areas - Read

Vehicles Used

1

General Foreman

Frank J. Pace

Date 6-11-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

Employees on Job

F.P. - G.F.
2 HR 4 HR

Vehicles or Equip. Used

1-3

Sewer Department

Address

BY-PASS PUMPED IN FIELD FROM
RRNOIS

Job Completed

CYCLED BLOWERS AT CROCKETS
CYCLED PUMPS AT BLUFF

Ex. 7f (Water Infra.)

Ex. 6 (Personal Privacy)

Employees on Job

F.P.
1 HR

Vehicles or Equip. Used

1

Meter Readers

Employees on Job

F.P. - G.F.
3 HR 4 HR

FINISHED AREAS

24 - G.F. 23+26 - F.P.

Areas - Read

Vehicles Used

1-3

General Foreman

Frank J. Pace

Date 6-12-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed	
Employees on Job F.P. 20R	
Vehicles or Equip. Used 1	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) - CALVIN BLVD.
Job Completed	CYCLED BLOWERS AT CROCKETS, OAKLAND, PERSHING - CYCLED PUMPS AT CLINTON, BLUFF, Ex. 6 (Personal Privacy)
Employees on Job C.F.	
Vehicles or Equip. Used 5	

Meter Readers	
Employees on Job F.P. G.M.K.	FINISHED AREA 29
Areas - Read	
Vehicles Used 1	

General Foreman Frank J. Pace

Date 6-15-00

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS TOOK MAIL TO POST OFFICE	
Jobs Completed		
Employees on Job	F.P. 1 HR	
Vehicles or Equip. Used	1	
Sewer Department		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST & Ex. 7f (Water Infra.)	
Job Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND & PERSHING & CYCLED PUMPS AT CLINTON, BLUFF & Ex. 6 (Personal Privacy)	
Employees on Job	G.F. - F.P. 4 HR	
Vehicles or Equip. Used	5-14-BACKHOLE LOCATED MANHOLE ON VALLY & Ex. 6 (Personal Privacy) TRYING TO FIND REASON FOR WATER COMING OUT OF BANK	
Meter Readers		
Employees on Job	F.P. 3 HR	
Areas - Read	FINISHED 1-20 P.T. METERS	
Vehicles Used	1	
General Foreman	Frank J. Pace	

Date 6-16-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F. 4 HR	
Vehicles or Equip. Used 3	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT CALVIN BLVD, FIELD FROM RENOIS
Job Completed	CYCLD BLOWERS AT OAKLAND, CROCKETTS, CYCLD PUMPS AT CLINTON, BLUFF
Employees on Job F.P. - G.F. 2 HR 4 HR	CHECKED STATIONS ON SIGNAL HILL - ALL GOOD
Vehicles or Equip. Used 1-5	CHECKED END OF GRAND VIEW

Ex. 6 (Personal Privacy)

Meter Readers

Employees on Job F.P. 5 HR	FINISHED AREA 3
Areas - Read	
Vehicles Used 1	
General Foreman	Frank J. Pare

Date 6-17-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

BY-PASS PUMPER WITH 3" GAS PUMP
AT DIST. **Ex. 7f (Water Infra.)**

Jobs Completed

CYCLED BLOWERS AT CROCKETTS, OAKLAND,
PERSHING, CYCLED PUMPS AT CLINTON,
BLUFF **Ex. 6 (Personal Privacy)**

Employees on Job

G.F.
4 HR

Vehicles or Equip. Used

5

Meter Readers

Employees on Job

F.P. - G.F.
4 HR

FINISHED

4-F.P.

2-G.F.

Areas - Read

STARTED

5-F.P.

8-G.F.

Vehicles Used

1-3

General Foreman

Frank Pace

Date 6-18-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

TALKED TO PLUMBER AT **Ex. 6 (Personal Privacy)**
ABOUT TURNING ON WATER & METER
ANTENNA HOOK UP

Employees on Job

G.P. - F.P.
3 HR 1 HR

Vehicles or Equip. Used

1-3

Sewer Department

Address

Ex. 7f (Water Infra.) BY-PASS PUMPED WITH 3" GAS PUMP AT
TO RELIEVE SYSTEM

Job Completed

CHECKED FOR BACKUP AT **Ex. 6 (Personal Privacy)**
CUSTOMER PROBLEM

Employees on Job

F.P. - G.P.
1 HR

Vehicles or Equip. Used

1-5

Meter Readers

Employees on Job

G.P. F.P.
4 HR 6 HR

Meters - Read

FINISHED
5-F.P. 8-G.P.
STARTED
6-F.P. 9-G.P.

Vehicles Used

1-3

General Foreman

Frank J. Pace

Date 6-19-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

RE-LEADS

Jobs Completed

LOCATES

Employees on Job

F.P. - G.P.

3 HR 1 HR

Vehicles or Equip. Used

1 - 3

TURNED ON 6" VALVE TO SUPPLY WATER
TO **Ex. 6 (Personal Privacy)** - TALKED TO
PLUMBER ABOUT ANTENNAS

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST & **Ex. 7f (Water Infra.)** CALVIN BLVD.

Job Completed

CYCLED BLOWERS AT CROCKETS, OAKLAND,
PERSHING, CYCLED PUMPS AT CLINTON,
BLUFF & **Ex. 7f (Water Infra.)**

Employees on Job

F.P. - G.P.

2 HR 7 HR

Vehicles or Equip. Used

1 - 1/4 - 5

TOOK BACK OFF OF PUMPS & CLEANED
OUT RAGS AT SUPERIOR - PUMPING NOW

Meter Readers

Employees on Job

F.P.
3 HRFINISHED
6

Areas - Read

Vehicles Used

1

General Foreman

Frank J. Pace

Date 6-22-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

Employees on Job

C.F.
4 HR

Vehicles or Equip. Used

3

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST & **Ex. 7f (Water Infra.)** FIELD FROM
RENOIS

Jobs Completed

CYCLED BLOWERS AT CROCKETT'S, OAKLAND,
PERSHING - CYCLED PUMPS AT CLINTON
BLUFF **Ex. 6 (Personal Privacy)**

Employees on Job

F.P. - C.F.
1 HR 4 HR

Vehicles or Equip. Used

1-5

Meter Readers

Employees on Job

F.P.
7 HRFINISHED
9 & 10

Areas - Read

Vehicles Used

1

General Foreman

Frank J. Pace

Date 6-23-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	(C) FILLED IN AROUND METER BOX WITH ONE BUCKET OF C-M-10 ROCK AT Ex. 6 (Personal Privacy)
Employees on Job	
G.P. - F.P. 2 HR 2 HR	
Vehicles or Equip. Used	
1-3- BACKHOLE	

sewer Department

Address	CYCLED BLOWERS AT CROCKETTS & OAKLAND CYCLED PUMPS AT CLINTON + Ex. 6 (Personal Privacy)
Job Completed	SETTLED LINE ON GRANVUE
Employees on Job	
F.P. - G.P. 6 HR	WORKED ON PUMP AT SNOWS
Vehicles or Equip. Used	BY-PASS PUMPED Ex. 7f (Water Infra.) 1-14-9- BACKHOLE

meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 6-24-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

Employees on Job

G.F.
J.K.M.

Vehicles or Equip. Used

3

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST & **Ex. 7f (Water Infra.)** CALVIN BLVD

Jobs Completed

CYCLED BLOWERS AT CROCKETTS, OAKLAND,
PARKSHIRE, - CYCLED PUMPS AT CLINTON,
BLUFF, SNOWS, **Ex. 6 (Personal Privacy)**

Employees on Job

G.F.
G.M.

Vehicles or Equip. Used

5

Meter Readers

Employees on Job

F.P.

FINISHED

11 & 12

Areas - Read

STARTED

13

Vehicles Used

1

General Foreman

Frank J. Rose

Date 6-25-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job F.P. 2 W.R.	
Vehicles or Equip. Used 1	

Sewer Department

Address	CYCLAD BLOWERS AT OAKLAND, CROCKETTS PERSHING - CYCLAD PUMPS AT BLUFF CLINTON Ex. 6 (Personal Privacy) SNOWS
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers

Employees on Job F.P. G.F. W.R.	FINISHED 13 & 14 F.P. 15 - G.F.
Meters - Read	STARTED 17 - G.F.
Vehicles Used 1-3	

General Foreman Frank J. Pace

Date 6-24-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

REMOVED JUMPER & RISER/RE SETTER
FROM **Ex. 6 (Personal Privacy)**

Employees on Job

F.P. - G.F.
2 HR 3 HR

Vehicles or Equip. Used

1 - 3

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST & **Ex. 7f (Water Infra.)** REEL FROM
RENOIS

Job Completed

CYCLED BLOWERS AT CROCKETTS, OAKLAND,
PERSHING - CYCLED PUMPS AT CLINTON,
BLUFF, SNOWS, **Ex. 6 (Personal Privacy)**

Employees on Job

F.P. - G.F.
2 HR 5 HR

Vehicles or Equip. Used

1 - 5

Meter Readers

Employees on Job

F.P.
4 HR.FINISHED
17

Meters - Read

STARTED
18

Vehicles Used

1

General Foreman

Frank J. Pace

Date 6-29-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job F.P. JMR	
Vehicles or Equip. Used 1	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) & RENOIS
Jobs Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND PARSHING, - CYCLED PUMPS AT CLINTON BLUFF, SNOWS, Ex. 6 (Personal Privacy)
Employees on Job F.P. - G.P. JMR	REPLACED PUMP AT Ex. 6 (Personal Privacy) WITH NEW PUMP IN SHOP.
Vehicles or Equip. Used 5-14-BACKHOL	

Meter Readers

Employees on Job F.P. JMR	FINISHED AREA 18
Areas - Read	
Vehicles Used 1	

General Foreman

Frank J. Pace

Date 6-30-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICES TRUCK WORK ORDERS LOCATIONS
Jobs Completed	
Employees on Job F.P. 4MR	
Vehicles or Equip. Used 3	

Sewer Department

Address	CHECKED STATIONS CHANGED OIL IN 3" PUMP
Jobs Completed	BY-PASS PUMPED WITH 3" GAS PUMP AT Ex. 7f (Water Infra.) CALVIN BLVD.
Employees on Job F.P. - G.F. 4MR	CYCLED BLOWERS AT CROCKETTS, OAKLAND PRESHING - CYCLED PUMPS AT CLINTON SNOWS, BLUFF, Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 3-5	LEFT STATIONS OFF DUE TO HEAVY RAIN AT CROCKETTS, OAKLAND, CLINTON, Ex. 6 (Personal Privacy) E. ST. LOUIS NOT TAKING DUE TO RAIN

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman Frank J. Pace

Date 7-1-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

LOCATES

Jobs Completed

RE-ROADS

Employees on Job

G.F. - F.P.
DNR

Vehicles or Equip. Used

1-3

Sewer Department

Address

PUMPED OUT CANS AT BLUFF,
WITH 3" PUMP

Ex. 7f (Water Infra.)

Job Completed

CHECKED STATIONS - AMES,
SIST, Ex. 6 (Personal Privacy) P.S. REAR HILL OFF

Ex. 6 (Personal Privacy)

Employees on Job

F.P.
GHR

Vehicles or Equip. Used

5-1

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 7-2-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

Employees on Job

F.P. - G.F.
JMR

Vehicles or Equip. Used

1-3

Sewer Department

Address

CHECKED STATIONS - ALL ON
BLUFF OFF - BLUEVUE ON

Job Completed

BY-PASS PUMPED WITH BOTH 3" GAS PUMPS
AT 71ST **Ex. 7f (Water Infra.)** VIOLET,
FIELD FROM RENOIS, CALVIN BLVD.

Employees on Job

F.P. - Corbi
G. JMR

Vehicles or Equip. Used

1-5-BACKHOE

CYCLED BLOWERS AT CROCKETT, OAKLAND
PARSHING, CYCLED PUMPS AT CLINTON,
SNOWS **Ex. 6 (Personal Privacy)** SNOWS OFF

PUMPED OUT BASEMENT AT **Ex. 6 (Personal Privacy)**

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 7-3-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	H O L I D A Y
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

Sewer Department

Address	4 TH OF J U L Y
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers	J U L Y
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman Frank Pace

Date 7-6-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	<u>SERVICE TRUCK WORK ORDERS</u> <u>LOCATES</u>
Jobs Completed	
Employees on Job F.P. Q.M.R.	
Vehicles or Equip. Used 1	

Water Department

Address	BY-PASS PUMPED WITH BOTH 2" CAS PUMPS AT 71ST+ Ex. 7f (Water Infra.) FIELD FROM RENDIS,
Jobs Completed	CHECKED STATIONS - 51ST+ Ex. 7f (Water Infra.) & Ex. 6 (Personal Privacy) OFF DUE TO BACKUP.
Employees on Job F.P. - G.F. Q.M.R.	CYCLED BLOWERS AT CROCKETTS OAKLAND, PERSHING - CYCLED PUMPS AT CLINTON, BLUFF, SNOWS, Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 1-5 - BACKHOE	

Meter Readers

Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman Frank J. Pace

Date 7-7-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F. 4 HR	
Vehicles or Equip. Used 3	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT CALVIN BLVD.
Jobs Completed	CYCLED BLOWERS AT OAKLAND, CROCKETTS PERSHING - CYCLED PUMPS AT CLINTON, BLUFF, SNOWS, Ex. 6 (Personal Privacy)
Employees on Job G.F. F.P. 2 HR 2 HR	CHECKED STATIONS - ALL BACK ON - SNOWS ON
Vehicles or Equip. Used 1-5	

Meter Readers

Employees on Job G.F. F.P. 2 HR 5 HR	FINISHED 19
Meters - Read	STARTED 20
Vehicles Used 1	
General Foreman	<u>Frank J. Pace</u>

Date 7-8-20

Daily Job Sheet

Sheet ___ of ___

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

RE-READS

Jobs Completed

LOCATES

Employees on Job

F.P. C.F.
1 hr 4 hr

Vehicles or Equip. Used

1-3

Sewer Department

Address

CHECKED STATIONS - NEED TO
PULL CLINTON & #2 AT CRESTON

Job Completed

ALL STATIONS ON AUTO ON SOUTH END

Employees on Job

C.F. F.P.
4 hr 1 hrBY-PASS PUMPED WITH 3" GAS PUMP AT
71ST + Ex. 7f (Water Infra.)

Vehicles or Equip. Used

5 1

CYCLED BLOWERS AT CROCKETTS & OAKLAND
CYCLED PUMPS AT BLUFF + Ex. 6 (Personal Privacy)
SNOWS IS ON

Meter Readers

Employees on Job

F.P.
6 hrFINISHED
20+21

Areas - Read

STARTED
22

Vehicles Used

1

General Foreman

Frank J. Pace

Date 7-9-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDER

Jobs Completed

Employees on Job

G.F.
4 HR

Vehicles or Equip. Used

3

Sewer Department

Address

PULLED PUMPS & CLEANED RAGS OUT
AT CLINTON & #2 AT CRESTON

Job Completed

CYCLED BLOWERS AT CROCKETTS
PERSHING - CYCLED PUMPS AT CLINTON & #2

Ex. 7f (Water Infra.)

Ex. 6 (Personal Privacy)

Employees on Job

G.F. F.P.
4 HR

Vehicles or Equip. Used

14 - BACKHOE

Meter Readers

Employees on Job

F.P.
4 HRFINISHED
22

Areas - Read

Vehicles Used

1

General Foreman

Frank J. Pace

Date 7-10-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

Employees on Job

F.P. - G.F.
2 hr

Vehicles or Equip. Used

1-3

Sewer Department

Address

BY-PASS PUMPED WITH BOTH 3" GAS
PUMPS AT 71ST - Ex. 7f (Water Infra.)

CALVIN BLVD, FIELD FROM RENOIS - Ex. 7f (Water Infra.)

Job Completed

CYCLED BLOWERS AT CROCKETTS, OAKLAND,
PERSHING - CYCLED PUMPS AT CLINTON,
BLUFF, Ex. 6 (Personal Privacy) KNOWS

Employees on Job

F.P. - G.F.
4 hr 6 hr

Vehicles or Equip. Used

1-5 - BACKHOE

Meter Readers

Employees on Job

F.P.
2 hr

FINISHED AREA
DS

Areas - Read

Vehicles Used

1

General Foreman

Frank J. Pace

Date 7-13-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F. JMK	
Vehicles or Equip. Used 3	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST * Ex. 7f (Water Infra.)
Jobs Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING - CYCLED PUMPS AT CLINTON, BLUFF, Ex. 6 (Personal Privacy) SNOWS
Employees on Job F.P. - G.F. QMK 5 MK	PULLED DISCHARGE LINE & CLEANED OUT ROCK/RAGS AT Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 5-14 - BACKHOLE	

Meter Readers

Employees on Job F.P. 6 MK	FINISHED AREAS 24 & 26
Areas - Read	
Vehicles Used 1	

General Foreman

Frank J. Pace

Date <u>7-14-00</u>		Daily Job Sheet		Sheet <u> </u> of <u> </u>	
Water Department		Comments			
Address		SEARCH TRUCK WORK ORDERS			
Jobs Completed		LOCATES			
Employees on Job B.S. - G.F. 3 HR 6 HR					
Vehicles or Equip. Used 2-3					
Sewer Department					
Address		BY-PASS PUMPED WITH 3" GAS PUMP AT CALVIN BLVD., FIELD FROM RENOIS, Ex. 7f (Water Infra.)			
Job Completed		CYCLED BLOWERS AT CROCKETS, CARLAND, PERSHING - CYCLED PUMPS AT CLINTON, BLUFF, SINOVS, Ex. 6 (Personal Privacy)			
Employees on Job F.P. G.F. B.S. 1 HR 2 HR 1 HR		MADE UP DISCHARGE LINE FOR FIELD FROM RENOIS IN SHOP			
Vehicles or Equip. Used BACKHOL-5-2					
Meter Readers					
Employees on Job F.P. - B.S. 4 HR		STARTED AREA 29			
Areas - Read					
Vehicles Used 1-2					
General Foreman		Frank J. Pace			

Date 7-15-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

Employees on Job

G.F.
4 PR

Vehicles or Equip. Used

3

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST & **Ex. 7f (Water Infra.)**

Job Completed

CYCLED BLOWERS AT CROCKETTS OAKLAND
PERSHING, CYCLED PUMPS AT CLINTON,
BLUFF, SNOWS, & **Ex. 6 (Personal Privacy)**

Employees on Job

G.F. - B.S. - F.P.
4 PR

Vehicles or Equip. Used

1-2-5-BACKHOL-74

INSTALLED NEW FLOAT BALL & HUNG
WIRKS FOR PUMP & FLOAT BALL FROM
POSTS AT SNOWS - SENSOR IN PANELBOX IS STILL TRIPPING PUMP - ONLY
RUNS ON HAND CHECKED STATIONS

Meter Readers

Employees on Job

F.P. - B.S.
4 PR

FINISHED

24-F.P. & B.S. - 1-B.S. - 2-F.P.

Areas - Read

Vehicles Used

1 & 2

General Foreman

Frank J. Pace

Date 7-16-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F. 4 HR	
Vehicles or Equip. Used 3	

Sewer Department

Address	CYCLER BLOWERS AT CROCKETTS, OAKLAND, PERSHING - CYCLER PUMPS AT CLINTON, SNOWS & Ex. 6 (Personal Privacy)
Jobs Completed	CHECKED STATIONS - BEECHLAND STARTER KICKED OUT - RESET & PUMPING NOW, 63RD Ex. 7f (Water Infra.) AD BREAKER OR STARTER
Employees on Job F.P. - B.S.	WIRED BLOWER INTO BREAKER DIRECT & PUMPED DOWN SYSTEM - TRIED TO WIRE INTO STARTER #2 BUT COULD NOT GET STARTER TO PULL IN
Vehicles or Equip. Used 1-2-14- BACKHOL	PULLED PUMP AT Ex. 6 (Personal Privacy) & CLEANED OUT RAGS/DEBRIS - PUMPING NOW

Meter Readers

Employees on Job G.F. 4 HR	FINISHED AREA 3
Areas - Read	STARTED AREA 4
Vehicles Used 3	
General Foreman Frank J. Pice	

Date 7-17-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

LOCATIONS

Jobs Completed

Employees on Job

G.F. F.P.
4 HR 2 HR

Vehicles or Equip. Used

1-3

Sewer Department

Address

BY-PASS PUMPS WITH BOTH 3" GAS PUMPS
AT 71ST & Ex. 7f (Water Infra.) CALVIN BLVD.
FIELD FROM RENOIS, Ex. 7f (Water Infra.)

Job Completed

CYCLED PUMPS AT CLINTON, BLUFF, SNOWS
Ex. 6 (Personal Privacy) CYCLED BLOWERS AT CROCKETTS,
OAKLAND, PERSHING, GSRB Ex. 7f (Water Infra.)

Employees on Job

B.S. - F.P.
2 HR

Vehicles or Equip. Used

5-BACKHOE

Meter Readers

Employees on Job

F.P. - G.F.
4 HR

FINISHED

4-G.F. 7-F.P.

Areas - Read

STARTED

5-G.F. 8-F.P.

Vehicles Used

1-3

General Foreman

Frank J. Pore

Date 7-20-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	LOCATES
Employees on Job F.P. - G.F. 2 WRC	
Vehicles or Equip. Used 1-3	

Sewer Department

Address	BY-PASS PUMPED AT 71ST & Ex. 7f (Water Infra.) WITH 3" GAS PUMP
Jobs Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING, G3RD Ex. 6 (Personal Privacy) CYCLED PUMPS AT CLINTON, SNOWS, Ex. 6 (Personal Privacy)
Employees on Job B.S.	CHECKED STATIONS - BRIDGDALE BACKED UP FROM RAIN - #2 STARTER KICKED OUT AT CRESTON
Vehicles or Equip. Used 5	COULD NOT TURN ON BLUFF DUE TO BELLEVIEW BACKED UP. LEFT SNOWS ON - WATER OVER WELL FROM RAIN

Meter Readers

Employees on Job F.P. - G.F. 6 WRC	FINISHED 5 - G.F. 8 - F.P.
Areas - Read	STARTED 9 - F.P.
Vehicles Used 1-3	

General Foreman Frank J. Pace

Date 7-21-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

RE-READS

LOCATES

Jobs Completed

Employees on Job

F.P. - G.F. B.S.
4 HR 4 HR 2 HR

Vehicles or Equip. Used

1 - 3 - 2

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
CALVIN BLVD. Ex. 7f (Water Infra.)

Job Completed

CYCLED BLOWERS AT CROCKETTS, OAKLAND
PRESHING, G3RD Ex. 7f (Water Infra.)
CLINTON, Ex. 6 (Personal Privacy) + BLUFF

Employees on Job

B.S.
6 HRSNOWS LEFT ON - WATER OVER WELLS
FROM HEAVY RAINS

Vehicles or Equip. Used

5

Meter Readers

Employees on Job

F.P. - G.F.
7 HR 4 HR

FINISHED AREAS

6 - G.F. 9410 - F.P.

Areas - Read

Vehicles Used

1 - 3

General Foreman

Frank J. Pace

Date 7-22-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F. 5 HR	
Vehicles or Equip. Used 3	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) FIELD FROM RENOS
Job Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING. CYCLED PUMPS AT CLINTON, Ex. 6 (Personal Privacy) SNOWS LEFT ON DUE TO RAIN
Employees on Job B.S. - F.P. 5 HR	BELLVIEW PUMPING AGAINST HEAD BLUFF OFF
Vehicles or Equip. Used 5-14- BACKHOE	RESET STARTERS AT CLINTON & CLEANED ROAD AT Ex. 6 (Personal Privacy) WHERE MANHOLE SURCHARGED.

Meter Readers

Employees on Job F.P. - G.F. 3 HR - 3 HR	STARTED 11 - G.F. - 15 - F.P.
Meters - Read	
Vehicles Used 1-3	

General Foreman Frank J. Pace

Date 7-23-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

RE-ROADS

Jobs Completed

SHUT OFF CORP, STOP AT MAIN AT
ST. JOHN - HOUSE IS EMPTY - NEED TO
PULL LINE UNDER ROAD IF HOUSE IS OCCUPIED

Ex. 6 (Personal Privacy)

Employees on Job

G.F. - F.P. - B.S.
6 HR 3 HR

IN FUTURE

Vehicles or Equip. Used

3 - 14 - BACKHOE

Sewer Department

Address

CHECKED SNOWS - NOT PUMPING - 240 in
FROM POLE & THROUGH STARTER - DRAWING
LOW AMPS - MAY HAVE SHEARED SHAFT?

Job Completed

CYCLED BLOWERS AT CROCKETTS, OAKLAND,
PERSHING - CYCLED PUMPS AT CLINTON,

Ex. 6 (Personal Privacy) BELLEVUE PUMPING AGAINST HEAD

Employees on Job

F.P. - B.S. G.F.
1 HR 2 HR

Vehicles or Equip. Used

14-2

Meter Readers

Employees on Job

F.P. - B.S.
4 HR

FINISHED

11-12 - F.P.

15 - B.S.

Areas - Read

STARTED

13 - F.P.

17 - B.S.

Vehicles Used

1-2

General Foreman

Frank J. Pace

Date 7-24-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

LOCATES

Jobs Completed

SHUT OFF CORP. STOP FOR SERVICE TO
PARKLANE - NEEDED TO PULL NEW LINE BEFORE
REPAIRING DRIVEWAY AT

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Employees on Job

B.S. - F.P. C.F.
4HR GHR 2HRUSED $\frac{3}{4}$ TRUCK LOAD OF CLEAN ROCK &
TWO BACKHOE BUCKETS OF C-M-G FOR
BACKFILL IN DRIVEWAY

Vehicles or Equip. Used

BACKHOE - 5-1-3-14

Sewer Department

Address

BY-PASS PUMPED WITH 3" PUMPS AT
71ST & Ex. 7f (Water Infra.) FIELD FROM
RENOIS

Job Completed

CYCLED BLOWERS AT CROCKETTS, OAKLAND
PERSHING - CYCLED PUMPS AT CLINTON &
Ex. 6 (Personal Privacy) BELLEVUE PUMPING AGAINST

Employees on Job

B.S. - F.P.
4HR 1HR

HEAD - BLUFF OFF

Vehicles or Equip. Used

1-5-BACKHOE

Meter Readers

Employees on Job

F - F.P.
G 4HR 1HRREAD IN AREA 13 - C.F.
17 - F.P. (CALLED OFF DUE TO LEAK)

Areas - Read

Vehicles Used

1-3

General Foreman

Frank J. Pace

Date 7-27-20

Daily Job Sheet

Sheet 1 of 1Water Department

Comments

Address

Jobs Completed

Employees on Job

GF

Vehicles or Equip. Used

3

Service Truck

Sewer Department

Address

Job Completed

Employees on Job

BS - GF

Vehicles or Equip. Used

BACK HOE 3-5

BY PASSED 71ST - RAN BLOWERS

BY PASSED Ex. 7f (Water Infra.) CALVIN

+ RENOITS

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman



Water Department		Comments
Address		
Jobs Completed		Service TRUCK
Employees on Job GF		
Vehicles or Equip. Used 3		

Sewer Department		Comments
Address		RAN BLOWERS
Job Completed		found A BLOCKED LINE Re SET
Employees on Job BS		Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 2		

Meter Readers		
Employees on Job GF-BS		
Areas - Read 14-17- START 18		
Vehicles Used 3-2		
General Foreman		B. Smith

Date 7-29-20

Daily Job Sheet

Sheet 1 of 1Water Department

Comments


Address	Service TRUCK
Jobs Completed	
Employees on Job G.F	
Vehicles or Equip. Used 3	

Sewer Department

Address	Cycled BLOWERS BY PASSED 71ST
Job Completed	JETTED LINE ON 74TH ST
Employees on Job BS	TURNED ON BLUFF
Vehicles or Equip. Used 5	

Meter Readers

Employees on Job GF	
Areas - Read 13-18	
Vehicles Used 3	

General Foreman

Date 7-30-20

Daily Job Sheet

Sheet 1 of 1

Water Department

Comments

Address

Jobs Completed

Service TRUCK

Employees on Job

BS GF

LOCATES

Vehicles or Equip. Used

#2 3

Sewer Department

Address

BY PASSED

Ex. 7f (Water Infra.)

J RENAI'S

Job Completed

CYCLED BLOWERS

Employees on Job

BS

Vehicles or Equip. Used

5- BACK HOE

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

B. Smith

Date 7/31/20

Daily Job Sheet

Sheet 1 of 1

Water Department

Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

BY PASS WSP. CYCLE BLOWERS

JET LINE PROP

Ex. 6 (Personal Privacy)

6 PM

5 14

H. K. Kim

Date 8-3-20

Daily Job Sheet

Sheet 1 of 1Water Department

Comments

Address	SERVICE TRUCK
Jobs Completed	LOCATES
Employees on Job GF BS	
Vehicles or Equip. Used 3 5	

Sewer Department

Address	BY PASSED TEST BY PASSED CALVIN
Jobs Completed	Cycled BLOWERS
Employees on Job	
Vehicles or Equip. Used 5	

Meter Readers

Employees on Job

GF	
Areas - Read 20-21 STARTED 22	
Vehicles Used 3	

General Foreman

B. Smith

Date 8-4-20

Daily Job Sheet

Sheet 1 of 1

Water Department

Comments

Address Ex. 6 (Personal Privacy)

Jobs Completed

Employees on Job

66

INSTALL BY-PASS LEADER FOR
SERVICE AT
LOCATESEx. 6 (Personal Privacy)

Vehicles or Equip. Used

3

Sewer Department

Address

BY-PASS VIEWS

Jobs Completed

Employees on Job

44

Vehicles or Equip. Used

5

Meter Readers

Employees on Job

66

Areas - Read

22

READ Meters

Vehicles Used

3

General Foreman

H. J. Smith

Date 8-5-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

PULLED NEW SERVICE LINE UNDER ROAD
FOR **Ex. 6 (Personal Privacy)** USED ONE $\frac{3}{4}$ " FLARE
& COMP. FITTING, TWO $\frac{3}{4}$ " X $\frac{3}{4}$ " COMP. FITTINGS

Employees on Job

F.P. - B.S. - G.F.
445' OF $\frac{3}{4}$ " P.V.C. TUBING, 45' OF $\frac{3}{4}$ " COPPER
TUBING ~ BACKFILL WITH SPOIL.

Vehicles or Equip. Used

3-14- BACKHOL

EXPOSED MAIN & TAP & COPPER OUT OF BOX
AT **Ex. 6 (Personal Privacy)** FOR PULL JOB.

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
TIST & **Ex. 6 (Personal Privacy)**

Job Completed

CYCLED BLOWERS AT CROCKETTS, OAKLAND
LAURA, CYCLED PUMPS AT CLINTON,
Ex. 6 (Personal Privacy) BELLEVUE UP & ON

Employees on Job

G.F.
4 HR

BLUFF IS ON

Vehicles or Equip. Used

5

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 8-6-20

Daily Job Sheet

Sheet ___ of ___

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

PULLED NEW SERVICE LINE UNDER ROAD
AT **Ex. 6 (Personal Privacy)** - USED 90' OF 3/4" P.V.C.
TUBING, ONE 3/4" X 3/4" COMP. FITTING, ONE 3/4"

Employees on Job

F.P. - B.S. - G.F.
7 HRCOMP. NUT. BACKFILLED WITH SPOIC.
P.V.C. FROM METER TO MAIN

Vehicles or Equip. Used

3-2-14- BACKHOLE

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP
IN FIELD FROM RENOIS

Job Completed

CYCLED PUMP AT **Ex. 6 (Personal Privacy)**

Employees on Job

B.S. - G.F.
1 HRBROUGHT IN TO SHOP M.H. BROKEN RING
& GOOD LID FROM FIRST M.H. NORTH OF
LAURALIE DR.

Vehicles or Equip. Used

3- BACKHOLE

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 8-7-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address		SERVICE TRUCK W.O.
		LOCATES
Jobs Completed		
Employees on Job	G.F. 5 F.P. 2 hr	
Vehicles or Equip. Used	3	

Sewer Department		
Address		BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST & Ex. 6 (Personal Privacy)
Jobs Completed		CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING, Ex. 7f (Water Infra.) CYCLED PUMPS AT CLINTON, BLUFF, Ex. 6 (Personal Privacy)
Employees on Job	B.S. 4 hr F.P. 3 hr	JETTED LINE AT BATES Ex. 6 (Personal Privacy) RELIEVE BACKUP FOR Ex. 6 (Personal Privacy) USED VILLAGE JET TRUCK
Vehicles or Equip. Used	1-5- VILLAGE JET TRUCK	CHECKED STATIONS - ALL GOOD

Meter Readers	
Employees on Job	G.F. 3 hr F.P.
Areas - Read	FINISHED 22-G.F. - 23-F.P. - 24-F.P. & G.F.
Vehicles Used	1-3

General Foreman Frank J. Poel

Date 8-10-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

LOCATES

Jobs Completed

Employees on Job

G.F. F.P.
2 per 1 per

Vehicles or Equip. Used

1 - 3

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
71ST & **Ex. 7f (Water Infra.)** CALVIN BLVD,

Job Completed

CYCLED BLOWERS AT CROCKETS, OAKLAND,
PERSHING, 63RD **Ex. 7f (Water Infra.)** CYCLED PUMPS
AT CLINTON, BLUFF, **Ex. 6 (Personal Privacy)**

Employees on Job

F.P. - G.F.
3 per 6 per

Vehicles or Equip. Used

1-5-14

Meter Readers

Employees on Job

F.P.
4 perFINISHED
19426

Areas - Read

Vehicles Used

1

General Foreman

Frank J. Pace

Date 8-11-20

Daily Job Sheet

Sheet 1 of 1

Water Department

Comments

Address	Service TRUCK
Jobs Completed	
Employees on Job GF	
Vehicles or Equip. Used 3	

Sewer Department

Address	Checked SIATIONS
Jobs Completed	Cycled BLOWERS
Employees on Job BS	
Vehicles or Equip. Used 5	

Meter Readers

Employees on Job BS - GF	STARTED AREA 29
Areas - Read STARTED 29	
Vehicles Used 5-3	

General Foreman

[Signature]

Date 8-11-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	O.T. CALL OUT
Jobs Completed	REPAIRED 12" A.C. MAIN BREAK - USED TWO 12" 501 EXTREME DRESSERS & 59' OF 12" SDR P.V.C. PIPE
Employees on Job F.P. - B.S. - G.F.	DID NOT BACKFILL - BARRICADED OFF HOLE
Vehicles or Equip. Used	

Sewer Department

Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers

Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman

Frank J. Pace

Date 8-12-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	CALL OUT - O.T.
Jobs Completed	REPAIRED 12" A.C. MAIN BREAK AT Ex. 6 (Personal Privacy) - USED TWO 50' EXTREME PRESSURE 4 5/8" OF S.D.R. P.V.C. PIPE
Employees on Job F.P. - B.S. - G.F.	
Vehicles or Equip. Used 5-14-2 - BOTH BACKHOES	

Sewer Department

Address	
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	
Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman

Frank J. Pace

Date 8-12-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed	
Employees on Job G.F. F.P. G.M. J.M.	
Vehicles or Equip. Used 1-3-	

Sewer Department

Address	BY-PASS PUMPED WITH 24 GAS PUMP AT 71ST Ex. 7f (Water Infra.) VIOLET
Jobs Completed	CYCLER BLOWERS AT CROCKETT'S OAKLANDS, PERSHING, 63RD Ex. 7f (Water Infra.) CYCLER PUMPS AT CLINTON, BLUFF, Ex. 6 (Personal Privacy)
Employees on Job B.S. - F.P. 4HR 4HR	CHECKED STATIONS - NEED TO PULL CRESTON #1 & CLEAN
Vehicles or Equip. Used 1-5	

Meter Readers

Employees on Job <u>F.P.-G.F.</u> 2HR	FINISHED AREA 19 PUMPED OUT VAULTS
Areas - Read	
Vehicles Used 1-5	

General Foreman Frank J. Pace

Date 8-13-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
RE-READS

Jobs Completed

LOCATED VALVE IN MOUSETTE FOR
MOUSETTE FIRE LINE - VALVE IS OFF

Ex. 6 (Personal Privacy)

Employees on Job

G.F.

Vehicles or Equip. Used

3

Sewer Department

Address

PULLED PUMP #1 & CLEANED OUT RAGS
AT CROSTON

PUMPED BASEMENT OUT AT

Ex. 6 (Personal Privacy)

Jobs Completed

CYCLED BLOWERS AT CROCKETTS, OAKLAND,
PERSHING, 63RD - CYCLED PUMPS AT
CLINTON, BLUFF, &

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - B.S.

2 ME

INSTALLED TWO NEW BELTS ON PUMP #1
AT

Ex. 7f (Water Infra.)

Vehicles or Equip. Used

1-2-14 - BACKHOE

Meter Readers

Employees on Job

F.P. - B.S.
2 MEFINISHED AREAS
142

Areas - Read

Vehicles Used

1-2

General Foreman

Frank J. Pace

Date 8-14-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

COCATAS

Jobs Completed

Employees on Job

F.P.
GMR

Vehicles or Equip. Used

3

Sewer Department

Address

BY-PASS PUMPED WITH 2" GAS PUMP AT
71ST + **Ex. 7f (Water Infra.)** VIOLET,
CHURCH ST. STATION

Job Completed

CYCLED BLOWERS AT CROCKETS, OAKLAND,
PARSHING, G3 **Ex. 7f (Water Infra.)** CYCLED PUMPS
AT CLINTON, BLUFF, **Ex. 6 (Personal Privacy)**

Employees on Job

B.S. - F.P.
2 GMR

Vehicles or Equip. Used

5-14-BACKHOLE

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 8-17-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

LOCATES

Employees on Job

F.P. - G.F.
JMR

Vehicles or Equip. Used

Sewer Department

Address

BY-PASS PUMPED WITH BOTH 3" GAS PUMPS
AT 71ST **Ex. 7f (Water Infra.)** VIOLET,
FIELD FROM RENOIS, CHURCH RD.

Jobs Completed

CYCLAD BLOWERS AT CROCKETT, OAKLAND,
PERSHING, CYCLAD PUMPS AT CLINTON,
BLUFF, G3RD **Ex. 6 (Personal Privacy)**

Employees on Job

B.S. - F.P.
JMR

Vehicles or Equip. Used

5-1-BACKHOLE

Meter Readers

Employees on Job

F.P. - G.F. FINISHED
5MR JMR G.F. - 3 - F.P.

Areas - Read

Vehicles Used

1-3

General Foreman

Franky Price

Date 8-18-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

LOCATES

Employees on Job

B.S.
7 HR

Vehicles or Equip. Used

3

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
CHURCH RD. STATION

Job Completed

Employees on Job

B.S. - F.P.
1 HR

Vehicles or Equip. Used

1-3

Meter Readers

Employees on Job

F.P. - G.F.
1 HR

FINISHED AREAS

4-F.P. 8-G.F.

Areas - Read

STARTED AREAS

5-F.P. 9-G.F.

Vehicles Used

1-2

General Foreman

Frank J. Pace

Date 8-19-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

Employees on Job

B.S.
3 HR

Vehicles or Equip. Used

3

Sewer Department

Address

BY-PASS PUMPLE WITH 3" GAS PUMP AT
71ST & **Ex. 7f (Water Infra.)** CHURCH RD.

Job Completed

CYCLED BLOWERS AT CROCKETTS, OAKLAND,
PRESHING, GSRD **Ex. 7f (Water Infra.)** CYCLED PUMPS
AT CLINTON, BLOFF, **Ex. 6 (Personal Privacy)**

Employees on Job

G.F. B.S.
1 HR 5 HR

Vehicles or Equip. Used

2-5

Meter Readers

Employees on Job

F.P. - G.F.

FINISHED AREAS
5-F.P. 9 & 10-G.F.

Areas - Read

STARTED AREAS
6-F.P.

Vehicles Used

1-2

General Foreman

Frank J. Puse

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed		
Employees on Job G.F. 3 hr		
Vehicles or Equip. Used 3		
Sewer Department		
Address	BY-PASS PUMPED WITH BOTH 3" GAS PUMPS AT CHURCH RD. STATION - THEN PULLED PUMPS CLEANED OUT RAGS & RE-SET	
Job Completed	PUMP - PUMPING NOW.	
Employees on Job F.P. - G.F. B.S. 5 hr		
Vehicles or Equip. Used 1-5-7-14 - BACKHOE		
Meter Readers		
Employees on Job F.P. 3 hr	FINISHED AREA 6	
Areas - Read		
Vehicles Used 1		
General Foreman <u>Franky. Poe</u>		

Date 8-21-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		<u>Comments</u>
Address		SERVICE TRUCK WORK ORDERS
Jobs Completed		LOCATES
Employees on Job G.F. F.P. 4HR 6HR		
Vehicles or Equip. Used 1-3		

<u>Water Department</u>		
Address		BY-PASS PUMPED WITH BOTH 3" GAS PUMPS AT TISTE Ex. 7f (Water Infra.) FIELD FROM RENOIS Ex. 7f (Water Infra.) CALVIN BLVD.
Jobs Completed		CYCLED BLOWERS AT BAKLAND, CROCKETTS, PERSHING, 63R Ex. 7f (Water Infra.) CYCLED PUMPS AT CLINTON, BLUFF Ex. 6 (Personal Privacy)
Employees on Job F.P. - B.S. 2HR		DRESSED UP ROAD INTO FIELD FOR BY-PASS PUMPING RENOIS
Vehicles or Equip. Used 5 - BACKHOLE		

<u>Meter Readers</u>		
Employees on Job		
Areas - Read		
Vehicles Used		

General Foreman Frank J. Pace

Date 8-24-20

Daily Job Sheet

Sheet 1 of 1

Water Department

Comments

Address

Jobs Completed

Service TRUCK

Employees on Job

GF

Vehicles or Equip. Used

3

Sewer Department

Address

BY PASSED 71ST

Ex. 7f (Water Infra.)

Job Completed

Renov's

Employees on Job

BS

Vehicles or Equip. Used

5

Meter Readers

Employees on Job

GF


Areas - Read

11-12

Vehicles Used

3

General Foreman



Date 8-25-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

Employees on Job

G.F.

JMR

Vehicles or Equip. Used

3

Sewer Department

Address

PULLED PUMP & CLEANED OUT DISCHARGE
LINE AT **Ex. 6 (Personal Privacy)**

Job Completed

PULLED PUMP & CLEANED OUT RAGS AT
Ex. 6 (Personal Privacy)

Employees on Job

F.P. - B.S.

PULLED BACK OFF OF PUMP & CLEANED OUT
RAGS AT 5151 **Ex. 7f (Water Infra.)** PUMP IS STILL
STARVED FOR WATER FROM WELL - NEED TO
BY-PASS WELL & JET HEADER TOMORROW

Vehicles or Equip. Used

LOCATORS

1-5-14- BACKHOLE

Meter Readers

Employees on Job

G.F.
C.M.C.FINISHED
13

Areas - Read

Vehicles Used

3

General Foreman

Frank J. Pace

Date 8-26-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
RE-READS

Jobs Completed

Employees on Job

F.P. G.F.
1 HR 2 HR

Vehicles or Equip. Used

1- 3

Sewer Department

Address

PUMPED DOWN SYSTEM AT 51ST

Ex. 7f (Water Infra.)

Job Completed

CYCLED

Ex. 6 (Personal Privacy)

Employees on Job

G.F. F.P. - B.S.
2 HR 7 HR

Vehicles or Equip. Used

7-14-6" DIESEL PUMP

Meter Readers

Employees on Job

G.F.
4 HR

FINISHED
14

Areas - Read

STARTED
15

Vehicles Used

3

General Foreman

Frank J. Pace

Date 8-27-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F. 5 PR	
Vehicles or Equip. Used 3	

Sewer Department

Address	BY-PASSED SYSTEM DOWN AT 51ST & Ex. 7f (Water Infra.)
Job Completed	
Employees on Job F.P. - B.S.	
Vehicles or Equip. Used 7-14-6" GAS PUMP (VIA RCR)	

Meter Readers

Employees on Job G.F. 3	FINISHED 15
Areas - Read	
Vehicles Used 3	

General Foreman

Frank J. Pace

Date 8-28-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

BY-PASS PUMPED WITH 3" GAS PUMP AT
Ex. 7f (Water Infra.) PILL BOX, CALVIN BLVD,
[REDACTED]

CYCLED BLOWERS AT CROCKETT'S, OAKLAND,
PERSHING, 63RD Ex. 7f (Water Infra.)
AT CLINTON, BLUFF, Ex. 6 (Personal Privacy)

BY-PASS PUMPED WITH VILLAGE 6" GAS
PUMP AT 51ST Ex. 7f (Water Infra.)
Ex. 6 (Personal Privacy) OFF - SYSTEM DOWN

(VILLAGE)
7-14-5-6" GAS PUMP

Date 8-31-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

LOCATES

Jobs Completed

Employees on Job

F.P. G.F.
1 hr 6 hr

Vehicles or Equip. Used

14 - 3

Sewer Department

Address

BY-PASS PUMPS WITH BOTH 3" GAS PUMPS AT
51ST Ex. 7f (Water Infra.) FIELD FROM RENOS,
Ex. 7f (Water Infra.) CALVIN BLVD.

Job Completed

CYCLED BLOWERS AT CROCKETTS, OAKLAND,
PERSHING, 63RD Ex. 7f (Water Infra.) CYCLED PUMPS AT
CLINTON, BLUFF, Ex. 6 (Personal Privacy)

Employees on Job

G.F. - F.P. - B.S.
2 hr 7 hrPUMPS AT 51ST Ex. 7f (Water Infra.) 4" PUMP
FOR 1 1/2 HR + PUMP SHUT DOWN

Vehicles or Equip. Used

5-7-14-6" Pump (vacu)

Ex. 6 (Personal Privacy)

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 9-1-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F.	
Vehicles or Equip. Used 3	

Sewer Department

Address	BY-PASS PUMPED DOWN SYSTEM AT MARKET Ex. 7f (Water Infra.)
Job Completed	
Employees on Job F.P. - B.S. 2HR 4HR	
Vehicles or Equip. Used 7-14-6" PUMP (RENTAL)	

Meter Readers

Employees on Job F.P. - B.S. 6HR 4HR	FINISHED AREAS 17- F.P. - 18 B.S. & F.P.
Areas - Read	
Vehicles Used 1-2	

General Foreman

Frank J. Pace

Date 9-2-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	LOCATIONS
Employees on Job G.F. 5 HR F.P. 2 HR	
Vehicles or Equip. Used 1-3	

Sewer Department

Address	BY-PASS PUMPED DOWN SYSTEM AT MARKET JACKETED HEADER & SUCTION LINE TO STATION - NEEDED TO LET WELL FILL OVER
Job Completed	HEADER & TURN ON PUMP IN STATION
Employees on Job F.P. - G.F. - B.S. 6 HR 3 HR	
Vehicles or Equip. Used 5-7-14-BACKHOLE-6" PUMP	

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Ace

Date 9-3-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	EXPOSED 4" A.C. MAIN, INSTALLED SADDLE & CORP. STOP - MADE PUSH UNDER ROAD, BUILT SERVICE & HOOKED UP TO CUST. LINE
Employees on Job F.P.-B.S. G.F. 3 NR	USED 40' OF 3/4" P.V.C. TUBING, 10' OF 3/4" COPPER TUBING, ONE METER SHUT OFF, ONE METER COUPLING, ONE 1" BARBX 3/4" COMP. FITTING, ONE 18" X 30" P.V.C. METER BOX, ONE RING & LID & INSTALLED R.R. METER. AT
Vehicles or Equip. Used 3-14- BACKHOET MACHINE	HOOKED UP AND NEW LINE AT USED ONE 3/4" X 3/4" COMP. FITTING.

Ex. 6 (Personal Privacy)

Ex. 6 (Personal Privacy)

Sewer Department

Address	STARTED PUMP AT 50 ST. PUMPING NOW
Job Completed	
Employees on Job	
Vehicles or Equip. Used	
Meter Readers	
Employees on Job G.F. 5 NR	FINISHED 20
Areas - Read	STARTED 21
Vehicles Used 3	
General Foreman	Frank J. Rice

Ex. 7f (Water Infra.)

Water Department		Comments
Address	<u>SERVICE TRUCK WORK ORDERS</u> <u>LOCATES</u>	
Jobs Completed		
Employees on Job F.P. 6HR		
Vehicles or Equip. Used 1-3		
Sewer Department		
Address	BY-PASS PUMPED WITH BOTH 3" GAS PUMPS AT 7 th ST Ex. 7f (Water Infra.) CALVIN BLVD. Ex. 7f (Water Infra.) & FIELD FROM RENOID	
Job Completed	CYCLED BLOWERS AT CROCKETS, OAKLAND, PERSHING, CSRD Ex. 7f (Water Infra.) CYCLED PUMPS AT CLINTON, BLUFF, Ex. 6 (Personal Privacy)	
Employees on Job F.P. - B.S. 2HR		
Vehicles or Equip. Used 5 - BACKHOL		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	<u>Frank J. Pace</u>	

Date 9-7-20

Daily Job Sheet

Sheet of

<u>Water Department</u>	<u>Comments</u>
Address	
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

<u>Sewer Department</u>	
Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman	<u>Frank J. Pace</u>
-----------------	----------------------

Date 9-8-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	<u>SERVICE TRUCK WORK ORDERS</u> <u>LOCATES</u> <u>RE-READS</u>
Jobs Completed	
Employees on Job <u>F.P.</u> <u>GMC</u>	
Vehicles or Equip. Used <u>1-3</u>	

Sewer Department

Address	<u>BX-PASS PUMPED WITH BOTH 3" GAS PUMPS</u> <u>AT 71ST & RENOIR</u> <u>CALVIN BLVD.</u>
Job Completed	<u>CYCLED BLOWERS AT CROCKETS, OAKLAND,</u> <u>PERSHING, GSR</u> <u>CLINTON, BLUFF & YCLB PUMPS AT</u>
Employees on Job <u>F.P.</u> <u>2HR</u> <u>B.S.</u>	<u>NEED TO PULL</u> <u>HAD TO RE-SET STARTER AT BEECHLAND</u>
Vehicles or Equip. Used <u>BACKHOE - 5</u>	

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 9-9-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SEWICK TRUCK WORK ORDERS

Jobs Completed

Employees on Job

B.S.
4HR

Vehicles or Equip. Used

3

Sewer Department

Address

PULLED PUMP AT Ex. 6 (Personal Privacy) STATION
& TOOK TO SHOP

Job Completed

TRIED TO INSTALL NEW PUMP AT
Ex. 6 (Personal Privacy) BUT ELECTRIC BOX ON
POLE NERDS REPAIRED COULDN'T INSTALL

Employees on Job

F.P. - B.S.
4HR

Vehicles or Equip. Used

BACKHOE - 14

Meter Readers

Employees on Job

F.P.
4HRFINISHED
21

Areas - Read

STARTED
22

Vehicles Used

1

General Foreman

Frank J. Pace

Date 9-10-20

Daily Job Sheet

Sheet of

<u>Water Department</u>	
Comments	
Address	INSTALLED NEW SADDLE & CORP STOP, PULLED NEW LINE UNDER ROAD AT Ex. 6 (Personal Privacy) USED ONE 6" A.C. SADDLE, ONE 3/4" X 3/4" CORP STOP, ONE 3/4" BARBX COMP,
Jobs Completed	FITTING, TWO 3/4" P.V.C. INSERTS & 40' OF 3/4" P.V.C. TUBING - P.V.C. FROM MAIN TO METER DID NOT DISTURB BACKSIDE DUE TO EMPTY HOUSE
Employees on Job F.P. - B.S. 6 HR	
Vehicles or Equip. Used 14 - BACKHOLE	
<u>Sewer Department</u>	
Address	WIRED IN NEW PUMP & PUT IN WALL AT Ex. 6 (Personal Privacy) PUMP DID NOT PUMP SO WE PULLED IT BACK OUT & TOOK TO SHOP
Job Completed	
Employees on Job F.P. - B.S. 2 HR	
Vehicles or Equip. Used 14 - BACKHOLE	
<u>Meter Readers</u>	
<u>Employees on Job</u>	
<u>Areas - Read</u>	
<u>Vehicles Used</u>	
<u>General Foreman</u>	

Date 9-11-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
LOCATHS

Jobs Completed

Employees on Job

F.P.
GAR

Vehicles or Equip. Used

1-3

Sewer Department

Address

BY-PASS PUMPED WITH BOTH 3" GAS PUMPS
AT 7151 **Ex. 7f (Water Infra.)** RENOIS, **Ex. 7f (Water Infra.)**
CALVIN BLVD.

Job Completed

CYCLED BLOWERS AT CROCKETTS, OAKLAND,
PERSHING, 63RD **Ex. 7f (Water Infra.)** CYCLED PUMP AT
CLINTON

Employees on Job

F.P. - B.S.
JHR

JETTED LINE TO RELIEVE BACKUP AT
Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

1-5 - VILLAGE JET

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Rice

Date 9-14-20

Daily Job Sheet

Sheet ___ of ___

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed		
Employees on Job B.S. 1 hr		
Vehicles or Equip. Used 5		

Sewer Department		Comments
Address	BY-PASS PUMPED WITH BOTH 3" PUMPS AT 71ST & Ex. 7f (Water Infra.) RENOIS, Ex. 7f (Water Infra.) CALVIN BLVD	
Job Completed	CYCLED BLOWERS AT CROCKETS, OAKLAND, PERSHING, 63RD Ex. 7f (Water Infra.) CYCLED PUMPS AT CLINTON Ex. 7f (Water Infra.)	
Employees on Job F.P. B.S. 1 hr 7 hr		
Vehicles or Equip. Used 5 - BACKHOE		

Meter Readers	
Employees on Job F.P. - G.F. 7 hr	FINISHED AREAS 24 19-F.P. & G.F. - 22-F.P. 23-G.F.
Areas - Read	STARTED 26-G.F.
Vehicles Used 1-3	
General Foreman	Frank J. Pace

Date 9-15-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
RE-READS

Jobs Completed

REBUILT SERVICE AT Ex. 6 (Personal Privacy) DUE TO BROKE
GALVANIZED SET, - USED ONE $\frac{3}{4}$ " I.P. X $\frac{3}{4}$ "
COMP. FITTING, ONE METER COUPLING, ONE METER
SHUT OFF, ONE $\frac{3}{4}$ " BARB $\frac{3}{4}$ " COMP. FITTING,

Employees on Job

B.S. - G.F. - F.P.
4MRONE 18" X 30" P.V.C. METER BOX, 10' OF $\frac{3}{4}$ "
COPPER TUBING, PLASTIC FROM MAINTO
TAIL OUTSIDE BOX - GALVANIZED FROM TAIL
OUTSIDE BOX TO HOUSE - CUSTOMER SAYS

Vehicles or Equip. Used

2-3

THEY ARE GOING TO REPLACE THEIR LINE IN
NEAR FUTURE.Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

B.S. - F.P.
2MR 4MRFINISHED AREA
20 - F.P.

Areas - Read

STARTED AREA
29 - F.P. & B.S.

Vehicles Used

1

General Foreman

Frank J. Pace

Date 4-16-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed		
Employees on Job G.F. 4 HR		
Vehicles or Equip. Used 3		
Sewer Department		
Address	BY-PASS PUMPED DOWN SYSTEM WITH 6" DIESEL PUMP AT Ex. 6 (Personal Privacy)	
Job Completed		
Employees on Job F.P. - G.F. 2 HR 6 HR		
Vehicles or Equip. Used 14-7-1-3 6" PUMP		
Meter Readers		
Employees on Job F.P. - G.F. - B.S. GHR 2 HR	FINISHED 29-172	
Areas - Read		
Vehicles Used 1-3		
General Foreman	Frank J. Pace	

Date 9-17-20

Daily Job Sheet

Sheet of

Water Department	
Comments	
Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	PULLED NEW D.I.C. SERVICE LINE UNDER ROAD AT Ex. 6 (Personal Privacy) USED ONE 3/4" FLARE X COMP FITTING, ONE METER SHUTOFF ONE 3/4" X 3/4" COMP. FITTING, ONE 18" X 30"
Employees on Job F.P. - B.S. - G.F.	METER BOX, 30' OF 3/4" P.V.C. TUBING, 6' OF 3/4" COPPER TUBING - 3/4" P.V.C. FROM MAIN TO COPPER TAIL OUTSIDE BOX - DID NOT DISTURB BACKSIDE
Vehicles or Equip. Used 1-3-14 - BACKHOE	SHUT OFF SERVICE TO STOP LEAK AT Ex. 6 (Personal Privacy) DON'T KNOW LOT #

Sewer Department	
Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	
General Foreman	<u>Frank J. Pace</u>

Date 9-18-20

Daily Job Sheet

Sheet of

Water Department	Comments
Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	LOCATES
Employees on Job G.P. - F.P. 3 hr 3 hr	
Vehicles or Equip. Used 1-3	

Sewer Department	
Address	BY-PASS PUMPED WITH 3" GAS PUMPS AT TIST Ex. 6 (Personal Privacy) - RENOIS
Job Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING, 63RD Ex. 7f (Water Infra.) CYCLED PUMPS AT CLINTON, BLUFF, Ex. 6 (Personal Privacy)
Employees on Job B.S. - F.P. - G.P. 5 hr	BY-PASS PUMPED SYSTEM DOWN AT Ex. 6 (Personal Privacy) Ex. 6 (Personal Privacy) WITH 6" DIESEL PUMP
Vehicles or Equip. Used 1-7-14-6" Pump-Backhoe	WIRED IN & SET NEW PUMP AT Ex. 6 (Personal Privacy) Ex. 6 (Personal Privacy)

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	
General Foreman	Frank J. Pace

Date 9-28-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS RH - READS LOCATES
Jobs Completed	
Employees on Job F.P. - G.F. 4HR	
Vehicles or Equip. Used 1-3	

Sewer Department

Address	BY-PASS PUMPED WITH BOTH 3" GAS PUMPS AT 71ST Ex. 7f (Water Infra.) RENOIS, Ex. 7f (Water Infra.)
Job Completed	CYCLER BLOWERS AT CROCKETTS, OAKLAND, PERSHING, 63RD Ex. 7f (Water Infra.) PUMPS AT CLINTON, BLUFF, Ex. 6 (Personal Privacy)
Employees on Job F.P. - B.S. 4HR 6HR	TRIED TO JET DISCHARGE LINE AT AMES BUT COULDN'T GET THROUGH BLOCK PUT PLYWOOD OVER M.H. MISSING RING & Ex. 6 (Personal Privacy) Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 1-5-9	LIDS AT Ex. 6 (Personal Privacy) ACROSS FROM Ex. 6 (Personal Privacy) N. 73RD. CHECKED FOR BLOCK ON DOWDA BUT DIDN'T FIND ONE - OUR LINES ARE DOWN

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman Frank J. Pace

Date 9-21-20

Daily Job Sheet

Sheet 1 of 1

<u>Water Department</u>	
Comments	
Address	Service TRUCK
Jobs Completed	
Employees on Job	
GF	
Vehicles or Equip. Used	
3	

<u>Sewer Department</u>	
Address	By PASSED 71ST
Job Completed	cycled BLOWERS By PASSED CALVIN
Employees on Job	
BS	
Vehicles or Equip. Used	
5	

Meter Readers	
Employees on Job	
GF	
Areas - Read	
3 STARTED 4	
Vehicles Used	
3	
General Foreman	<u>Ba Smith</u>

Date 9-22-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

Employees on Job

B.S. - F.P.
GAR 2HR

Vehicles or Equip. Used

1-2

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
RENOIS Ex. 6 (Personal Privacy)

Job Completed

CYCLED PUMP AT Ex. 6 (Personal Privacy)

Employees on Job

F.P.
2HR

Vehicles or Equip. Used

Meter Readers

Employees on Job

F.P. - G.F.
4HR

FINISHED
4-G.F. 7-F.P.

Areas - Read

STARTED
5-G.F. 8-F.P.

Vehicles Used

1-3

General Foreman

Frank J. Pace

Date 9-23-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATED VALVE AT OLD 1574 Ex. 6 (Personal Privacy) BY TRACKS - 7'-8' DEEP	
Jobs Completed	RE-PLACED BROKEN SHUT OFF IN BOX AT Ex. 6 (Personal Privacy)	
Employees on Job F.P. - B.S. - G.F. GMR 4HR 3HR	TURNED ON CORP, STOP AT MAIN FOR Ex. 6 (Personal Privacy) INSTALLED METER	
Vehicles or Equip. Used 1-14-5-3-BACKHOE		
Sewer Department		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST & Ex. 7f (Water Infra.)	
Job Completed	CYCLED PUMPS AT CLINTON, BLUFF & Ex. 6 (Personal Privacy) CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING, 63RD Ex. 6 (Personal Privacy)	
Employees on Job B.S. - F.P. 4HR 3HR	INSTALLED RING & LID ON MANHOLE NORTH OF CADRALEE ON Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 5-14-BACKHOE		
Meter Readers		
Employees on Job G.F. 5HR	FINISHED 546	
Areas - Read		
Vehicles Used 3		
General Foreman	Frank J. Rice	

Date 9-24-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed	PUT BREAKER ON BACKHOLE & GOT MATERIALS READY FOR JOB AT	
Employees on Job	G.F. - B.S. - F.P. 1 HR	
Vehicles or Equip. Used	3 - SHOP	
Sewer Department		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job	FINISHED 708 - B.S. - 9 - F.P.	
Areas - Read		
Vehicles Used	1-2	
General Foreman	Frank J. Pace	

Ex. 6 (Personal Privacy)

Date 9-25-20

Daily Job Sheet

Sheet ___ of ___

Water Department	
Comments	
Address	EXPOSED MAIN/CORP STOP & SHUT OFF CORP. STOP - REMOVED SERVICE/BOX - TRIED TO PUSH CABLE THROUGH BUT COULD NOT GET CABLE OR FISH TAP THROUGH
Jobs Completed	OLD LINE - NEEDED TO MAKE PUSH UNDER ROAD AT Ex. 6 (Personal Privacy) BACKFILLED AROUND MAIN WITH CLEAN ROCK & TOPPED WITH CMG
Employees on Job F.P. - B.S.	
Vehicles or Equip. Used BOTH BACKHOES. BREAKER 14	

Sewer Department	
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST & Ex. 6 (Personal Privacy)
Job Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING, GSR Ex. 7f (Water Infra.) CYCLED PUMPS AT CLINTON, BLUFF, Ex. 6 (Personal Privacy)
Employees on Job G.P. 4 PM	
Vehicles or Equip. Used 5	

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman Frank J. Pace

Date 9-25-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	EXPOSED MAIN/CORP STOP & SHUT OFF CORP. STOP - REMOVED SERVICE/BOX - TRIED TO PUSH CABLE THROUGH BUT COULD NOT GET CABLE OR FISH TAP THROUGH
Jobs Completed	OLD LINE - NEEDED TO MAKE PUSH UNDER ROAD AT Ex. 6 (Personal Privacy) BACKFILLED AROUND MAIN WITH CLEAN ROCK & TOPPED WITH CMG
Employees on Job F.P. - B.S.	
Vehicles or Equip. Used BOTH BACKHOES - BREAKER 14	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.)
Job Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING, GSR Ex. 6 (Personal Privacy) CYCLED PUMPS AT CLINTON, BLUFF, Ex. 6 (Personal Privacy)
Employees on Job G.F. 4012	
Vehicles or Equip. Used 5	

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 9-29-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

REMOVED OLD SADDLE, INSTALLED OVERSIZED
G.H.A.C. S.S. REPAIR CLAMP, INSTALLED NEW
SADDLE + CORR. STOP, MADE TAP, PUSHED NEW
P.V.C. LINE UNDER ROAD, REBUILT SERVICE

Jobs Completed

AT **Ex. 6 (Personal Privacy)** NEED TO SET BOX &
BACKFILL AROUND BOX. - P.V.C. FROM MAIN
TO METER - COPPER FROM METER TO HOUSE

Employees on Job

F.P. - B.S. - G.F.

Vehicles or Equip. Used

1-14- BOTH BACKHOES

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 9-29-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address

REMOVED OLD SADDLE, INSTALLED OVERSIZED
G.H.A.C. S.S. REPAIR CLAMP, INSTALLED NEW
SADDLE & CORR. STOP, MADE TAP, PUSHED NEW
P.V.C. LINE UNDER ROAD, REBUILT SERVICE

Jobs Completed

AT **Ex. 6 (Personal Privacy)** NEED TO SET BOX &
BACKFILL AROUND BOX. - P.V.C. FROM MAIN
TO METER - COPPER FROM METER TO HOUSE

Employees on Job

F.P. - B.S. - G.F.

Vehicles or Equip. Used

1-14 - BOTH BACKHOES

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 9-30-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed	SET BOX & BACKFILLED WITH SPOIC GRADED ROAD WITH CLEAN ROCK & C-MG ROCK AT Ex. 6 (Personal Privacy)	
Employees on Job <u>B.S. - F.P. G.F.</u> <u>3 Hrs</u>	UNCRIMPED LINE IN DITCH & INSTALLED METER & TURNED ON AT Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 3-14- BACKHOL - 6		
Sewer Department		
Address	PUMPED WELL DOWN WITH 3" GAS PUMP & REMOVED BY-PASS PUMP AT SNOWS	
Job Completed	CYCLED STATIONS	
Employees on Job <u>F.P. - B.S.</u> <u>3 Hrs</u>		
Vehicles or Equip. Used 14- BACKHOL		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	<u>Franky Rice</u>	

Date 10-1-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS RR-READS LOCATES	
Jobs Completed	SHUT OFF CORP STOP AT MAIN F.P. ABANDON SERVICE TO Ex. 6 (Personal Privacy) HARVEST FILLED IN OLD METER BOX (EMPTY LOT)	
Employees on Job	F.P. - B.S. - G.F. 4 PM	
Vehicles or Equip. Used	3-14 - BACKHOL	
Sewer Department		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job	FINISHED 19 F.P. - B.S. 4 PM	
Areas - Read	STARTED 20	
Vehicles Used	1-2	
General Foreman	Frank J. Rice	

Date 10-2-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS RE-READS
Jobs Completed	
Employees on Job G.F. 7 HR	
Vehicles or Equip. Used 3	

Sewer Department

Address	BY-PASS PUMPED WITH BOTH 3" GAS PUMPS AT 71ST, Ex. 7f (Water Infra.) CALVIN, Ex. 7f (Water Infra.) RENOIS, SNOWS
Jobs Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING, 63RD, Ex. 7f (Water Infra.) CLINTON, BLUFF, Ex. 6 (Personal Privacy)
Employees on Job G.F., F.P. - B.S. 1 HR 4 HR	REMOVED OLD WET WELL LID & REPLACED WITH NEW LID AT SNOWS
Vehicles or Equip. Used 1-14-BACKHOE	

Meter Readers

Employees on Job F.P. 4 HR	FINISHED 20421
Areas - Read	STARTED 22
Vehicles Used 1	

General Foreman

Frank J. Pace

Date 10-5-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

Employees on Job

F.P.
G.P.

Vehicles or Equip. Used

3

Sewer Department

Address

BY-PASS PUMPED WITH BOTH 3" GAS PUMPS
AT 71ST & **Ex. 7f (Water Infra.)** VOLUNT, RENOIS

Job Completed

CYCLER BLOWERS AT CROCKETS, OAKLAND,
PERSHING, C3R **Ex. 7f (Water Infra.)** LLD PUMPS AT
CLINTON, BLUFF, **Ex. 7f (Water Infra.)**

Employees on Job

G.P. F.P.
T.H.R. I.H.R.

NRED TO JET DISCHARGE LINE AT CLINTON

Vehicles or Equip. Used

5 - BACKHOE

Meter Readers

Employees on Job

F.P. - G.P.
1 H.R.

STARTED

22-F.P. - 23-G.P.

Areas - Read

Vehicles Used

1-3

General Foreman

Frank J. Pace

Date 10-6-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

LOCATES

Employees on Job

G.F. - F.P.
4 HR 2 HR

Vehicles or Equip. Used

1-3

Sewer Department

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

G.F. - F.P.
4 HR 6 HR

FINISHED

23 & 24 - G.F.

22 & 26 - F.P.

Areas - Read

Vehicles Used

1-3

General Foreman

Frank J. Pace

Date 10-7-20

Daily Job Sheet

Sheet of

<u>Water Department</u>	
	Comments
Address	SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed	REPAIRED LEAK AT Ex. 6 (Personal Privacy) CT. (EMPTY LOT) - RESULT SERVICE WITH USED PARTS FROM SCRAP PILE DUE TO MAIN BEING
Employees on Job <u>G.F. - F.P.</u> 8 HR	LOCATED IN ROAD.
Vehicles or Equip. Used 1-3	
<u>Sewer Department</u>	
Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	
Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	
General Foreman <u>Frank J. Pace</u>	

Date 10-8-20

Daily Job Sheet

Sheet of

Water Department	
	Comments
Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	LOCATED FLYING J COMPLEX FOR MAYER
Employees on Job F.P. - G.F. GWR	
Vehicles or Equip. Used 1-3	

Sewer Department	
Address	CYCLAS PUMP AT Ex. 6 (Personal Privacy)
Job Completed	BY-PASS PUMPED Ex. 7f (Water Infra.)
Employees on Job F.P. 2WR	
Vehicles or Equip. Used 1	

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman Frank J. Pace

Date 10-9-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address	<u>SERVICE TRUCK WORK ORDERS</u> <u>LOCATES</u>	
Jobs Completed		
Employees on Job F.P. 5 HRC		
Vehicles or Equip. Used 3		
<hr/>		
Sewer Department		
<hr/>		
Address	BY-PASS PUMPED WITH BOTH 3" PUMPS AT 71ST Ex. 7f (Water Infra.) RENOIS, Ex. 7f (Water Infra.) CALVIN BLVD.	
Job Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING, C3RD Ex. 7f (Water Infra.) PUMPS AT CLINTON, BLUFF, Ex. 6 (Personal Privacy)	
Employees on Job G.F. - F.P. 3 HRC	FIXED KINKED DISCHARGE AT CLINTON	
Vehicles or Equip. Used 5-14-BACKHOLE		
<hr/>		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank J. Pace</u>		

Water Department		Comments
Address		Service TRUCK
Jobs Completed		
Employees on Job GF		
Vehicles or Equip. Used 3		
Sewer Department		
Address		By PASSED 71ST - Ex. 7f (Water Infra.)
Job Completed		cycled blowers
Employees on Job BS		
Vehicles or Equip. Used 5		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman		B. Smith

Date 10-13-20

Daily Job Sheet

Sheet 1 of 1

Water Department

Comments

Address

Service TRUCK

Jobs Completed

Employees on Job

BS GF

LOCATES

Vehicles or Equip. Used

S 3

Sewer Department

Address

BY PASSED RENOVIS

Job Completed

Cycled Blowers ON 73rd +
Ex. 7f (Water Infra.)

Employees on Job

BS

Vehicles or Equip. Used

S


Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman



11-13-20 41.

Date 10-13-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS <u>LOCATES</u>	
Jobs Completed		
Employees on Job F.P. G.F. 5 3		
Vehicles or Equip. Used 1-3		
Sewer Department		
Address	BY-PASS PUMPED WITH BOTH 3" GAS PUMPS AT 71ST Ex. 7f (Water Infra.) RENOIS, Ex. 7f (Water Infra.)	
Job Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING, CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy) BLUFF	
Employees on Job G.F. F.P. 5 3	WORKED ON 63RD Ex. 7f (Water Infra.) BACK ON AUTO D.T. Made Repairs	
Vehicles or Equip. Used 1-5-14		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>Frank - Pace</u>		

Date 10-14-20

Daily Job Sheet

Sheet 1 of 1

<u>Water Department</u>		Comments
Address		Service TRUCK
Jobs Completed		LOCATES
Employees on Job GF BS		
Vehicles or Equip. Used 3 + 2		
<u>Sewer Department</u>		
Address		Pulled RAGS AT BRIDGE DALE
Job Completed		
Employees on Job BS-GF		
Vehicles or Equip. Used 14-5		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman <u>B. Smith</u>		

Date 10-15-20

Daily Job Sheet

Sheet 1 of 1Water Department

Comments

Address

Jobs Completed

Service TRUCK

Employees on Job

BS GF

LOCATES

Vehicles or Equip. Used

3-2

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

BS-GF

Areas - Read

29

Vehicles Used

3

General Foreman

B. Linn

Water Department	Comments
Address	Service TRUCK
Jobs Completed	WORK orders
Employees on Job GF	
Vehicles or Equip. Used 3	

Sewer Department	
Address	By PASSED 71ST
Job Completed	Cycled Blowers & By PASSED Ex. 7f (Water Infra.)
Employees on Job BS	SPOKE TO HANKS ABOUT INSTALLING XTRA LATERAL
Vehicles or Equip. Used 5	

Meter Readers	
Employees on Job GF	
Areas - Read 1-2	
Vehicles Used 3	
General Foreman	B. Hunt

Date <u>10-19-20</u>		Daily Job Sheet		Sheet <u>1</u> of <u>1</u>	
Water Department		Comments			
Address					
Jobs Completed		Service TRUCK			
Employees on Job GF					
Vehicles or Equip. Used 3					
Sewer Department					
Address		Pooled Ex. 6 (Personal Privacy) Pump Removed RAGS - Reinstalled			
Job Completed		By PASS 71 ST. Ex. 7f (Water Infra.)			
Employees on Job GF BS		Renois - Ex. 7f (Water Infra.) - PERSHING AT LAURA			
Vehicles or Equip. Used 5 BACK HOE 14					
Meter Readers					
Employees on Job					
Areas - Read					
Vehicles Used					
General Foreman					

Date 10-20-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATES	
Jobs Completed	REMOVED LEAKING SADDLE & REPLACED WITH 4" A.C. S.S. REPAIR CLAMP - SADDLE WAS FOR [REDACTED] LOT IS AN EMPTY LOT.	
Employees on Job F.P. - B.S. - G.F. JMR	REMOVED RING & LINE FILLED IN BOX AT [REDACTED] BACKFILLED DRIVE WITH 3 BUCKETS CLEAN ROCK & ONE BUCKET C-M-G FROM SHOP.	
Vehicles or Equip. Used 3-14- BACKHOL	EXPOSED SERVICE AT [REDACTED] IT IS COPPER FROM MAIN TO METER. DID NOT EXPOSE BACKSIDE	
Sewer Department		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job G.F. JMR	FINISHED AREA 3	
Areas - Read	STARTED AREA 4	
Vehicles Used 3		
General Foreman <u>Frank J. Pace</u>		

Date 10-21-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS LOCATES FOR HANKS ON JUDITH
Jobs Completed	
Employees on Job F.P. - B.S. 1 HR G.F. 1 HR	
Vehicles or Equip. Used 3-14	

Sewer Department

Address	EXPOSED SEWER MAIN/LATERAL BEHIND AMES STATION & CYCLED STATION TO FIND REASON FOR BACKUP - STATION PUMPED FINE
Job Completed	FROM AMES TO OAKLAND - THINK PROBLEM WAS DUE TO SURCHARGED LINES LEADING TO OAKLAND. - NEED TO PUMP OAKLAND DOWN
Employees on Job F.P. - B.S. 7 HR	BEFORE TURNING AMES ON. LOCATES
Vehicles or Equip. Used 14 - BACKHOL	LOWERED PUMP AT

Ex. 6 (Personal Privacy)

Meter Readers	
Employees on Job G.F. 7 HR	FINISHED AREA 4
Areas - Read	STARTED 5
Vehicles Used 3	

General Foreman Frank J. Pace

Date 10-22-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	TURNED ON CORP. STOP AT MAIN & INSTALLED NEW METER AT Ex. 6 (Personal Privacy)
Employees on Job G.F. - F.P.-B.S. 2HR 2HR	
Vehicles or Equip. Used 3-14-BACKHOLE	

Sewer Department

Address	REMOVED 4" A.C. SEWER LATERAL & REPLACED WITH 4" P.V.C. - RAN P.V.C. INTO OLD CONCRETE BUTTON TEMPORARILY. EXPOSED
Job Completed	NEW 6" P.V.C. LINE TO TIE INTO - NEED TO FINAL GRADE & HOOK UP LATERAL AT Ex. 6 (Personal Privacy) REPAIRED HIT WATER
Employees on Job F.P.-B.S. - G.F. GHR 3HR	SERVICE LINE - USED ONE $\frac{1}{2}$ " x $\frac{3}{4}$ " COMP. & ONE $\frac{3}{4}$ " x $\frac{3}{4}$ " COMP. FITTINGS & 2' OF 6" P.V.C. TUBING AT Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 3-14-BACKHOLE	CYCLED Ex. 6 (Personal Privacy)

Meter Readers	
Employees on Job G.F. 3HR	FINISHED 5
Areas - Read	
Vehicles Used 3	
General Foreman	Frank J. Pace

Date 10-23-20

Daily Job Sheet

Sheet of

<u>Water Department</u>	
Comments	
Address	SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed	
Employees on Job F.P. - B.S. J.H.R.	
Vehicles or Equip. Used 2-3	

<u>Sewer Department</u>	
Address	REPLACES LATERAL AT Ex. 6 (Personal Privacy) USED ONE 4" CLAY X 4" P.V.C. PERNCO, 5 STICKS P.V.C., ONE 6" X 4" REDUCER - INSTALLED CLEANOUT FOR COST.
Job Completed	BY-PASS PUMPED WITH 6" PUMPS AT 71ST Ex. 71 (Water Infra.) PILL BOX, & RENOIS
Employees on Job F.P. - B.S. - G.F. G.H.R.	CYCLED BLOWERS AT AMES, CROCKETS, OAKLAND, PARSHING, CYCLAD PUMPS AT PARSHING, BLUFF, Ex. 6 (Personal Privacy) LAURA BLOWER
Vehicles or Equip. Used 5-14 - BACKHOL	

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman Frank J. Pace

Date 10-27-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed		
Employees on Job B.S. GHR		
Vehicles or Equip. Used 3		
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job B.S. - F.P. 2HR	FINISHED 647 - F.P.	
Areas - Read	STARTED 9-B.S. - 8-F.P.	
Vehicles Used 2-1		
General Foreman <u>Frank J. Pace</u>		

Date 10-26-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job B.S. 2 HR	
Vehicles or Equip. Used 3	

Sewer Department

Address	BY-PASS PUMPED WITH BOTH 3" GAS PUMPS AT 71ST Ex. 7f (Water Infra.) RENOIS Ex. 7f (Water Infra.)
Job Completed	CYCLED BLOWERS AT CROCKETS, OAKLAND, AMES, G3RD Ex. 7f (Water Infra.) AT CLINTON, BLUFF, Ex. 6 (Personal Privacy)
Employees on Job B.S. 6 HR	
Vehicles or Equip. Used 5	

Meter Readers	
Employees on Job F.P. 4 HR	STARTED AREA 6
Areas - Read	
Vehicles Used 1	
General Foreman	Frank J. Pace

Date 10-28-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job F.P. - B.S. C.F. 2 HR 1 HR	
Vehicles or Equip. Used 1-2-3	

Sewer Department

Address	BY-PASS PUMPED WITH 24 GAS PUMP AT 71ST+ Ex. 7f (Water Infra.)
Job Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, AMLS, GBR Ex. 7f (Water Infra.) CLINTON, BLOTT Ex. 6 (Personal Privacy)
Employees on Job B.S. 6 HR	
Vehicles or Equip. Used 5	

Meter Readers

Employees on Job F.P. - C.F. GPR 3 HR	FINISHED 8+10-G.F. 9-F.P.
Areas - Read	
Vehicles Used 1-3	

General Foreman Frank J. Pace

Date 10-29-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS LOCATES
Jobs Completed	
Employees on Job F.P. - B.S. 4 HR 2 HR	
Vehicles or Equip. Used 1 - 2	

Sewer Department

Address	CYCLED BLOWERS AT CROCKETTS, OAKLAND, AMRS, PERSHING - CYCLIC PUMPS AT CLINTON, BLUFF, Ex. 6 (Personal Privacy)
Job Completed	JETTED LINE TO RELIEVE BACKUP AT Ex. 6 (Personal Privacy) VILLAGE JET TRUCK
Employees on Job F.P. - B.S. 2 HR 6 HR	
Vehicles or Equip. Used 1 - 2 - VILLAGE JET	

Meter ReadersEmployees on JobAreas - ReadVehicles UsedGeneral Foreman Frank J. Pace

Date 10-30-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATES	
Jobs Completed		
Employees on Job F.P. - B.S. 4HR 2HR		
Vehicles or Equip. Used 2-3		
Sewer Department		
Address	BY-PASS PUMPED WITH BOTH 3" GAS PUMPS AT 71ST + Ex. 7f (Water Infra.) VIOLET, RENOIS	
Job Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, AMKS, PERSHING, CYCLED PUMPS AT CLINTON, BLUFF, Ex. 6 (Personal Privacy)	
Employees on Job F.P. B.S. 1HR 6HR		
Vehicles or Equip. Used 5		
Meter Readers		
Employees on Job F.P. 3HR	STARTED AREA 11	
Areas - Read		
Vehicles Used 1		
General Foreman	<u>Frank J. Pace</u>	

Date 11-2-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATRS	
Jobs Completed	REPLACED LEAKING SADDLE AT USED ONE 10" A.C. SADDLE, ONE 3/4" X 3/4" COMP. STOP, ONE 3/4" X 3/4" COMP. FITTING, 3' OF 3/4" COPPER TUBING - BACKFILLED YARD WITH SPOIL & DRIVE WITH ONE BUCKET CLEAN ROCK & ONE BUCKET C-M-G ROCK - COPPER FROM MAIN TO METER	
Employees on Job	F.P. - B.S. S.M. G.H.R.	
Vehicles or Equip. Used	3-1-14- BACKHOF	
<u>Sewer Department</u>		
Address		
Job Completed		
Employees on Job		
Vehicles or Equip. Used		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman	Frank J. Pace	

Ex. 6 (Personal Privacy)

Date 11-3-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed		
Employees on Job F.P. 1 HR		
Vehicles or Equip. Used 3		
Sewer Department		
Address	BY-PASS PUMPED WITH 3" GAS PUMP AT TIST4 Ex. 6 (Personal Privacy)	
Job Completed	CYCLED BLOWERS AT CROCKETS, OAKLAND, PERSHING, C3RD Ex. 7f (Water Infra.) CYCLED PUMPS AT CLINTON, BLUFF, Ex. 6 (Personal Privacy)	
Employees on Job F.P. 5 HR	APRS STATION SURCHARGING OUT OF MANHOLE AGAIN - SHUT OFF	
Vehicles or Equip. Used 5		
Meter Readers		
Employees on Job F.P. 2 HR	FINISHED AREA 11	
Areas - Read	STARTED AREA 12	
Vehicles Used 1		
General Foreman <u>Frank J. Pace</u>		

Date 11-4-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		<u>Comments</u>
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed		
Employees on Job B.S.		
Vehicles or Equip. Used 3		
<u>Sewer Department</u>		
Address	BY-PASS PUMPED WITH 24" GAS PUMP AT RENOIS, Ex. 7f (Water Infra.)	
Job Completed	CYCLED PUMPS AT BLOFF+ Ex. 6 (Personal Privacy)	
Employees on Job B.S.		
Vehicles or Equip. Used 5 - BACKHOE		
Meter Readers		
Employees on Job F.P. - B.S.	FINISHED 12-13 - F.P.	
Areas - Read	STARTED 14 - F.P. 15 - B.S.	
Vehicles Used 1-2		
General Foreman <u>Frank J. Pace</u>		

Date 11-5-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address		SERVICE TRUCK WORK ORDERS
Jobs Completed		
Employees on Job B.S. 3 HRE		
Vehicles or Equip. Used 3		
<u>Sewer Department</u>		
Address		CYCLED Ex. 6 (Personal Privacy) PUMP - NEED TO PULL PUMP & CLEAN
Job Completed		JETTED LINE TO RELIEVE BACKUP ON Ex. 6 (Personal Privacy) (VILLAGE TRUCK)
Employees on Job B.S. F.P. 3 HRE 1 HRE		
Vehicles or Equip. Used 2-1		
<u>Meter Readers</u>		
Employees on Job F.P. - B.S. 2 HRE 2 HRE		FINISHED 14 - B.S. 17 - F.P.
Areas - Read		STARTED 15 - B.S. 18 - F.P.
Vehicles Used 1-2		
General Foreman <u>Frank J. Pace</u>		

Date 11-6-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job F.P. - B.S. JMC 3HR	
Vehicles or Equip. Used 1-3	

Sewer Department

Address	BY-PASS PUMPS WITH BOTH 3" GAS PUMPS AT 21ST Ex. 7f (Water Infra.) RENOIS, Ex. 7f (Water Infra.)
Job Completed	CYCLAD BLOWING AT PARKETTE, OAKLAND, PERSHING, G3RD Ex. 7f (Water Infra.) AT CLINTON, BLUFF, Ex. 6 (Personal Privacy)
Employees on Job B.S. - F.P. SHR 1HR	
Vehicles or Equip. Used 5- BACKHOE	

Meter Readers

Employees on Job F.P. SHR	FINISHED 15 & 18
Areas - Read	
Vehicles Used 1	

General Foreman Frank J. Force

Date 11-9-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	<u>SERVICE TRUCK WORK ORDERS</u> <u>LOCATES</u>
Jobs Completed	
Employees on Job G.F. F.P. GHR 1 HR	
Vehicles or Equip. Used 3 ~ 1	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMPS AT 71ST Ex. 7f (Water Infra.) RENOIS, Ex. 7f (Water Infra.)
Job Completed	CYCLED BLOWERS AT CROCKFORD, OAKLAND, G3RA Ex. 7f (Water Infra.) CYCLED PUMPS AT CLINTON + BLUFF
Employees on Job F.P. - B.S. SHR	JETTED DISCHARGE LINE AT AMES STATION
Vehicles or Equip. Used 9-14-5- BACKHOL	PULLED PUMP AT Ex. 6 (Personal Privacy) TOOK TO SHOP & CLEANED,

Meter Readers

Employees on Job F.P. - G.F. SHR	FINISHED AREAS 19
Areas - Read	
Vehicles Used 1	

General Foreman

Frank J. Pace

Date 11-10-20

Daily Job Sheet

Sheet of

<u>Water Department</u>		Comments
Address	SERVICE TRUCK WORK ORDERS	
Jobs Completed		
Employees on Job B.S. GHR		
Vehicles or Equip. Used 2		
<u>Sewer Department</u>		
Address	INSTALLED NEW PUMP AT Ex. 6 (Personal Privacy)	
Job Completed	CYCLED PUMP AT Ex. 6 (Personal Privacy)	
Employees on Job F.P. - B.S. 2 HR		
Vehicles or Equip. Used 14 - BACKHOL		
Meter Readers		
Employees on Job G.F. - F.P. GHR	FINISHED 20 & 21 - G.F. 23 & 24 - F.P.	
Areas - Read	STARTED 22 - G.F.	
Vehicles Used 1 - 3		
General Foreman	Frank J. Pace	

Date 11-12-20

Daily Job Sheet

Sheet of

Water Department		Comments
Address	SERVICE TRUCK WORK ORDERS LOCATES	
Jobs Completed		
Employees on Job G.F. F.P. CNR 214R		
Vehicles or Equip. Used 3 - 1		
Sewer Department		
Address	PULLED PUMP, CLEANED & BROUGHT TO SHOP - Installed PUMP AT PUMPING NOW Ex. 6 (Personal Privacy)	
Job Completed	CHECKED STATIONS	
Employees on Job B.S. - F.P. CNR	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING, CSR Ex. 7f (Water Infra.) CYCLED PUMPS AT BLUFF + Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used 2-14- BACKHOL		
Meter Readers		
Employees on Job F.P. - G.F. 214R	FINISHED 22 - G.F. 26 - F.P.	
Areas - Read		
Vehicles Used 1 - 3		
General Foreman <u>Frank J. Pace</u>		

Date 11-11-20

Daily Job Sheet

Sheet ___ of ___

Water Department

Comments

Address	HOLIDAY
Jobs Completed	
Employees on Job	
Vehicles or Equip. Used	

Sewer Department

Address	VETERANS
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers	DAY
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman Frank J. Pace

Water Department		Comments
Address		
Jobs Completed		
Employees on Job		
Vehicles or Equip. Used		
Sewer Department		
Address		PULLER PUMP & CLEANED OUT RAGS AT Ex. 6 (Personal Privacy) PUMPING NOW.
Job Completed		BY-PASS PUMPED WITH 3" GAS PUMP AT 71ST Ex. 7f (Water Infra.) Ex. 7f (Water Infra.)
Employees on Job B.S. - F.P. 1042		CYCLED BLOWERS AT CROCKETTS OAKLAND, PERSHING, CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 5-14- BACKHOE		PUMPED OUT BOX AT 82ND Ex. 7f (Water Infra.)
Meter Readers		
Employees on Job F.P. 3442		FINISHED 142
Areas - Read		
Vehicles Used 1		
General Foreman <u>Frank J. Pace</u>		

Date 11-14-20

Daily Job Sheet

Sheet ____ of ____

<u>Water Department</u>		Comments
Address		
Jobs Completed		
Employees on Job		
Vehicles or Equip. Used		
<u>Sewer Department</u>		
Address		2 HR, CALL OUT O.T.
Job Completed		CHECKED FOR BACKUP AT CLARITA - OUR LINES DOWN & FLOWING, COST, PROBLEM - TALKED TO CUSTOMER
Employees on Job F.P.		
Vehicles or Equip. Used 14		
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman		Frank J. Pace

Ex. 6 (Personal Privacy)

Date 11-17-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	REPLACED CRUSHED BOX & GRADED TO ASPHALT AROUND BOX - BACKFILLED WITH 3 BUCKETS OF CLEAN ROCK & 1 1/2 BUCKETS OF C-MG
Employees on Job F.P. - B.S. SHE	ROCK AT Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 3-14. BACKHOE	

Sewer Department

Address	CYCLED PUMP AT Ex. 6 (Personal Privacy)
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers

Employees on Job F.P. 3042	STARTED 29
Areas - Read	
Vehicles Used 1	
General Foreman <u>Frank J. Pace</u>	

Date 11-18-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	REPAIRED LEAK AT Ex. 6 (Personal Privacy) IN Ex. 6 (Personal Privacy) REPLACED 2" 90° - USED ONE 90° M.I. FITTING & TWO 2" X 16" SOLID SLEEVES, 36" OF 2" SDR 26 P.V.C. PIPE
Jobs Completed	BACKFILLED WITH SPOIL. SET NEW WATER BOX OVER 8" C.I. MAIN & 2" CORP STOP ON OLD MD. - BACKFILLED REPAIR WITH 1/2
Employees on Job F.P. - B.S.	TRUCK LOAD OF CLEAN ROCK - BACKFILLED AROUND BOX WITH SPOIL.
Vehicles or Equip. Used 5-14 - BACKHOLE	

Sewer Department

Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	
Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	
General Foreman <u>Frank J. Pace</u>	

Date 11-19-20

Daily Job Sheet

Sheet of Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS
LOCATES

Jobs Completed

Employees on Job

F.P.
J.H.W.

Vehicles or Equip. Used

1

Sewer Department

Address

CYCLD BLOWERS AT CROCKETTS
CYCLD PUMPS AT BLUFF &

Ex. 7f (Water Infra.)

Ex. 6 (Personal Privacy)

Job Completed

INSTALLED TWO NEW FLOATBALLS AT
BLUFF & INSTALLED STARTER AT BLUFF

Employees on Job

F.P.
J.H.W.

INSTALLED TARP AT 63RD

Ex. 7f (Water Infra.)

Vehicles or Equip. Used

14

Meter Readers

Employees on Job

F.P.
J.H.W.

FINISHED AREA
29

Areas - Read

Vehicles Used

1

General Foreman

Frank J. Pace

Date 11-20-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job F.P. 3KCR	
Vehicles or Equip. Used 1	

Sewer Department

Address	BY-PASS PUMPED WITH BOTH 3" PUMPS AT TIST Ex. 7f (Water Infra.) RENOIS
Job Completed	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PERSHING, CYCLED PUMPS AT CLINTON & Ex. 6 (Personal Privacy)
Employees on Job F.P. 5KCR	PUT TARP ON BEECHLAND
Vehicles or Equip. Used 5 - BACKHOL	CHECKED BLUFF- FLOAT BALLS ADJUSTED TO PUMP

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman Frank J. Pace

Date 11-23-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address	<u>SERVICE TRUCK WORK ORDERS</u> <u>LOCATES</u>
Jobs Completed	
Employees on Job G.F. F.P. 1 HR 6 HR	
Vehicles or Equip. Used 3-1	

Sewer Department

Address	PULLED PUMP & CLEANED RACS OUT OF DISCHARGE AT Ex. 6 (Personal Privacy)
Job Completed	BY-PASS PUMPED WITH BOTH 3" GAS PUMPS AT TIS Ex. 7f (Water Infra.) & RHNOIS, Ex. 7f (Water Infra.)
Employees on Job F.P. - G.F. 2 HR 7 HR	CYCLD BLOWERS AT CROCKETS, OAKLAND, PERSHING, CYCLD PUMPS AT CLINTON & Ex. 6 (Personal Privacy)
Vehicles or Equip. Used 5-14- BACKHOES	BLUFF OFF DUE TO E. ST. LOUIS NOT TAKING FROM BELLEVUE

Meter ReadersEmployees on JobAreas - ReadVehicles UsedGeneral ForemanFrank J. Pace

Date 11-24-20

Daily Job Sheet

Sheet of Water DepartmentComments

Address	SERVICE TRUCK WORK ORDERS <u>LOCATIONS</u>
Jobs Completed	
Employees on Job F.P. 2 hr	
Vehicles or Equip. Used 1	

Sewer Department

Address	CYCLED BLOWERS AT CROCKETTS, OAKLAND, PARSHING - CYCLED PUMPS AT CLINTON Ex. 6 (Personal Privacy) BLUFF OFF
Job Completed	RE-SET STARTER AT Ex. 7f (Water Infra.) FRONT AT 12:30 P.M. - STILL PUMPING AT 4 Ex. 7f (Water Infra.) NE PUMP ON
Employees on Job F.P. 2 hr	
Vehicles or Equip. Used 1	

Meter Readers

Employees on Job G.F. F.P. 4 hr	FINISHED 728 - G.F.
Areas - Read	STARTED 3 - F.P.
Vehicles Used 1-3	

General Foreman	<u>Frank J. Price</u>
-----------------	-----------------------

Date 11-25-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job F.P. 2HR	
Vehicles or Equip. Used 1	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMPS AT 71ST Ex. 7f (Water Infra.) AURALEE
Job Completed	CYCLING BLOWERS AT CROCKETTS, OAKLAND PERSHING - CYCLING PUMPS AT CLINTON & Ex. 6 (Personal Privacy) BLUFF OFF DUE TO E. ST. LOUIS NOT TAKING
Employees on Job F.P. - G.F. 6HR 4HR	PULLED PUMP & CLEANED AT Ex. 6 (Personal Privacy) PULLED BACK OFF PUMP & CLEANED OUT RAGS/MOP AT Ex. 7f (Water Infra.)
Vehicles or Equip. Used 1-5-14-BACKHOLE	ONE PUMP ON AT 53RD Ex. 7f (Water Infra.) DUE TO SURCHARGE AT 54TH

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman Frank J. Pace

Date 11-26-20

Daily Job Sheet

Sheet ___ of ___

Water Department

Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

HOLIDAY

THANKS
6/11/20

Date 11-27-20

Daily Job Sheet

Sheet ___ of ___

Water Department

Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman Frank J. Pace

HOLIDAY

THANKSGIVING
FRIDAY

✓

Water Department		Comments
Address		
Jobs Completed		
Employees on Job 6F	Service TRUCK	
Vehicles or Equip. Used 3		
Sewer Department		
Address		By PASSED 71ST -
Job Completed		Cycled BLOWERS
Employees on Job BS	By PASSED Reno's Ex. 7f (Water Infra.)	
Vehicles or Equip. Used 5 BACKHOE	Pumped Ex. 6 (Personal Privacy) 1 HR	
Meter Readers		
Employees on Job		
Areas - Read		
Vehicles Used		
General Foreman		B. Seal

Date 11-1-20

Daily Job Sheet

Sheet 1 of 1Water Department

Comments

Address	
Jobs Completed	SERVICE TRUCK
Employees on Job GF BS	LOCATES
Vehicles or Equip. Used 3-1	

Sewer Department

Address	DUG OUT Line for FLOAT BAHS AT Ex. 6 (Personal Privacy)
Job Completed	Pulled Pump + Re INSTALLED AT Ex. 6 (Personal Privacy) NO RAGS
Employees on Job	
Vehicles or Equip. Used BACK HOE 14	

Meter Readers

Employees on Job BS GF	
Areas - Read finished 3 READING 9	
Vehicles Used 1-3	
General Foreman D. Smith	

Water Department		Comments
Address	Service TRUCK	
Jobs Completed		
Employees on Job 6 F		
Vehicles or Equip. Used 3		
Sewer Department		
Address	INSTALLED FLOAT BALLS AT Ex. 6 (Personal Privacy)	
Job Completed		
Employees on Job BS		
Vehicles or Equip. Used BACK HOC #14		
Meter Readers		
Employees on Job BS 6 F		
Areas - Read 9-10-4	FINISHED 9-10 STARTED 4	
Vehicles Used		
General Foreman	B. Smith	

Date 12-3-20

Daily Job Sheet

Sheet 1 of 1Water Department

Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

BS-GF

Areas - Read

FINISHED 4

STARTED 5 16

Vehicles Used

2-3

General Foreman

B. Smith

Date 12-4-20

Daily Job Sheet

Sheet 1 of 1Water Department

Comments

Address

Jobs Completed

Service TRUCK

Employees on Job

GF

Vehicles or Equip. Used

3

Sewer Department

Address

By PASSAL 71ST - cycled
blowers - By PASSAL

Ex. 7f (Water Infra.)

Job Completed

+ RENOIS

Employees on Job

BS - GF

Vehicles or Equip. Used

5- BACK HOE

Meter Readers

Employees on Job

BS - GF

Areas - Read

Finished 5+6

Vehicles Used

3-2

General Foreman

D. Smith

Date 12-7-20

Daily Job Sheet

Sheet 1 of 1Water Department

Comments

Address <u>HALLORAN</u> ↓ <u>Ex. 7f (Water Infra.)</u>	<u>POT Holed 4" A/C MAIN</u>
Jobs Completed	<u>Service TRUCK</u>
Employees on Job <u>BS-GF</u>	
Vehicles or Equip. Used <u>14 - BACK HOE</u> <u>#3</u>	

Sewer Department

Address	<u>Cycled Blowers</u> <u>BY PASSED 71ST</u>
Job Completed	<u>+</u> <u>Renois</u>
Employees on Job <u>BS</u>	
Vehicles or Equip. Used <u>5</u> <u>BACK HOE</u>	

Meter Readers

Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman

Water Department		Comments
Address	Service TRUCK	
Jobs Completed	DUG TAP HOLE FOR TAP AT HALLORAN	
Employees on Job	+ Ex. 6 (Personal Privacy)	
Vehicles or Equip. Used	BACK HOE	

Sewer Department	
Address	Re-Set STARTER AT I.C.S. STATION
Job Completed	
Employees on Job	BS
Vehicles or Equip. Used	3

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	
General Foreman	<u>B. Lunt</u>

Water Department	Comments
Address	
Jobs Completed	Service TRUCK
Employees on Job BS	SUPPORTE d NEW VALVE AT MISKELL Ex. 7f (Water Infra.) BACK FILLED
Vehicles or Equip. Used BACK HOE 3	

sewer Department	
Address	
Job Completed	
Employees on Job	
Vehicles or Equip. Used	

Meter Readers	
Employees on Job	
Areas - Read	
Vehicles Used	

General Foreman

Date 12-10-20

Daily Job Sheet

Sheet 1 of 1

Water Department

Comments

Address

RePAIred 6" MAIN

Jobs Completed

BLeAK AT DONALD
AND Ex. 6 (Personal Privacy)

Employees on Job

Used 1 6" A.C

Vehicles or Equip. Used

RePAIr CLAMP AND
30 TON CLEAN ROCK

sewer Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used


Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman



Water Department

Comments

Address	Service TRUCK WORK orders
Jobs Completed	
Employees on Job GF	
Vehicles or Equip. Used 3	

sewer Department

Address	Cycled BLOWERS - BY PASSED 71ST - Ex. 7f (Water Infra.) Renois
Jobs Completed	
Employees on Job BS	
Vehicles or Equip. Used BACK HOE 5	

Meter Readers

Employees on Job GF	
Areas - Read 4-6	
Vehicles Used 3	

General Foreman

B. Smith

Date 12-14-20

Daily Job Sheet

Sheet 1 of 1

Water Department

Comments

Address

Service TRUCK

Jobs Completed

Employees on Job

GF
BS

LOCATES

Vehicles or Equip. Used

3
5

Sewer Department

Address

BY PASSED 71ST
CYCLED BLOWERS

Jobs Completed

BY PASSED
11

Ex. 7f (Water Infra.)

RENDS

Employees on Job

BS

Vehicles or Equip. Used

BACK HOE
5


Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman



Date 12-15-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F. 4HR	
Vehicles or Equip. Used 3	

Water Department

Address	BY-PASS PUMPED WELL DOWN & PULLED PUMP AT Ex. 7f (Water Infra.)
Jobs Completed	
Employees on Job F.P. - G.F. 4HR 2HR	
Vehicles or Equip. Used 3-14-BACKHOLE	

Water Readers

Employees on Job G.F. F.P. 2HR 4HR	FINISHED 11-F.P.
Areas - Read	STARTED 15-G.F.
Vehicles Used 1-3	

General Foreman

Frank J. Pace

Date 12-16-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F. 1 KWR	
Vehicles or Equip. Used 3	

Water Department

Address	PULLED PUMP & CLEANED AT Ex. 6 (Personal Privacy)
Jobs Completed	
Employees on Job F.P. - G.F. 3 KWR 2 HWR	
Vehicles or Equip. Used 14 - BACKHOE	

Water Readers

Employees on Job F.P. - G.F. 5 KWR	FINISHED 12-P.P. 15-G.F.
Areas - Read	STARTED 13-P.P. 17-G.F.
Vehicles Used 1-3	

General Foreman

Frank J. Pace

Date 12-17-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F. 3 KMC	
Vehicles or Equip. Used 3	

Water Department

Address	BY-PASS PUMPED AT RENOIS HAULED 4 BUCKETS OF CLEAN ROCK TO ROAD INTO FIELD AT RENOIS
Jobs Completed	CYCLED AMES - OAKLAND Ex. 7f (Water Infra.) LOOKED FOR M.H. AT END OF Ex. 6 (Personal Privacy) FOR H.O.
Employees on Job F.P.	LOCATES
Vehicles or Equip. Used	

Meter Readers

Employees on Job G.F. K.M. S.M.R.	FINISHED 13414 - K.M. 17218 - G.F.
Areas - Read	
Vehicles Used 2-3	

General Foreman Frank J. Pace

Date 12-18-20

Daily Job Sheet

Sheet of Water Department

Comments

Address SERVICE TRUCK WORK ORDERS

Jobs Completed

Employees on Job

G.F.
1 HR

Vehicles or Equip. Used

3

Sewer Department

Address

BY-PASS PUMPS WITH 3" GAS PUMPS AT
Ex. 7f (Water Infra.) VIOLET, 71ST Ex. 7f (Water Infra.)

Jobs Completed

CYCLED BLOWERS AT CROCKETTS, OAKLAND,
PERSHING, - CYCLED PUMP AT CLINTON

Employees on Job

K.M. - F.P.
6 HR 4 HR

ADJUSTED BOTTOM BALL AT

Ex. 6 (Personal Privacy)

Vehicles or Equip. Used

1-5- BACKHOE

Meter Readers

Employees on Job

F.P. - G.F. - K.M.
4 HR 7 HR 3 HR

FINISHED

19 - G.F. & K.M. - 22 - G.F.

Areas - Read

STARTED

21 & 23 - F.P.

Vehicles Used

1-3

General Foreman

Franky Rose

Date 12-19-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	CALL OUT 2 HR D.T.
---------	-----------------------

Jobs Completed	LOCATED LINES AT
----------------	------------------

Ex. 6 (Personal Privacy)

Employees on Job F.P.	
--------------------------	--

Vehicles or Equip. Used 1	
------------------------------	--

Water Department

Address	
---------	--

Jobs Completed	
----------------	--

Employees on Job	
------------------	--

Vehicles or Equip. Used	
-------------------------	--

Water Readers

Employees on Job	
------------------	--

Areas - Read	
--------------	--

Vehicles Used	
---------------	--

General Foreman Frank J. Pace

Date 12-21-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

REPAIRED 4" CAST IRON MAIN BREAK
AT **Ex. 6 (Personal Privacy)** USED ONE 4" S.S.
REPAIR CLAMP - BACKFILLED SPOIL - WILL
NEED TO GO BACK & FIX YARD/DITCH

Jobs Completed

Employees on Job

F.P. - K.M. - P.C.
2 HR

Vehicles or Equip. Used

14 - BACKHOE

Sewer Department

Address

PULLED PUMP, CHECKED FOR BLOCKAGE -
NO BLOCKAGE - RE-SET PUMP & ADJUSTED
FLOAT BALLS AT 82ND **Ex. 7f (Water Infra.)**

Jobs Completed

Employees on Job

F.P. - K.M.

Vehicles or Equip. Used

14 - BACKHOE

Meter Readers

Employees on Job

T.C.
K.M. 6 HR
1 HR

FINISHED AREAS
20 & 21 - T.C. 23 - T.C. & K.M.

Areas - Read

Vehicles Used

5 & DROP OFF

General Foreman

Franky Pace

Date 12-22-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

Jobs Completed

SWAPT UP SHOP

Employees on Job

K.M. T.C. F.P.
2HR 2HR 7HR

Vehicles or Equip. Used

3-5

Sewer Department

Address

BY-PASS PUMPED WITH BOTH 3" GAS
PUMPS AT 71ST Ex. 7f (Water Infra.)

Ex. 7f (Water Infra.) RENOIS

Jobs Completed

CYCLED BLOWERS AT CROCKETTS, OAKLAND,
PARRISHING, CYCLED PUMP AT CLINTON

Employees on Job

K.M. - F.P.
6HR 11HR

Vehicles or Equip. Used

5- BACKHOE

Meter Readers

Employees on Job

T.C.
6HRFINISHED
24426

Areas - Read

Vehicles Used

DROP OFF

General Foreman

Frank J. Pace

Date 12-23-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	REPAIRED 4" CAST IRON MAIN BREAK ACROSS FROM Ex. 6 (Personal Privacy) USED ONE 4" C.I. X 12" S.S. REPAIR CLAMP - BACKFILLED
Employees on Job F.P. - T.C. - K.M. 7 HR 6 HR	ROAD WITH 1/2 TRUCK OF CLEAN ROCK & TWO BUCKETS OF C-M-G FROM MARTY
Vehicles or Equip. Used 1 - 14- BACKHOE	

Sewer Department

Address	BY-PASS PUMPED BEHIND Ex. 6 (Personal Privacy)
Job Completed	
Employees on Job F.P. 1 HR	
Vehicles or Equip. Used BACKHOE	

Meter Readers

Employees on Job T.C. - K.M. 2 HR	STARTED 29
---	---------------

Areas - Read

Vehicles Used

5

General Foreman

Frank J. Pace

Date 12-24-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

BY-PASS PUMPED WITH BOTH 3" GAS PUMPS
AT 71ST **Ex. 7f (Water Infra.)** VIOLET,
FIELD FROM RENOIS

CYCLED BLOWERS AT CROCKETTS, OAKLAND
PERSHING, CYCLED PUMP AT CLINTON

K.M. F.P.
JHR

5 - BACKHOE

T.C. - F.P. FINISHED
29

3

Francis J. Pace

Date 12-25-20

Daily Job Sheet

Sheet of Water Department

Comments

Address	CALL OUT DOUBLE TIME
Jobs Completed	REPAIRED 8" C.I. MAIN BREAK AT Ex. 6 (Personal Privacy) USED ONE 8" C.I. S.S. REPAIR CLAMP - HAULED 3 BUCKETS OF
Employees on Job F.P. - T.C. - K.M. 6HR 4HR 3HR	CLEAN ROCK TO COVER MAIN - NEED TO HAUL 102 BUCKETS CLEAN & 102 BUCKETS C-MG TO FINISH JOB, BARRICADED OFF.
Vehicles or Equip. Used	
5-14 - BACKHOLE BREAKER	

Water Department

Address

Job Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Areas - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 12-25-20

Daily Job Sheet

Sheet ___ of ___

Water Department

Comments

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Sewer Department

Address

Jobs Completed

Employees on Job

Vehicles or Equip. Used

Meter Readers

Employees on Job

Meters - Read

Vehicles Used

General Foreman

Frank J. Pace

HOLIDAY
CHRISTMAS

Date 12-28-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

REPAIRED 6" C.I. MAIN BREAK AT
Ex. 6 (Personal Privacy) USED ONE 6" C.I. S.S. REPAIR
CLAMP - BACK FILLED WITH 1/2 LOAD CLEAN ROCK
& 3 BUCKETS C-M-G ROCK

Jobs Completed

HAULED IN CLEAN ROCK & C-M-G ROCK TO
Ex. 6 (Personal Privacy) & FILLED IN ROAD WHERE
MAIN BREAK WAS REPAIRED ON 12-25-20

Employees on Job

F.P. - T.C. - K.M. D.T.
4 HR

Vehicles or Equip. Used

5-14 - BACKHOLE - 6

Sewer Department

Address

BY-PASS PUMPA WITH 3" GAS PUMP AT
715' Ex. 7f (Water Infra.)

Job Completed

CYCLED BLOWERS AT CROCKETTS, OAKLAND &
PERSHING - CYCLED PUMP AT CLINTON

Employees on Job

K.M.
4 HR

Vehicles or Equip. Used

5

Meter Readers

Employees on Job

T.C.
4

FINISHED AREAS
142 - T.C.

Areas - Read

Vehicles Used

DROP OFF

General Foreman

Frank J. Pace

Date 12-29-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

RA - READS

LOCATES

Jobs Completed

Employees on Job

F.P. - C.F.
GME

Vehicles or Equip. Used

1-3

Sewer Department

Address

BY-PASS PUMPED WITH 3" GAS PUMP AT
FIELD FROM RENOIS - Ex. 6 (Personal Privacy)

Job Completed

Employees on Job

F.P.
JMR

Vehicles or Equip. Used

BACKHOLE

Meter Readers

Employees on Job

T.C. - K.M.

FINISHED

304 - T.C.

708 - K.M.

Areas - Read

STARTED

5 - T.C.

Vehicles Used

5/DROP OFF

General Foreman

Frank J. Pace

Date 12-30-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address	SERVICE TRUCK WORK ORDERS
Jobs Completed	
Employees on Job G.F.	
Vehicles or Equip. Used 3	

Sewer Department

Address	BY-PASS PUMPED WITH 3" GAS PUMP AT Ex. 7f (Water Infra.) LAURALEE
Jobs Completed	CHANGED OIL IN BLOWERS AT CROCKETTS OAKLAND, PERSHING, BEECHLAND, C3RD Ex. 7f (Water Infra.)
Employees on Job F.P. - K.M. - T.C.	MANUALLY CYCLED AMES STATION
Vehicles or Equip. Used 14 - BACKHOL	

Water Readers

Employees on Job

Meters - Read

Vehicles Used

General Foreman

Frank J. Pace

Date 12-31-20

Daily Job Sheet

Sheet of

Water Department

Comments

Address

SERVICE TRUCK WORK ORDERS

LOCATES

Jobs Completed

Employees on Job

F.P.

Vehicles or Equip. Used

1

Sewer Department

Address

BY-PASS PUMPED WITH BOTH 3" GAS PUMPS
AT 2157
Ex. 7f (Water Infra.) RENOIS,
AVALARBE

Jobs Completed

TAPPED LINE BEHIND

Ex. 6 (Personal Privacy)

Employees on Job

F.P. - K.M.

Vehicles or Equip. Used

5 - BACKHOLE - 9

Meter Readers

Employees on Job

T.C.

FINISHED
5

Meters - Read

STARTED
6

Vehicles Used

DROP OFF

General Foreman

Frank J. Pace